



MAXXAM ANALYTICS  
#1 2080 39 Ave. NE, Calgary, AB  
T2E 6P7

maxxam.ca  
Toll Free 800-386-7247  
Fax 403-219-3673

**AMBIENT AIR MONITORING MONTHLY DATA REPORT**  
**PEACE RIVER AREA MONITORING PROGRAM COMMITTEE**  
**THREE CREEKS 842b STATION**

**JOB #: 8449-2017-01-80-C**

**January 2017**

Prepared for:

**PEACE RIVER AREA MONITORING PROGRAM COMMITTEE**  
SUITE #91, 305 - 4625 VARSITY DR. N.W.  
CALGARY, ALBERTA  
T3A 0Z9

**Attention: KARLA REESOR**

DATE: **February 22, 2017**

Prepared by:

---

Wunmi Adekanmbi, M.Sc., EPt.  
Project Manager, Customer Service, Air Services

Reviewed by:

---

Cheri Sinclair, B.Sc.  
Supervisor, Customer Service, Air Services

## SUMMARY

In January 2017, Maxxam Analytics was contracted to manage the ambient air quality monitoring and maintenance activities at the Three Creeks 842b Station, near Peace River Oil Sands Area 2, Alberta. The monitoring station provides continuous meteorological measurements and air quality data for compliance parameters, as requested by the PRAMP Committee.

All data collected this month was compliant with the requirements outlined in the Air Monitoring Directive (Alberta Environment and Parks, 2016).

The operational time for all continuous ambient air analyzers, meteorological systems and data acquisition systems were above the 90% requirement.

- **Power Failure:** Four hours of downtime were recorded for all parameters on January 5 due to a power failure. One more hour of downtime was incurred for SO<sub>2</sub> and Station Temperature, and two more hours for THC/CH<sub>4</sub>/NMHC, as the equipments were recovering from the power failure.
- **TRS:** A total of sixty-six hours of downtime were recorded this month. Sixty hours were attributed to a converter failure that occurred after the power failure on January 5 and the subsequent quality assurance activities performed to address the issue. Six hours were incurred as a result of maintenance and additional quality checks.

The summary of results is presented on the following pages.

Any deviations or modifications made to the sampling or analytical methods are outlined in Section 1.0, Discussion. On this basis, Maxxam Analytics is issuing this completed report to Peace River Area Monitoring Program Committee, Three Creeks 842b Station.

Should you have any questions concerning the results or if we can be of further assistance, please contact us at 403-219-3677 or toll-free at 1-800-386-7247.

---

### Monthly Continuous Data Summary

Peace River Area Monitoring Program Committee Three Creeks 842b Station					MAXIMUM VALUES							OPERATIONAL TIME (%)						
					1-HOUR				24-HOUR									
					PARAMETER	OBJECTIVES		EXCEEDANCES		MONTHLY AVERAGE	READING	DAY						
						1-hr	24-hr	1-hr	24-hr		READING	DAY						
SO <sub>2</sub> (ppb)	172	48	0	0	SO <sub>2</sub> (ppb)					0.1	1.7	26	1	15.4	SW	0.5	26	99.3
TRS (ppb)	-	-	-	-	TRS (ppb)					0.3	0.9	2, 2	11, 12	1.7 1.3	ENE NNE	0.6	2	91.1
THC (ppm)	-	-	-	-	THC (ppm)					1.94	2.30	8	4	2.2	E	2.10	2	99.1
CH <sub>4</sub> (ppm)	-	-	-	-	CH <sub>4</sub> (ppm)					1.94	2.30	8	4	2.2	E	2.10	2	99.1
NMHC (ppm)	-	-	-	-	NMHC (ppm)					0.00	0.04	2	10	1.7	E	0.00	ALL	99.1
RELATIVE HUMIDITY (%)	-	-	-	-	RELATIVE HUMIDITY (%)					78	97	20	2	5.5	S	92	4	99.5
BAROMETRIC PRESSURE (inHg)	-	-	-	-	BAROMETRIC PRESSURE (inHg)					27.78	28.36	7	VAR	VAR	VAR	28.30	7	99.5
AMBIENT TEMPERATURE (°C)	-	-	-	-	AMBIENT TEMPERATURE (°C)					-8.6	8.8	18	13	9.1	SSW	4.0	28	99.5
STATION TEMPERATURE (°C)	-	-	-	-	STATION TEMPERATURE (°C)					21.2	22.9	7	16	6.8	N	22.3	14	99.5
VECTOR WS (kph)	-	-	-	-	VECTOR WS (kph)					4.3	30.7	14	6	-	SW	20.3	14	99.5
VECTOR WD (deg)	-	-	-	-	VECTOR WD (deg)					218 (SW)	-	-	-	-	-	-	-	99.5

VAR-VARIOUS

SOUR GAS PROCESSING INDUSTRY  
MONTHLY REPORT SUMMARY

Three Creeks 842b Station

Plant Name / Location

Peace River Area Monitoring Program Committee

Company

Licence Number	Report Date	
	YEAR	MONTH
N/A	2017	January

CONTINUOUS AMBIENT MONITORING						
PARAMETER	STN No.	% TIME OPERATIONAL	ONE - HOUR AVERAGE		24 - HOUR AVERAGE	
			MAXIMUM VALUES	NO. READINGS > REGULATION	MAXIMUM VALUES	NO. READINGS > REGULATION
SO <sub>2</sub>	1	99.3	0.0017 ppm	0	0.0005 ppm	0
TRS	1	91.1	0.0009 ppm	-	0.0006 ppm	-
THC	1	99.1	2.30 ppm	-	2.10 ppm	-
CH <sub>4</sub>	1	99.1	2.30 ppm	-	2.10 ppm	-
NMHC	1	99.1	0.04 ppm	-	0.00 ppm	-
RH	1	99.5	97 %	-	92 %	-
BP	1	99.5	28.36 inHg	-	28.30 inHg	-
Ambient TPX	1	99.5	8.8 °C	-	4.0 °C	-
Station TPX	1	99.5	22.9 °C	-	22.3 °C	-
Wind Speed	1	99.5	30.7 kph	-	20.3 kph	-
Wind Direction	1	99.5	-	-	-	-

SIGNATURE OF COMPANY REPRESENTATIVE

FOR ALBERTA ENVIRONMENT USE ONLY

## Exceedance Summary Report

---

### SO<sub>2</sub> 1-Hour Exceedances

Measured concentrations of sulphur dioxide were below the 1-hour AAAQO of 172 ppb.

### SO<sub>2</sub> 24-Hour Exceedances

Measured concentrations of sulphur dioxide were below the 24-hour AAAQO of 48.0 ppb.

*In accordance with EPEA and the Substance Release Regulation.*

*In accordance with A Guide to Release Reporting and the Alberta Ambient Air Quality Objectives and Guidelines Summary.*

## TABLE OF CONTENTS

<u>Title</u>	<u>Page</u>
<b>SUMMARY</b>	1
<b>MONTHLY CONTINUOUS DATA SUMMARY REPORT</b>	2
<b>SOUR GAS SUMMARY REPORT</b>	3
<b>EXCEEDANCE SUMMARY REPORT</b>	4
<b>TABLE OF CONTENTS</b>	5
<b>1.0 Discussion</b>	<b>6</b>
<b>2.0 Project Personnel</b>	<b>9</b>
<b>3.0 Plant Monthly Required AMD Summary</b>	<b>9</b>
<b>4.0 Calculations and Results</b>	<b>9</b>
<b>5.0 Methods and Procedures</b>	<b>10</b>
 <b>Appendix I</b>	<b>Continuous Monitoring Data Results</b>
	13
	Sulphur Dioxide
	14
	Total Reduced Sulphur
	22
	Total Hydrocarbon
	30
	Methane
	38
	Non-Methane Hydrocarbon
	46
	Wind Speed
	54
	Wind Direction
	61
	Relative Humidity
	64
	Barometric Pressure
	67
	Ambient Temperature
	70
	Station Temperature
	73
 <b>Appendix II</b>	<b>Equipment Calibration Results</b>
	76
	Sulphur Dioxide
	77
	Total Reduced Sulphur
	80
	Total Hydrocarbon
	88
	Wind System
	92
	Calibrators
	94
	Calibration Gases
	98
 <b>Appendix III</b>	<b>Report Certification Form</b>
 <b>Appendix IV</b>	<b>Data Validation Certification Form</b>
	103
	105

## 1.0 Discussion

This monthly report consists of continuous monitoring results for the following parameters: Sulphur Dioxide (SO<sub>2</sub>), Total Reduced Sulphur (TRS), Total Hydrocarbon (THC), Methane (CH<sub>4</sub>), Non-Methane Hydrocarbon (NMHC), Relative Humidity (RH), Barometric Pressure (BP), Ambient Temperature (AmbTPX), Station Temperature (StnTPX), Wind Speed (WS) and Wind Direction (WD).

Sample filters for all continuous air monitors are changed before the calibration begins. The sample manifold is cleaned during the site visit each month.

Control checks, consisting of a zero and span, are conducted daily on all continuous air monitors. In place of the air sample, zero air (from scrubbed air or gas cylinders) is used for zero checks, and a known concentration of the pollutant being analyzed is used for span checks. These checks are controlled by automatic timers and valves. The total zero span cycle is completed within an hour, the commencement of the zero span cycle is at the beginning of the hour.

Multipoint calibrations are done a minimum of once a month for each continuous air monitor. An additional calibration is required under the following conditions: 1) within three days after the initial start-up and stabilization of a newly installed instrument, 2) prior to shut-down or moving of an instrument which has been working to specification, and 3) when major repair has been done on the instrument.

Time during the first multi-point calibration is not considered downtime (Data is flagged as C). If more than one calibration is performed during the month, the time during the additional calibration is considered as downtime (Data is flagged as C1).

Only one zero/span check is run per day. Time during the zero/span check is not considered as downtime (Data is flagged as S). If an extra zero/span check is performed, the time during the additional check is considered as downtime (Data is flagged as S1).

The AMD requires each instrument and accompanying data recording system to be operational 90% of the time, at a minimum, for each monthly monitoring period.

All sampling, analysis, and QA/QC for this project was performed by Maxxam Analytics and complies with the Alberta Air Monitoring Directive.

Data contained in this monthly report has undergone the verification and validation based on the requirements of the AMD Chapter 6: [Ambient Data Quality \(August 3, 2016\)](#). The descriptions of the data verification and validation process can be found in Section 5 of this report. Instantaneous data, where applicable, is provided for reference purposes and has not undergone zero correction.

Hourly/minute data have been reviewed based on daily zero/span results and multi-point calibration results. Data may be considered invalid if a zero-corrected span check in excess of +/- 10% of the span concentration (established by the previous multi-point calibration) is encountered and/or significant differences in the calibration factor occurs (greater than 10%).

**SULPHUR DIOXIDE (SO<sub>2</sub>)**

- The routine monthly calibration was performed on January 4.
- Four hours of downtime were recorded from hour 09:00 to hour 12:00 on January 5, due to a power failure. Data collected at hour 13:00 was invalidated as the analyzer was recovering from the power failure.

**TOTAL REDUCED SULPHUR (TRS)**

- A shut-down calibration was performed on January 4 prior to a scheduled maintenance. Maintenance was conducted on the converter and the thermocouple; a successful post-repair calibration was subsequently completed. Two hours of downtime were incurred during this maintenance event.
- The analyzer did not span correctly after a power failure that occurred on January 5. It was determined that the converter had failed during the power failure. The converter was replaced on January 7, followed by a successful post-repair calibration. Data was invalidated back to just before the power failure occurred, which was on January 5 at hour 08:00. Sixty hours of downtime were incurred as a result.
- An additional zero/span check was triggered remotely on January 18 and a 3-point repeat calibration was performed onsite on January 20, as quality assurance measures. This is because the analyzer was showing biased low zero and biased high span trends, within acceptance limits. Four hours of downtime were recorded as a result of these additional quality checks.
- Maximum instantaneous data collected between the calibration on January 7 and the one on January 20 appear to be lower than hourly data collected at the same period. This is because for instantaneous data, negative readings were corrected to zero but baseline zero correction was not applied.

**TOTAL HYDROCARBONS (THC), METHANE (CH<sub>4</sub>) and NON-METHANE HYDROCARBONS (NMHC)**

- The routine monthly calibration was performed on January 4.
- Four hours of downtime were recorded from hour 09:00 to hour 12:00 on January 5, due to a power failure. Data collected at hours 13:00 and 14:00 were invalidated as the analyzer was recovering from the power failure.
- The span gas cylinder was replaced on January 20. An additional span check was triggered afterwards, one hour of downtime was incurred as a result.
- Slight, sporadic noise was noted for the NMHC parameter when sampling ambient air and this is reflected in the NMHC instantaneous maximum data. With the exception of two isolated instances (January 2 at hour 10:00 - 0.21 ppm; and January 7 at hour 18:00 - 0.25 ppm) this noise remained below the acceptable threshold for this parameter based on AMD requirements (0.2 ppm) and, at all times, remained below a level that might trigger a VOC canister (0.3 ppm). This noise had minimal effect on hourly average data and given the analyzer was demonstrated to be operating within accepted limits ,this noise is considered not to be significant. That said, these data are monitored on a daily basis and, should the data quality begin to deteriorate, the analyzer will be replaced
- The canister sampler is programmed to draw in a whole air sample when the 5-minute average concentration of NMHC is above 0.30 ppm. A representative sample of ambient air is collected over a one-hour period when the canister event is triggered. No canister event was recorded this month.

**WIND SPEED (WS) and WIND DIRECTION (WD)**

- The wind system was working well throughout the month. Wind data is reported as vector wind speed and vector wind direction. Wind direction is defined as the direction from which the wind is blowing from and is measured in degrees from true north.
- Four hours of downtime were recorded from hour 09:00 to hour 12:00 on January 5, due to a power failure.

**RELATIVE HUMIDITY (RH)**

- Four hours of downtime were recorded from hour 09:00 to hour 12:00 on January 5, due to a power failure.

**BAROMETRIC PRESSURE (BP)**

- Four hours of downtime were recorded from hour 09:00 to hour 12:00 on January 5, due to a power failure.

**AMBIENT TEMPERATURE (AmbTPX)**

- Four hours of downtime were recorded from hour 09:00 to hour 12:00 on January 5, due to a power failure.

**STATION TEMPERATURE (StnTPX)**

- Four hours of downtime were recorded from hour 09:00 to hour 12:00 on January 5, due to a power failure. Data collected at hour 13:00 was invalidated as the temperature sensor was recovering from the power failure.

## **2.0 Project Personnel**

Karla Reesor was the contact for Peace River Area Monitoring Program Committee and the Maxxam field technicians were Raja Ashraf and Russel Kirchner.

## **3.0 Plant Monthly Required AMD Summary**

All data collected this month was compliant with the requirements outlined in the Air Monitoring Directive (Alberta Environment and Parks, 2016).

The operational time for all continuous ambient air analyzers, meteorological systems and data acquisition systems were above the 90% requirement.

## **4.0 Calculations and Results**

All calculations and reporting of results follow the methods described in the AMD, 2016.

## 5.0 Methods and Procedures

The following methods and procedures were used to complete the monitoring program:

- Maxxam AIR SOP-00001 - Methane, Non-Methane Hydrocarbon Analyzer Monitoring
- Maxxam AIR SOP-00208: RM Young Wind Monitor Calibration
- Maxxam AIR SOP-00209: Ambient Sulphur Monitoring

There were no deviations from the prescribed methods.

The following instruments were used to perform the test program:

- Sulphur Dioxide - API 100A UV Flourescent Analyzer
- Total Reduced Sulphur - Thermo 43i UV Flourescent Analyzer
- Methane, Non-Methane Hydrocarbon - Thermo 55i FID Analyzer
- Wind System - RM Young Unit
- Relative Humidity - RM Young Unit
- Barometric Pressure - Met One Unit
- Ambient Temperature - RM Young Unit
- Datalogger - ESC 8832

The following steps were used to complete the data verification and validation process:

**Level 0 Preliminary Verification**

Level 0 data are raw data obtained directly from the data acquisition system (DAS). Under the step of Level 0, these data undergo a certain amount of manual or automated screening and flagging. It included a) identification of periods of missing data; b) verification of time stamps against reference time; c) verification that instrument diagnostics/datalogger flags indicate normal operation; d) comparison of data to upper and lower limits; e) rate of change flagging indicating that data changed too rapidly or not at all; and f) verification that zero, span and multipoint performance checks are within specifications. This level of verification is performed on a daily basis.

**Level 1 Primary Validation**

Validation actions under the step of Level 1 include a) review of all screening flags assigned during preliminary verification; b) review of all supporting site information and documentation; c) review of operational acceptance limits for each parameter/analyser; d) review of daily zero/span and monthly calibration results for all gaseous parameters; and e) application of any necessary adjustments to data (e.g. baseline adjustments, below zero adjustments). This level of validation is performed on a monthly basis.

**Level 2 Final Validation**


The purpose of Level 2 validation is to verify that there are no inconsistencies among related data, or among regional data measured at nearby sites.

**Level 3 Independent Data Review**

Level 3 validation is the last step of data review, and it is completed by an individual that is independent of both field operations and primary data validation. A final independent QA review and endorsement is performed during this step before data is submitted to Alberta Environment.

**Post-Final Validation**

The Post-Final Validation step serves to re-evaluate the data that errors or omissions are discovered and/or suspected after the initial submittal of data. Any data issues or patterns which were not clear on a monthly basis are highlighted during this step. This validation is performed on an annual basis.



Source: Air Monitoring Directive (Aug 3, 2016), Chapter 6, Ambient Data Quality; Figure 1 Data Collection and Management Process Flow Chart


**APPENDIX I**  
***CONTINUOUS MONITORING DATA RESULTS***

***SULPHUR DIOXIDE***

SULPHUR DIOXIDE Hourly Averages (SO<sub>2</sub> ppb)


	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.			
	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59							
DAY																																
1		0.1	0.0	0.0	0.4	0.3	0.0	0.0	0.0	0.0	0.0	0.1	0.7	0.4	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.1	24		
2		0.1	0.1	0.0	0.1	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.4	0.3	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.1	24		
3		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	24		
4		0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	C	C	C	C	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	24
5		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	P	P	P	R	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19		
6		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	24	
7		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	24	
8		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24		
9		0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	S	0.3	0.2	0.2	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.3	0.1	24	
10		0.1	0.2	0.4	0.3	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.3	0.0	0.4	0.1	24				
11		0.2	0.3	0.1	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.3	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.1	24		
12		0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.3	0.2	0.0	0.1	0.1	0.2	0.1	0.2	0.2	0.2	0.0	0.0	0.0	0.0	0.3	0.1	24		
13		0.2	0.0	0.0	0.0	S	0.0	0.1	0.1	0.0	0.1	0.0	0.2	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.0	24		
14		0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.2	0.2	0.1	0.0	0.0	0.2	0.1	24			
15		0.1	S	0.0	0.1	0.0	0.1	0.2	0.2	0.2	0.2	0.3	0.2	0.0	0.3	0.1	0.2	0.1	0.3	0.2	0.1	0.1	0.1	0.3	0.0	0.0	0.3	0.2	24			
16		S	0.2	0.2	0.2	0.1	0.2	0.3	0.3	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.2	S	0.0	0.0	0.3	0.1	24			
17		0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	S	0.1	0.0	0.1	0.0	24				
18		0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	24			
19		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	24
20		0.0	0.0	0.0	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	S	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	24
21		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24
22		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0	S	0.2	0.0	0.2	0.3	0.1	0.0	0.0	0.0	0.3	0.1	24	
23		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.0	24	
24		0.1	0.0	0.1	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.5	0.7	0.7	0.9	0.9	1.0	0.6	0.3	0.2	0.2	0.1	0.0	0.0	0.0	0.0	1.0	0.3	24			
25		0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.3	0.3	0.7	S	0.5	0.6	0.4	0.2	0.3	0.4	0.7	0.9	1.2	0.0	1.2	0.3	24				
26		1.5	1.7	1.5	0.8	0.6	0.3	0.3	0.2	0.1	0.2	0.1	0.0	0.3	S	0.2	0.0	0.0	0.6	0.5	0.5	0.4	0.7	0.7	0.5	0.3	1.7	0.5	24			
27		0.0	0.0	0.0	0.2	0.0	0.1	0.2	0.1	0.1	0.1	0.4	S	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.4	0.1	24			
28		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	24		
29		0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.3	0.2	0.2	S	0.1	0.0	0.3	0.1	0.0	0.2	0.4	0.3	0.2	0.2	0.1	0.0	0.0	0.4	0.1	24			
30		0.3	0.4	0.2	0.2	0.3	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.4	0.1	24			
31		0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	S	0.1	0.3	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	24			
HOURLY MAX		1.5	1.7	1.5	0.8	0.6	0.3	0.3	0.3	0.3	0.7	0.7	0.9	0.9	0.5	1.0	0.6	0.5	0.4	0.7	0.7	0.9	1.2									
HOURLY AVG		0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	24		

## 24 HR AVERAGES January 2017



NUMBER OF 1-HR EXCEEDANCES:	0	NUMBER OF 24-HR EXCEEDANCES:	0	NUMBER OF NON-ZERO READINGS:	250	MINIMUM 1-HR AVERAGE:	0.0	MAXIMUM 1-HR AVERAGE:	1.7	MAXIMUM 24-HR AVERAGE:	0.5	ON DAY(S)	ALL
						@ HOUR(S)			1	ON DAY(S)	26		
										ON DAY(S)	26		
										VAR-VARIOUS			
I2S CALIBRATION TIME:	30	hrs	OPERATIONAL TIME:	739	hrs								
MONTHLY CALIBRATION TIME:	4	hrs	AMD OPERATION UPTIME:	99.3	%								
STANDARD DEVIATION:	0.2		MONTHLY AVERAGE:	0.1	ppb					</			

SULPHUR DIOXIDE Hourly Averages (SO<sub>2</sub> ppb)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE

Three Creeks 842b Station - January 2017

SULPHUR DIOXIDE Instantaneous Maximum (SO<sub>2</sub> ppb)

	HR START (MST) 0:00 HR END (MST) 0:59	0:00 1:59	1:00 2:59	2:00 3:59	3:00 4:59	4:00 5:59	5:00 6:59	6:00 7:59	7:00 8:59	8:00 9:59	9:00 10:59	10:00 11:59	11:00 12:59	12:00 13:59	13:00 14:59	14:00 15:59	15:00 16:59	16:00 17:59	17:00 18:59	18:00 19:59	19:00 20:59	20:00 21:59	21:00 22:59	22:00 23:59	23:00 DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
DAY																													
1	0.7	0.4	0.4	1.3	1.3	0.4	0.4	0.4	0.4	1.0	1.9	1.6	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	1.9	0.6	24		
2	0.7	0.7	0.4	0.4	0.4	0.7	0.7	0.4	0.4	0.4	1.0	1.0	0.4	S	0.1	0.1	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.1	1.0	0.5	24	
3	0.4	0.4	0.4	0.4	0.4	0.1	0.4	0.4	0.1	0.4	0.4	0.4	0.4	0.4	S	0.4	0.4	0.4	0.4	1.0	1.0	0.7	0.7	0.4	0.4	1.0	0.5	24	
4	0.7	0.7	0.4	0.7	0.4	0.4	0.4	0.7	0.7	0.4	0.4	0.4	P	P	P	R	1.3	0.7	0.4	0.4	0.4	0.7	0.7	0.4	0.4	0.4	1.3	0.5	19
5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	P	P	P	R	1.3	0.7	0.4	0.4	0.4	0.7	0.7	0.4	0.4	0.4	1.3	0.5	24
6	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	S	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.4	1.0	0.7	24	
7	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	S	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.1	1.6	0.5	24	
8	0.4	0.4	0.7	0.4	0.4	0.7	0.7	0.4	S	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.7	0.5	24	
9	0.7	1.0	1.0	1.0	0.7	1.0	1.0	S	1.0	0.7	0.7	1.0	1.0	0.7	0.4	0.7	0.7	0.7	0.4	0.7	0.7	0.7	0.7	0.4	1.0	0.8	24		
10	0.7	1.0	1.0	1.0	0.7	0.7	S	0.7	0.4	0.4	0.4	0.4	1.0	0.7	0.7	0.4	0.7	0.7	0.7	0.7	1.0	1.0	1.0	1.3	0.4	1.3	0.8	24	
11	1.0	1.3	1.0	1.0	1.0	S	0.7	1.0	1.0	1.6	1.9	0.7	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	1.9	0.8	24		
12	0.4	0.7	0.7	0.7	S	0.4	0.4	0.7	0.7	0.7	1.0	1.0	0.7	0.7	1.0	1.0	1.0	1.0	1.0	1.0	0.7	0.7	0.4	0.4	1.0	0.8	24		
13	1.0	0.7	0.7	S	0.7	0.7	0.7	1.0	1.0	1.0	1.0	1.0	0.7	1.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.4	0.4	1.0	0.8	24		
14	0.7	0.7	S	0.4	0.7	0.7	0.7	0.7	0.7	0.7	1.0	1.0	0.7	0.7	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.7	0.4	1.0	0.8	24			
15	0.7	S	0.7	0.7	0.7	0.7	0.7	0.7	1.0	1.0	1.0	1.0	1.0	1.0	0.7	1.0	1.0	1.0	1.0	1.0	0.7	0.7	1.0	1.0	0.7	1.0	0.8	24	
16	S	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.7	0.7	1.3	1.0	1.0	1.0	1.0	1.0	1.0	1.3	S	0.7	1.3	1.0	24		
17	1.0	1.0	1.0	1.3	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.7	S	1.0	0.7	1.3	1.0	24		
18	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.7	1.0	1.0	1.0	1.0	1.0	1.3	1.3	1.0	1.0	1.3	1.0	1.0	0.7	S	1.0	1.0	0.7	1.3	24	
19	0.7	1.0	0.7	0.7	0.7	0.7	0.7	1.0	0.7	0.7	1.0	1.0	1.3	1.3	1.0	1.3	1.0	1.0	1.0	1.0	0.7	S	0.7	0.7	0.7	1.0	0.8	24	
20	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.7	1.0	1.0	1.0	1.3	1.3	1.0	1.3	1.0	1.0	1.0	1.0	0.7	S	1.0	0.7	0.7	0.7	1.3	1.0	24
21	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.4	0.7	0.7	0.4	0.4	0.7	0.4	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.7	0.6	24		
22	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.7	0.4	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.4	1.0	0.6	24	
23	0.4	0.7	0.4	0.4	0.4	0.7	1.0	0.7	0.7	0.4	0.7	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	1.0	0.6	24		
24	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	1.3	1.3	1.3	1.6	1.9	S	1.6	1.3	1.3	1.0	0.7	0.7	0.7	0.7	0.7	0.7	1.9	0.9	24	
25	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.4	0.7	0.7	1.0	1.0	1.6	S	1.3	1.3	1.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.4	1.9	1.0	24	
26	2.2	2.2	2.2	1.6	1.3	1.0	0.7	0.7	0.7	0.7	1.0	1.0	S	1.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	2.2	1.1	24	
27	0.7	0.7	0.7	1.0	0.7	1.0	0.7	0.7	0.7	1.0	1.0	S	1.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	1.0	0.8	24		
28	0.7	0.7	0.7	0.7	0.7	1.0	1.0	1.0	1.0	1.0	S	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.7	0.7	1.0	0.9	24			
29	0.7	1.0	0.7	0.7	0.7	0.7	0.7	1.0	1.0	S	0.7	0.7	1.0	1.0	1.0	0.7	0.7	0.7	1.0	1.0	1.0	1.0	1.0	0.7	0.7	1.0	0.8	24	
30	1.0	1.0	1.0	1.0	1.0	0.4	0.4	0.7	0.7	S	0.4	0.4	0.7	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	1.0	0.6	24
31	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	S	0.4	0.7	0.7	1.0	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	1.0	0.5	24
HOURLY MAX	2.2	2.2	2.2	1.6	1.3	1.0	1.0	1.0	1.6	1.9	1.9	1.6	1.6	1.9	1.3	1.6	1.3	1.0	1.6	1.3	1.6	1.6	1.9						
HOURLY AVG	0.7	0.8	0.7	0.8	0.7	0.7	0.7	0.7	0.8	0.8	0.9	0.8	0.8	0.8	0.7	0.7	0.8	0.7	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7		


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	704
MAXIMUM INSTANTANEOUS VALUE:	2.2 ppb @ HOUR(S)
VAR	ON DAY(S) 26
VAR-VARIOUS	
I2S CALIBRATION TIME:	31 hrs
MONTHLY CALIBRATION TIME:	4 hrs
STANDARD DEVIATION:	0.3
OPERATIONAL TIME:	739 hrs

SULPHUR DIOXIDE Instantaneous Maximum (SO<sub>2</sub> ppb)




Wind: THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-SO2[ppb] Monthly: 01/2017 Type: PollutionRose Direction: Blowing From (Wind Frequency) Based On 1 Hr.  
Calm: 5.11% Valid Data: 94.88% Calm Avg: 0.03 [ppb]

Direction	0-3	3-10	10-85	85-170	>170.0	Total
N	13.21	0	0	0	0	13.21
NE	5.82	0	0	0	0	5.82
E	6.11	0	0	0	0	6.11
SE	8.38	0	0	0	0	8.38
S	21.45	0	0	0	0	21.45
SW	28.69	0	0	0	0	28.69
W	5.68	0	0	0	0	5.68
NW	5.54	0	0	0	0	5.54
Summary	94.88	0	0	0	0	94.88

% Icon Classes (ppb)	95	0-3	0	3-10	0	10-85	0	85-170	0	>170.0
----------------------	----	-----	---	------	---	-------	---	--------	---	--------

THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-SO2[ppb] 01/01/2017 00:00 - 31/01/2017 23:00 Calm: 5.11% Calm Poll Avg: 0.03[ppb]



SO<sub>2</sub>[ppb] Calibration: THREE CREEKS #842 TRAILER Monthly: 2017/01 Type: Span




## ***TOTAL REDUCED SULPHUR***

TOTAL REDUCED SULPHUR Hourly Averages (TRS ppb)

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.			
DAY	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59							
1		0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.4	24				
2		0.5	0.5	0.5	0.6	0.5	0.5	0.6	0.5	0.6	0.7	0.7	0.9	0.9	0.6	S	0.6	0.6	0.5	0.5	0.4	0.4	0.4	0.5	0.4	0.4	0.9	0.6	24			
3		0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.5	S	0.6	0.6	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.4	0.6	0.5	24			
4		0.6	0.6	0.6	0.6	0.6	0.7	0.6	0.6	0.7	0.6	C	C	C	Y	Y	C	C	C	0.2	0.2	0.1	0.1	0.0	0.0	0.7	0.5	22				
5		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	P	P	P	X	X	X	X	X	X	X	X	X	X	X	X	0.0	0.0	0.0	9			
6		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	0.0	0.0	0.0				
7		X	X	X	X	X	X	X	X	X	X	X	X	X	X	Y	Y	C1	C1	C1	C1	0.1	0.1	0.0	0.0	0.1	0.1	0.1	3			
8		0.1	0.1	0.1	0.1	0.2	0.3	0.3	0.2	S	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.3	0.1	24				
9		0.1	0.1	0.1	0.2	0.2	0.1	0.1	0.1	S	0.2	0.2	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.1	0.3	0.2	24					
10		0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	S	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.3	0.2	0.4	0.3	24				
11		0.2	0.2	0.2	0.2	0.2	S	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.1	0.3	0.2	24				
12		0.4	0.3	0.3	0.3	S	0.4	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.4	0.3	24					
13		0.2	0.2	0.2	S	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	24				
14		0.1	0.1	S	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	24				
15		0.0	S	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.0	0.0	0.1	0.0	24					
16		S	0.1	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	S	0.0	0.1	0.1	24				
17		0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	S	0.3	0.0	0.3	0.1	24					
18		0.3	0.2	0.2	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	S1	0.4	0.3	0.4	0.3	0.4	0.3	0.3	0.3	S	0.4	0.4	0.2	0.5	0.3	23			
19		0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.3	0.5	0.6	0.2	0.2	0.2	0.2	0.3	S	0.1	0.0	0.0	0.0	0.6	0.3	24			
20		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	C1	C1	C1	0.8	0.6	0.6	0.4	0.4	0.2	0.2	S	0.3	0.2	0.2	0.2	0.0	0.8	0.2	21			
21		0.2	0.2	0.2	0.2	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	S	0.2	0.1	0.2	0.2	0.1	0.2	0.1	24		
22		0.2	0.3	0.2	0.2	0.2	0.3	0.3	0.3	0.4	0.4	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	S	0.4	0.4	0.4	0.4	0.4	0.2	0.4	0.3	24		
23		0.4	0.4	0.4	0.3	0.4	0.4	0.4	0.3	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	S	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.3	24		
24		0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	S	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	24		
25		0.4	0.3	0.3	0.4	0.3	0.4	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	S	0.4	0.4	0.4	0.4	0.4	0.5	0.4	0.4	24		
26		0.5	0.4	0.5	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.4	0.5	0.5	0.5	S	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	24
27		0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.4	24				
28		0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.3	S	0.5	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.4	0.3	0.5	0.4	24		
29		0.5	0.5	0.5	0.6	0.5	0.5	0.6	0.6	0.6	S	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.6	0.5	24				
30		0.3	0.3	0.4	0.3	0.3	0.3	0.3	0.3	S	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.3	24				
31		0.4	0.4	0.4	0.4	0.3	0.3	0.3	S	0.4	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.3	0.5	0.4	24					
HOURLY MAX		0.6	0.6	0.6	0.6	0.6	0.7	0.6	0.7	0.7	0.9	0.9	0.8	0.8	0.6	0.6	0.6	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6					
HOURLY AVG		0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3					


24 HR AVERAGES January 2017



MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	584		
MINIMUM 1-HR AVERAGE	0.0	ppb	@ HOUR(S)
MAXIMUM 1-HR AVERAGE:	0.9	ppb	@ HOUR(S)
MAXIMUM 24-HR AVERAGE:	0.6	ppb	
ON DAY(S)			VAR
11 , 12			2 , 2
ON DAY(S)			
ON DAY(S)			2
VAR-VARIOUS			
I2S CALIBRATION TIME:	28	hrs	OPERATIONAL TIME:
MONTHLY CALIBRATION TIME:	7	hrs	AMD OPERATION UPTIME:
STANDARD DEVIATION:	0.2		678 hrs
			91.1 %
			MONTHLY AVERAGE:
			0.3 ppb

TOTAL REDUCED SULPHUR Hourly Averages (TRS ppb)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE

Three Creeks 842b Station - January 2017

TOTAL REDUCED SULPHUR Instantaneous Maximum (TRS ppb)

	HR START (MST) HR END (MST)	0:00 0:59	1:00 1:59	2:00 2:59	3:00 3:59	4:00 4:59	5:00 5:59	6:00 6:59	7:00 7:59	8:00 8:59	9:00 9:59	10:00 10:59	11:00 11:59	12:00 12:59	13:00 13:59	14:00 14:59	15:00 15:59	16:00 16:59	17:00 17:59	18:00 18:59	19:00 19:59	20:00 20:59	21:00 21:59	22:00 22:59	23:00 23:59	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
DAY																														
1		0.8	0.7	0.8	0.8	0.7	0.8	0.7	0.7	0.6	0.7	0.7	0.6	0.6	0.8	0.8	0.8	0.8	0.7	0.6	0.6	0.7	0.7	0.9	0.7	0.6	0.9	0.7	24	
2		0.8	0.8	0.8	1.0	0.8	0.8	1.0	0.8	1.1	1.0	1.1	1.5	1.3	0.9	S	1.0	0.9	0.9	0.7	0.8	0.7	0.8	0.8	0.8	0.7	1.5	0.9	24	
3		0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.9	0.8	0.9	1.0	0.8	S	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.9	0.8	0.7	1.0	0.8	24	
4		0.8	0.8	0.8	0.9	0.7	0.9	0.7	0.8	0.9	C	C	C	C	Y	Y	C	C	C	C	0.4	0.3	0.2	0.2	0.1	0.1	0.9	0.6	22	
5		0.2	0.1	0.0	0.1	0.0	0.1	0.1	0.2	0.0	P	P	P	X	X	X	X	X	X	X	X	X	X	X	X	X	0.0	0.2	0.1	9
6		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	0.0	0.0	0.0	
7		X	X	X	X	X	X	X	X	X	X	X	X	X	Y	Y	C1	C1	C1	C1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3
8		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
9		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
10		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
11		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
12		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
13		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
14		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
15		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
16		S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S	0.0	24	
17		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
18		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	23	
19		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	S1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24	
20		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	C1	C1	C1	C1	0.7	0.6	0.6	0.6	0.5	S	0.6	0.5	0.6	0.6	0.0	0.7	0.3	20		
21		0.6	0.6	0.7	0.6	0.6	0.6	0.6	0.7	0.6	0.7	0.6	0.5	0.6	0.6	0.6	0.7	0.6	0.7	0.6	0.7	0.8	0.6	0.5	0.8	0.6	0.5	24		
22		0.6	0.7	0.6	0.6	0.6	0.8	0.7	0.6	0.7	0.7	0.8	0.6	0.7	0.7	0.6	0.7	0.6	0.7	0.7	0.7	0.6	0.8	0.6	0.7	0.8	0.7	24		
23		0.7	0.6	0.7	0.7	0.8	0.7	0.8	0.8	0.6	0.7	0.7	0.8	0.7	0.6	0.7	0.6	0.7	0.7	0.6	0.7	0.6	0.7	0.6	0.8	0.7	0.7	24		
24		0.6	0.7	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.6	0.6	0.6	0.6	0.6	0.7	0.6	0.8	0.7	0.8	0.6	0.7	0.8	0.7	24		
25		0.7	0.6	0.6	0.7	0.7	0.6	0.7	0.7	0.7	0.6	0.9	0.7	0.8	0.8	S	0.6	0.7	0.6	0.7	0.7	0.6	0.7	0.8	0.7	0.6	0.9	0.7	24	
26		0.7	0.7	0.7	0.6	0.6	0.7	0.7	0.6	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.7	24	
27		0.5	0.6	0.6	0.6	0.5	0.7	0.5	0.6	0.6	0.5	0.6	0.7	S	0.6	0.6	0.7	0.6	0.6	0.7	0.5	0.6	0.7	0.6	0.5	0.7	0.6	0.5	0.7	24
28		0.7	0.6	0.6	0.6	0.7	0.7	0.7	0.6	0.5	0.6	S	0.9	0.6	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.9	0.6	24	
29		0.5	0.6	0.7	0.6	0.8	0.5	0.6	0.6	0.6	S	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.8	0.6	24		
30		0.6	0.5	0.6	0.6	0.6	0.8	0.8	0.6	0.6	S	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.7	0.5	0.8	0.6	24		
31		0.6	0.7	0.6	0.7	0.7	0.6	0.7	0.6	0.7	S	0.8	0.7	0.9	0.8	0.8	0.7	0.6	0.8	0.7	0.7	0.7	0.7	0.6	0.6	0.9	0.7	24		
HOURLY MAX		0.8	0.8	0.8	1.0	0.8	0.9	1.0	0.8	1.1	1.0	1.1	1.5	1.3	0.9	0.8	1.0	0.9	0.8	0.8	0.8	0.8	0.9	0.8	0.8	0.8	0.8			
HOURLY AVG		0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.3	0.4	0.4	0.4	0.4	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4		


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	351
MAXIMUM INSTANTANEOUS VALUE:	1.5 ppb @ HOUR(S) 11 ON DAY(S) 2
VAR-VARIOUS	
I2S CALIBRATION TIME:	28 hrs
MONTHLY CALIBRATION TIME:	8 hrs
STANDARD DEVIATION:	0.4
OPERATIONAL TIME:	677 hrs

TOTAL REDUCED SULPHUR Instantaneous Maximum (TRS ppb)




Wind: THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-TRS[ppb] Monthly: 01/2017 Type: PollutionRose Direction: Blowing From (Wind Frequency) Based On 1 Hr.  
Calm: 5.46% Valid Data: 86.39% Calm Avg: 0.35 [ppb]

Direction	0-1	1-3	3-10	>10.0	Total
N	10.92	0	0	0	10.92
NE	4.99	0	0	0	4.99
E	3.59	0	0	0	3.59
SE	9.05	0	0	0	9.05
S	22.46	0	0	0	22.46
SW	31.36	0	0	0	31.36
W	6.24	0	0	0	6.24
NW	5.93	0	0	0	5.93
Summary	94.54	0	0	0	94.54

% Icon Classes (ppb)	95	0-1	0	1-3	0	3-10	0	>10.0
----------------------	----	-----	---	-----	---	------	---	-------

THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-TRS[ppb] 01/01/2017 00:00 - 31/01/2017 23:00 Calm: 5.46% Calm Poll Avg: 0.35[ppb]




TRS[ppb] Calibration: THREE CREEKS #842 TRAILER Monthly: 2017/01 Type: Span



## ***TOTAL HYDROCARBON***


## TOTAL HYDROCARBONS Hourly Averages (THC ppm)

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
DAY	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59					
1		1.95	1.94	1.94	1.94	1.95	1.94	1.94	1.95	1.95	1.94	1.94	1.93	1.94	S	1.94	1.94	1.94	1.93	1.93	1.94	1.97	1.96	1.95	1.93	1.97	1.94	24		
2		2.23	2.20	2.18	2.27	2.17	2.21	2.19	2.16	2.15	2.13	2.26	2.26	2.13	1.99	S	2.00	2.00	2.00	1.98	1.98	1.99	1.99	1.97	1.97	1.97	2.27	2.10	24	
3		1.96	1.96	1.96	1.97	1.98	1.99	1.99	1.99	2.01	2.00	2.00	2.00	1.99	S	2.00	2.00	2.00	2.01	2.00	2.03	2.04	2.05	2.05	1.96	2.05	2.00	24		
4		2.04	2.05	2.06	2.06	2.07	2.06	2.06	2.04	2.02	C	C	C	C	C	2.04	2.05	2.05	2.04	2.02	2.03	2.05	2.10	2.00	2.00	2.10	2.05	24		
5		1.97	1.97	1.98	1.99	2.00	1.98	1.96	1.94	1.95	P	P	P	R	R	1.94	1.93	1.94	1.95	1.99	1.98	1.95	1.95	1.93	1.93	1.95	1.93	2.00	1.96	18
6		1.97	1.96	1.95	1.96	1.96	1.96	1.96	1.96	1.96	S	1.96	1.96	1.96	1.96	1.96	1.97	1.98	1.99	1.98	1.96	1.96	1.96	1.94	1.94	1.96	24			
7		1.93	1.93	1.94	1.94	1.94	1.93	1.93	1.94	1.94	S	1.95	1.94	1.94	1.93	1.94	1.93	1.95	1.96	1.95	1.94	1.94	1.93	1.92	1.93	1.96	24			
8		1.93	1.93	2.02	2.23	2.30	2.29	2.24	2.15	S	2.03	1.99	1.94	1.92	1.92	1.92	1.93	1.93	1.94	1.94	1.95	1.95	1.96	1.92	2.30	2.01	24			
9		1.96	1.96	1.96	1.96	1.97	1.97	1.97	S	1.98	1.98	1.98	1.96	1.92	1.91	2.01	1.98	1.94	1.93	1.93	1.92	1.93	1.93	1.91	2.01	1.95	24			
10		1.94	1.93	1.91	1.93	1.94	1.91	S	1.90	1.91	1.91	1.92	1.92	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.90	1.89	1.89	1.94	1.91	24			
11		1.89	1.89	1.89	1.88	1.90	S	1.86	1.85	1.85	1.85	1.85	1.86	1.87	1.88	1.88	1.89	1.89	1.90	1.90	1.92	1.94	2.00	1.85	2.00	1.89	24			
12		2.06	2.00	1.96	1.96	1.96	S	1.91	1.90	1.90	1.91	1.91	1.92	1.92	1.93	1.93	1.93	1.93	1.93	1.92	1.90	1.89	1.88	1.88	2.06	1.93	24			
13		1.87	1.89	1.89	S	1.90	1.89	1.89	1.89	1.89	1.89	1.89	1.88	1.88	1.88	1.88	1.89	1.90	1.90	1.89	1.89	1.89	1.87	1.90	1.89	24				
14		1.89	1.89	S	1.91	1.91	1.90	1.90	1.90	1.90	1.91	1.90	1.90	1.91	1.91	1.91	1.91	1.90	1.90	1.91	1.90	1.91	1.91	1.91	1.90	24				
15		1.89	S	1.90	1.91	1.90	1.91	1.90	1.90	1.92	1.91	1.90	1.90	1.91	1.90	1.90	1.91	1.90	1.90	1.90	1.91	1.91	1.91	1.92	1.90	24				
16		S	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	24				
17		1.91	1.90	1.89	1.89	1.89	1.88	1.87	1.87	1.87	1.88	1.88	1.88	1.88	1.88	1.87	1.87	1.89	1.89	1.89	1.88	1.88	1.88	1.87	1.91	1.88	24			
18		1.90	1.90	1.92	1.94	1.93	1.92	1.91	1.92	1.90	1.90	1.91	1.88	1.88	1.88	1.88	1.90	1.89	1.90	1.90	1.92	1.92	1.88	1.97	1.91	24				
19		1.92	1.90	1.90	1.90	1.90	1.89	1.89	1.89	1.89	1.89	1.89	1.89	1.89	1.89	1.91	1.91	1.88	1.88	1.88	1.92	1.91	1.91	1.88	1.92	1.90	24			
20		1.90	1.91	1.92	1.94	1.92	1.92	1.91	1.91	1.90	1.92	1.92	1.92	1.92	S1	1.95	1.95	1.95	1.95	1.95	S	1.95	1.93	1.92	1.92	1.91	1.95	23		
21		1.92	1.93	1.92	1.93	1.93	1.94	1.93	1.93	1.92	1.92	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.90	1.94	1.92	24		
22		1.92	1.92	1.91	1.91	1.92	1.91	1.92	1.91	1.91	1.93	1.93	1.95	1.96	1.95	1.95	1.95	1.95	1.95	S	1.95	1.95	1.94	1.94	1.95	1.97	1.93	24		
23		1.94	1.93	1.93	1.94	1.94	1.99	1.95	1.95	1.97	1.94	1.94	1.94	1.93	1.93	1.94	S	1.97	1.95	1.98	1.95	1.95	1.96	1.95	1.93	1.95	24			
24		1.96	1.97	1.97	1.96	1.96	1.97	1.98	1.99	1.99	2.01	2.02	2.03	2.03	2.02	S	2.01	2.04	2.06	2.05	2.03	2.03	2.02	1.99	1.96	2.06	2.00	24		
25		1.98	1.98	1.97	1.95	1.96	1.96	1.97	1.97	1.98	1.99	1.99	1.99	1.99	S	1.98	1.99	2.01	2.01	2.00	2.00	2.00	1.99	2.01	1.98	24				
26		1.99	1.97	1.96	1.95	1.95	1.94	1.93	1.92	1.92	1.92	1.93	1.93	1.93	S	1.94	1.95	1.95	1.95	1.93	1.93	1.92	1.92	1.92	1.99	1.94	24			
27		1.92	1.93	1.93	1.93	1.94	1.93	1.94	1.93	1.94	1.92	1.92	1.92	S	1.93	1.93	1.92	1.92	1.92	1.92	1.92	1.93	1.92	1.92	1.92	1.94	1.93	24		
28		1.92	1.93	1.92	1.92	1.91	1.91	1.91	1.92	1.92	1.91	S	1.90	1.90	1.91	1.91	1.91	1.91	1.92	1.90	1.91	1.91	1.91	1.91	1.90	24				
29		1.91	1.91	1.92	1.92	1.91	1.91	1.91	1.90	1.91	S	1.91	1.91	1.91	1.90	1.90	1.90	1.92	1.96	1.94	1.94	1.91	1.91	1.90	1.96	1.91	24			
30		1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	S	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.91	1.90	1.90	1.92	24			
31		1.91	1.91	1.91	1.91	1.92	1.92	1.92	S	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.93	1.93	1.92	1.94	1.95	1.91	24				
HOURLY MAX		2.23	2.20	2.18	2.27	2.30	2.29	2.24	2.16	2.15	2.13	2.26	2.26	2.13	2.03	2.02	2.04	2.05	2.05	2.06	2.05	2.05	2.05	2.10	2.05					
HOURLY AVG		1.95	1.94	1.94	1.96	1.96	1.95	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.93	1.92	1.93	1.94	1.94	1.94	1.94	1.94	1.94	1.95	1.92	24			

**24 HR AVERAGES January 2017**


NUMBER OF NON-ZERO READINGS: 702  
 MINIMUM 1-HR AVERAGE 1.85 ppm @ HOUR(S) VAR ON DAY(S) 11  
 MAXIMUM 1-HR AVERAGE 2.30 ppm @ HOUR(S) 4 ON DAY(S) 8  
 MAXIMUM 24-HR AVERAGE: 2.10 ppm ON DAY(S) 2 VAR-VARIOUS  
 IZS CALIBRATION TIME: 30 hrs OPERATIONAL TIME: 737 hrs  
 MONTHLY CALIBRATION TIME: 5 hrs AMD OPERATION UPTIME: 99.1 %  
 STANDARD DEVIATION: 0.06 MONTHLY AVERAGE: 1.94 ppm

TOTAL HYDROCARBONS Hourly Averages (THC ppm)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE

Three Creeks 842b Station - January 2017

**TOTAL HYDROCARBONS Instantaneous Maximum (THC ppm)**

HR START (MST) HR END (MST)	0:00 0:59	1:00 1:59	2:00 2:59	3:00 3:59	4:00 4:59	5:00 5:59	6:00 6:59	7:00 7:59	8:00 8:59	9:00 9:59	10:00 10:59	11:00 11:59	12:00 12:59	13:00 13:59	14:00 14:59	15:00 15:59	16:00 16:59	17:00 17:59	18:00 18:59	19:00 19:59	20:00 20:59	21:00 21:59	22:00 22:59	23:00 23:59	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
DAY																													
1	1.99	1.98	1.96	2.00	1.96	1.97	1.96	1.96	1.96	1.95	1.98	1.97	1.98	1.95	1.99	S	2.00	1.95	1.97	1.95	2.02	2.02	2.01	1.97	1.95	2.02	1.98	24	
2	2.44	2.45	2.41	2.48	2.20	2.29	2.24	2.21	2.20	2.23	2.42	2.42	2.29	2.03	S	2.01	2.03	2.01	1.99	2.01	2.07	2.03	2.00	2.16	1.99	2.48	2.20	24	
3	2.00	1.99	1.98	2.00	2.01	2.06	2.04	2.04	2.03	2.04	2.02	2.01	2.02	S	2.01	2.03	2.02	2.09	2.04	2.12	2.06	2.10	2.09	2.12	1.98	2.12	2.04	24	
4	2.08	2.08	2.08	2.12	2.09	2.12	2.11	2.09	2.09	C	C	C	C	C	C	C	2.07	2.12	2.07	2.19	2.10	2.04	2.12	2.24	2.09	2.04	2.24	2.11	24
5	2.00	2.01	2.10	2.05	2.03	2.00	1.98	1.97	1.98	P	P	P	P	R	R	R	1.98	1.99	1.95	1.96	2.05	2.03	1.96	1.96	1.98	1.95	2.10	2.00	18
6	2.04	1.99	1.99	2.08	1.97	2.02	1.97	1.97	1.97	1.98	S	1.99	1.98	1.98	1.99	2.01	2.00	2.07	2.02	1.98	1.98	1.98	1.97	1.96	1.96	2.08	2.00	24	
7	1.97	1.96	1.95	1.96	1.95	1.94	1.96	2.01	1.98	S	1.97	1.95	1.98	1.96	1.98	1.95	1.97	2.06	2.22	1.98	2.01	1.96	1.93	1.96	1.93	2.22	1.98	24	
8	2.07	1.96	2.21	2.37	2.42	2.36	2.35	2.25	S	2.10	2.05	1.97	1.96	1.97	1.95	1.93	1.92	1.97	1.97	1.96	1.99	2.01	1.97	1.97	1.92	2.42	2.07	24	
9	2.00	1.99	2.00	2.05	2.03	2.00	2.00	2.00	S	2.01	2.06	2.00	2.04	2.02	1.96	1.92	2.12	2.00	1.98	2.03	1.97	1.97	1.98	1.94	2.00	1.92	2.12	2.00	24
10	1.99	1.93	1.99	1.94	2.01	1.92	S	1.96	1.92	1.92	1.98	1.95	1.92	1.99	1.93	2.09	1.93	1.99	1.92	1.95	2.06	1.92	1.99	1.92	2.09	1.96	24		
11	1.92	1.98	1.93	1.91	2.01	S	1.91	1.89	1.86	1.89	1.87	1.89	1.89	1.91	1.91	1.91	1.96	1.97	1.98	1.93	1.97	1.98	2.09	1.86	2.09	1.94	24		
12	2.15	2.07	2.00	1.98	S	1.93	1.95	1.93	2.00	1.93	1.95	2.06	1.95	2.06	1.97	2.01	1.98	1.99	1.98	1.99	1.97	1.94	1.91	1.96	1.91	2.15	1.99	24	
13	1.91	1.94	1.92	S	2.11	1.95	1.91	1.92	1.95	1.92	2.02	1.91	1.91	1.91	1.90	1.91	1.91	1.91	1.90	1.92	1.98	1.97	1.90	1.90	2.11	1.94	24		
14	1.93	1.91	S	1.96	1.91	1.91	1.91	1.91	1.93	1.93	1.92	2.00	1.92	1.91	1.92	1.93	1.92	1.90	1.91	1.94	1.97	1.91	2.00	1.93	2.00	1.93	24		
15	1.91	S	1.94	1.97	1.91	1.91	1.96	1.95	1.90	1.95	1.94	1.90	1.93	1.91	1.95	1.93	1.96	1.92	1.92	1.91	1.94	1.91	1.98	1.93	2.07	1.94	24		
16	S	2.02	1.91	1.91	1.91	1.95	1.99	1.91	2.07	1.91	1.96	1.91	1.90	1.90	1.90	1.99	2.06	1.89	1.90	1.90	2.06	1.90	S	1.89	2.07	1.94	24		
17	1.91	1.93	1.97	2.00	1.98	1.88	1.89	1.88	1.88	1.99	1.89	1.88	1.88	1.99	1.99	1.96	1.91	1.90	2.00	2.00	1.97	S	1.92	1.88	2.00	1.93	24		
18	1.99	1.97	1.97	2.01	1.98	1.93	1.92	1.94	1.97	1.91	1.95	2.08	1.89	1.89	1.92	2.03	1.90	2.03	2.13	1.92	S	1.92	1.99	1.89	2.13	1.96	24		
19	1.93	1.92	1.92	1.91	1.92	1.92	1.91	1.91	1.91	1.90	1.92	1.98	1.91	1.91	1.93	1.91	1.91	1.91	1.92	1.93	S	1.95	1.93	1.95	1.90	1.98	1.92	24	
20	1.92	1.93	1.97	1.95	1.93	1.93	1.95	1.93	1.92	1.96	1.99	1.96	1.99	2.01	S1	2.08	2.15	2.11	2.02	S	1.97	1.95	2.00	2.02	1.92	2.15	1.98	23	
21	1.93	1.94	1.99	2.03	1.95	1.95	1.93	1.96	1.92	1.93	1.91	1.92	1.91	1.92	1.91	1.91	1.92	1.98	S	1.97	1.92	1.92	1.92	2.07	1.95	24			
22	1.92	1.97	2.01	1.95	1.96	1.96	1.92	1.95	1.96	1.93	1.97	2.17	1.97	1.96	1.97	1.99	1.97	S	1.97	1.98	1.98	1.98	1.97	2.12	1.92	2.17	1.98	24	
23	1.97	1.96	1.97	1.99	2.00	2.06	1.98	1.99	2.10	1.98	1.97	2.06	2.11	2.02	1.97	1.96	S	2.07	1.99	2.03	2.00	1.98	2.02	1.98	1.96	2.11	2.01	24	
24	1.99	2.15	1.99	1.98	1.98	1.99	2.01	2.08	2.10	2.19	2.13	2.10	2.03	S	2.06	2.13	2.24	2.17	2.15	2.21	2.20	2.01	1.98	2.24	2.08	24			
25	2.13	2.10	1.98	1.97	1.97	2.11	1.98	2.02	1.99	2.00	2.09	2.00	2.02	2.07	S	2.04	2.00	2.03	2.12	2.01	2.09	2.07	2.01	2.02	1.97	2.13	2.04	24	
26	2.03	1.99	2.05	2.04	1.98	1.97	2.01	1.93	1.94	1.95	1.92	2.01	1.95	S	1.95	1.96	1.97	2.10	2.00	1.95	1.97	1.92	2.02	1.95	2.10	1.98	24		
27	1.93	1.95	1.93	2.06	1.95	1.97	1.98	2.01	2.08	2.10	1.93	1.94	S	2.00	1.95	2.03	1.92	1.95	1.93	1.96	1.94	1.93	1.96	1.92	2.10	1.97	24		
28	1.93	1.94	1.92	1.98	1.95	1.93	2.03	1.92	1.97	2.00	1.92	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	2.03	1.95	24			
29	1.92	1.92	1.99	1.94	1.95	1.97	1.92	1.96	1.91	1.91	S	1.92	2.01	1.91	1.92	1.91	1.91	1.96	1.99	2.06	1.98	2.07	1.91	2.07	1.96	24			
30	1.95	1.92	1.92	2.00	1.92	1.92	1.93	1.93	1.93	S	2.03	1.93	1.97	1.96	1.93	1.99	1.93	1.92	1.92	1.93	1.92	1.92	1.93	1.92	2.03	1.94	24		
31	2.03	1.93	1.93	1.95	1.92	2.01	1.95	1.96	S	1.93	1.93	1.94	1.97	1.93	1.95	1.99	1.98	1.99	1.96	1.96	1.96	1.99	1.97	1.92	2.03	1.96	24		
HOURLY MAX	2.44	2.45	2.41	2.48	2.42	2.36	2.35	2.25	2.20	2.23	2.42	2.42	2.29	2.10	2.03	2.12	2.15	2.13	2.24	2.17	2.15	2.21	2.24	2.16					
HOURLY AVG	2.00	1.99	2.00	2.02	2.00	1.99	1.99	1.98	1.97	2.00	1.97	1.96	1.95	1.99	1.98	1.98	1.97	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99		


**STATUS FLAG CODES**

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

**MONTHLY SUMMARY**

NUMBER OF NON-ZERO READINGS:	701
MAXIMUM INSTANTANEOUS VALUE:	2.48 ppm @ HOUR(S) 3 ON DAY(S) 2
VAR-VARIOUS	
I2S CALIBRATION TIME:	30 hrs
MONTHLY CALIBRATION TIME:	6 hrs
STANDARD DEVIATION:	0.09
OPERATIONAL TIME:	737 hrs

TOTAL HYDROCARBONS Instantaneous Maximum (THC ppm)




Wind: THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-THC[ppm] Monthly: 01/2017 Type: PollutionRose Direction: Blowing From (Wind Frequency) Based On 1 Hr.  
Calm: 5.14% Valid Data: 94.47% Calm Avg: 2.00 [ppm]

Direction	0-2	2-3	3-5	5-10	>10.0	Total
N	13.27	0	0	0	0	13.27
NE	4.85	0.86	0	0	0	5.71
E	5.42	0.71	0	0	0	6.13
SE	6.7	1.71	0	0	0	8.41
S	18.4	3	0	0	0	21.4
SW	26.96	1.71	0	0	0	28.67
W	5.71	0	0	0	0	5.71
NW	5.56	0	0	0	0	5.56
Summary	86.87	7.99	0	0	0	94.86

%	Icon	Classes (ppm)	87	<span style="background-color: orange; border-radius: 50%; width: 10px; height: 10px;"></span>	0-2	8	<span style="background-color: red; border-radius: 50%; width: 10px; height: 10px;"></span>	2-3	0	<span style="background-color: darkblue; border-radius: 50%; width: 10px; height: 10px;"></span>	3-5	0	<span style="background-color: purple; border-radius: 50%; width: 10px; height: 10px;"></span>	5-10	0	<span style="background-color: magenta; border-radius: 50%; width: 10px; height: 10px;"></span>	>10.0
---	------	---------------	----	--	-----	---	---	-----	---	--	-----	---	--	------	---	---	-------

THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-THC[ppm] 01/01/2017 00:00 - 31/01/2017 23:00 Calm: 5.14% Calm Poll Avg: 2.00[ppm]



THC[ppm] Calibration: THREE CREEKS #842 TRAILER Monthly: 2017/01 Type: Span




***METHANE***

METHANE Hourly Averages (CH<sub>4</sub> ppm)

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
DAY	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59					
1	1.95	1.94	1.94	1.94	1.95	1.94	1.94	1.94	1.94	1.94	1.93	1.93	1.93	1.93	S	1.94	1.94	1.93	1.93	1.93	1.93	1.93	1.93	1.93	1.93	1.93	1.93	1.93	1.93	24
2	2.23	2.19	2.18	2.26	2.17	2.21	2.18	2.16	2.15	2.13	2.22	2.26	2.13	1.99	S	2.00	2.00	2.00	1.98	1.98	1.99	1.99	1.97	1.97	1.97	1.97	2.26	2.10	24	
3	1.96	1.96	1.96	1.97	1.98	1.99	1.99	1.99	2.00	2.00	2.00	2.00	1.99	S	2.00	2.00	2.00	2.00	2.00	2.03	2.04	2.05	2.05	2.05	1.96	2.05	2.00	2.00	24	
4	2.04	2.05	2.06	2.06	2.07	2.06	2.06	2.04	2.02	C	C	C	C	C	2.04	2.05	2.05	2.03	2.02	2.03	2.05	2.05	2.05	2.05	2.05	1.99	2.10	2.05	24	
5	1.97	1.97	1.98	1.99	2.00	1.98	1.96	1.94	1.95	P	P	P	R	R	1.94	1.93	1.94	1.95	1.99	1.98	1.95	1.95	1.95	1.93	1.93	1.93	1.93	1.93	18	
6	1.97	1.96	1.95	1.95	1.96	1.96	1.96	1.96	1.96	S	1.96	1.95	1.96	1.96	1.96	1.97	1.98	1.99	1.98	1.96	1.96	1.95	1.94	1.94	1.99	1.96	24			
7	1.93	1.93	1.94	1.94	1.94	1.93	1.93	1.94	1.94	S	1.95	1.94	1.94	1.93	1.93	1.93	1.95	1.96	1.95	1.94	1.94	1.93	1.92	1.92	1.96	1.94	24			
8	1.93	1.93	2.02	2.23	2.30	2.29	2.24	2.14	S	2.03	1.99	1.94	1.92	1.92	1.92	1.93	1.93	1.94	1.94	1.95	1.95	1.95	1.96	1.92	2.30	2.01	24			
9	1.96	1.96	1.96	1.96	1.97	1.97	1.97	1.97	S	1.98	1.98	1.98	1.96	1.92	1.91	2.01	1.98	1.94	1.93	1.93	1.92	1.93	1.93	1.91	2.01	1.95	24			
10	1.94	1.93	1.91	1.93	1.94	1.91	S	1.90	1.91	1.91	1.92	1.92	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.90	1.89	1.89	1.94	1.91	24			
11	1.89	1.89	1.89	1.88	1.90	S	1.86	1.85	1.85	1.85	1.85	1.86	1.86	1.87	1.88	1.88	1.89	1.89	1.90	1.92	1.94	2.00	1.85	2.00	1.89	24				
12	2.06	2.00	1.96	1.96	1.96	S	1.91	1.90	1.90	1.91	1.91	1.92	1.92	1.93	1.93	1.93	1.93	1.93	1.92	1.90	1.89	1.88	1.88	2.06	1.93	24				
13	1.87	1.89	1.89	S	1.90	1.89	1.89	1.89	1.89	1.89	1.88	1.88	1.88	1.88	1.88	1.88	1.88	1.89	1.89	1.89	1.89	1.89	1.87	1.90	1.89	24				
14	1.89	1.89	S	1.90	1.91	1.90	1.90	1.90	1.90	1.91	1.90	1.90	1.91	1.91	1.91	1.91	1.91	1.90	1.90	1.91	1.91	1.91	1.91	1.91	1.90	1.90	24			
15	1.89	S	1.90	1.91	1.90	1.91	1.90	1.90	1.90	1.92	1.91	1.90	1.90	1.91	1.90	1.91	1.90	1.90	1.90	1.90	1.91	1.91	1.91	1.91	1.92	1.90	24			
16	S	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	24			
17	1.91	1.89	1.89	1.89	1.89	1.88	1.87	1.87	1.87	1.88	1.88	1.88	1.87	1.87	1.87	1.87	1.89	1.89	1.89	1.88	1.88	S	1.90	1.87	1.91	1.88	24			
18	1.90	1.90	1.92	1.94	1.93	1.92	1.91	1.92	1.92	1.90	1.90	1.88	1.88	1.88	1.88	1.89	1.90	1.90	1.97	1.90	S	1.89	1.92	1.88	1.97	1.91	24			
19	1.92	1.90	1.90	1.90	1.90	1.89	1.89	1.89	1.89	1.89	1.89	1.88	1.88	1.88	1.89	1.91	1.91	1.88	1.88	1.91	S	1.92	1.91	1.91	1.88	1.92	24			
20	1.90	1.91	1.92	1.94	1.92	1.92	1.91	1.91	1.90	1.92	1.92	1.92	1.92	1.92	S1	1.95	1.95	1.95	1.95	1.95	S	1.95	1.93	1.92	1.91	1.91	23			
21	1.92	1.93	1.92	1.93	1.93	1.94	1.93	1.93	1.92	1.92	1.91	1.91	1.91	1.91	1.91	1.91	1.91	1.90	1.90	1.90	S	1.92	1.91	1.91	1.91	1.90	24			
22	1.92	1.92	1.91	1.91	1.92	1.92	1.91	1.91	1.91	1.93	1.95	1.96	1.95	1.95	1.95	1.95	1.95	1.95	1.95	1.95	S	1.95	1.94	1.94	1.95	1.97	24			
23	1.94	1.93	1.93	1.94	1.94	1.99	1.95	1.95	1.97	1.94	1.94	1.93	1.94	1.94	1.94	S	1.97	1.95	1.98	1.95	1.95	1.95	1.95	1.95	1.95	24				
24	1.96	1.96	1.97	1.96	1.96	1.97	1.98	1.99	1.99	2.00	2.02	2.03	2.03	2.03	2.02	S	2.00	2.04	2.06	2.04	2.04	2.03	2.02	2.00	1.99	1.96	2.06	2.00	24	
25	1.98	1.98	1.97	1.95	1.96	1.96	1.97	1.97	1.98	1.98	1.99	1.99	1.99	1.98	S	1.98	1.99	2.01	2.01	2.00	2.00	1.99	2.00	2.00	2.01	1.98	24			
26	1.98	1.97	1.96	1.95	1.95	1.94	1.93	1.92	1.92	1.92	1.93	1.93	1.93	S	1.94	1.95	1.95	1.95	1.93	1.93	1.93	1.92	1.92	1.92	1.92	1.98	24			
27	1.92	1.93	1.93	1.93	1.94	1.93	1.94	1.93	1.94	1.92	1.92	1.92	S	1.93	1.93	1.92	1.92	1.92	1.92	1.92	1.93	1.92	1.92	1.92	1.92	1.94	24			
28	1.92	1.93	1.92	1.92	1.91	1.91	1.91	1.92	1.92	1.91	S	1.90	1.90	1.91	1.91	1.91	1.91	1.92	1.90	1.91	1.91	1.91	1.91	1.91	1.91	24				
29	1.91	1.91	1.91	1.92	1.91	1.90	1.91	1.90	1.90	1.90	S	1.90	1.91	1.91	1.90	1.90	1.90	1.92	1.96	1.94	1.94	1.91	1.91	1.90	1.96	1.91	24			
30	1.91	1.91	1.92	1.91	1.92	1.92	1.92	1.92	1.92	S	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.91	1.90	1.90	1.92	24			
31	1.91	1.91	1.91	1.91	1.92	1.92	1.92	S	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.94	1.95	1.91	1.92	24				
HOURLY MAX		2.23	2.19	2.18	2.26	2.30	2.29	2.24	2.16	2.15	2.13	2.22	2.26	2.13	2.03	2.02	2.04	2.05	2.05	2.06	2.04	2.04	2.05	2.10	2.05					
HOURLY AVG		1.95	1.94	1.94	1.96	1.96	1.95	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.93	1.92	1.92	1.93	1.94	1.94	1.94	1.94	1.94	1.94	1.95	1.92				

## 24 HR AVERAGES January 2017



## NUMBER OF NON-ZERO READINGS: 702

MINIMUM 1-HR AVERAGE 1.85 ppm @ HOUR(S)

MAXIMUM 1-HR AVERAGE 2.30 ppm @ HOUR(S)

MAXIMUM 24-HR AVERAGE 2.10 ppm

ON DAY(S) 11

VAR 4

ON DAY(S) 8

VAR 2

VAR-VARIOUS

## IZS CALIBRATION TIME: 30 hrs

OPERATIONAL TIME: 737 hrs


MONTHLY CALIBRATION TIME: 5 hrs

AMD OPERATION UPTIME: 99.1 %

STANDARD DEVIATION: 0.06

MONTHLY AVERAGE: 1.94 ppm

METHANE Hourly Averages (CH<sub>4</sub> ppm)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE

Three Creeks 842b Station - January 2017

METHANE MAX Instantaneous Maximum (CH<sub>4</sub> ppm)

HR START (MST) HR END (MST)	0:00 0:59	1:00 1:59	2:00 2:59	3:00 3:59	4:00 4:59	5:00 5:59	6:00 6:59	7:00 7:59	8:00 8:59	9:00 9:59	10:00 10:59	11:00 11:59	12:00 12:59	13:00 13:59	14:00 14:59	15:00 15:59	16:00 16:59	17:00 17:59	18:00 18:59	19:00 19:59	20:00 20:59	21:00 21:59	22:00 22:59	23:00 23:59	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.			
DAY																															
1	1.97	1.95	1.96	1.95	1.96	1.97	1.95	1.96	1.95	1.98	1.97	1.98	1.95	1.95	1.95	1.95	1.96	1.95	1.97	1.95	2.02	2.02	2.02	1.97	1.95	2.02	1.97	24			
2	<b>2.44</b>	2.35	2.41	2.38	2.20	2.28	2.24	2.21	2.20	2.18	2.30	2.31	2.29	2.03	<b>S</b>	2.01	2.03	2.01	2.01	2.01	2.06	2.03	2.00	2.16	2.00	<b>2.44</b>	2.18	24			
3	2.00	1.99	1.98	2.00	2.01	2.05	2.03	2.03	2.02	2.02	2.01	2.02	<b>C</b>	<b>C</b>	<b>C</b>	<b>C</b>	<b>C</b>	<b>C</b>	2.06	2.07	2.06	2.06	2.04	2.05	2.09	2.08	1.98	2.09	2.03	24	
4	2.06	2.07	2.07	2.11	2.08	2.09	2.10	2.08	2.07	<b>C</b>	<b>C</b>	<b>C</b>	<b>C</b>	<b>C</b>	<b>C</b>	<b>R</b>	<b>R</b>	1.97	1.95	1.95	1.96	2.04	2.03	1.96	1.96	1.97	1.95	2.09	1.99	18	
5	2.01	1.98	2.09	2.04	2.03	2.00	1.98	1.95	1.96	<b>P</b>	<b>P</b>	<b>P</b>	<b>P</b>	<b>R</b>	<b>R</b>														2.15	2.08	24
6	1.99	2.00	1.97	1.97	1.98	1.97	1.97	1.97	1.98	<b>S</b>	1.98	1.98	1.97	1.99	1.99	2.00	2.06	2.02	1.98	1.99	1.98	1.97	1.96	1.96	1.96	1.96	2.06	1.98	24		
7	1.95	1.96	1.95	1.95	1.95	1.95	1.96	1.96	<b>S</b>	1.97	1.95	1.98	1.94	1.95	1.95	1.95	1.97	1.96	1.97	1.98	2.01	1.95	1.94	1.96	1.94	2.06	1.96	24			
8	1.94	1.96	2.22	2.37	2.42	2.36	2.35	2.26	<b>S</b>	2.10	2.04	1.97	1.96	1.93	1.95	1.94	1.95	1.94	1.96	1.96	1.96	1.95	1.98	1.97	1.93	2.42	2.06	24			
9	2.00	2.00	2.00	2.05	2.04	2.00	2.00	<b>S</b>	2.01	1.99	2.01	2.04	2.02	1.94	1.93	2.12	2.01	1.98	2.03	1.97	1.98	1.94	1.95	1.95	1.93	2.12	2.00	24			
10	1.96	1.94	1.93	1.95	2.02	1.93	<b>S</b>	1.92	1.92	1.93	1.98	1.94	1.93	1.93	1.94	2.08	1.94	1.93	2.00	1.93	1.93	2.06	1.92	1.99	1.92	2.08	1.96	24			
11	1.93	1.91	1.94	1.92	1.98	<b>S</b>	1.91	1.89	1.86	1.89	1.88	1.89	1.88	1.92	1.91	1.91	1.92	1.97	1.92	1.94	1.97	1.98	2.09	1.86	2.09	1.93	24				
12	2.14	2.06	2.00	1.97	<b>S</b>	1.94	1.94	2.00	1.94	1.95	1.94	1.96	2.05	1.97	2.01	1.97	1.96	1.99	1.97	1.96	1.94	1.92	2.14	1.98	24						
13	1.92	1.94	1.93	<b>S</b>	2.11	1.94	1.92	1.93	1.93	1.92	2.02	1.91	1.92	1.92	1.91	1.95	1.92	1.92	1.91	1.92	1.90	1.91	1.90	2.11	1.94	24					
14	1.91	1.91	<b>S</b>	1.92	1.92	1.92	1.92	1.92	1.92	1.91	1.93	1.93	1.94	1.93	1.92	1.93	1.94	1.93	1.91	1.92	1.91	1.93	1.91	1.95	1.92	24					
15	1.91	<b>S</b>	1.93	1.96	1.92	1.92	1.96	1.95	1.91	1.95	1.94	1.92	1.94	1.92	1.95	1.94	1.96	1.92	1.91	1.93	1.92	1.91	1.96	1.93	24						
16	<b>S</b>	1.91	1.92	1.91	1.92	1.92	1.91	1.91	1.92	1.91	1.92	1.91	1.91	1.91	1.91	1.99	1.90	1.90	1.90	1.91	1.91	<b>S</b>	1.90	1.99	1.92	24					
17	1.92	1.94	1.91	1.90	1.92	1.89	1.90	1.88	1.88	1.89	1.90	1.89	1.89	1.89	1.89	1.89	1.91	1.90	1.91	1.91	1.95	1.91	1.97	<b>S</b>	1.93	1.88	1.97	1.91			
18	1.92	1.94	1.97	2.01	1.97	1.94	1.93	1.95	1.94	1.92	1.95	1.95	1.95	1.98	1.90	1.90	1.93	1.92	1.90	2.03	2.13	1.93	<b>S</b>	1.91	1.95	1.89	24				
19	1.94	1.92	1.91	1.91	1.91	1.92	1.92	1.90	1.91	1.92	1.91	1.91	1.91	1.93	1.91	1.92	1.92	1.93	1.95	1.93	1.94	1.90	1.95	1.92	24						
20	1.93	1.93	1.96	1.94	1.94	1.95	1.93	1.91	1.92	1.99	1.93	1.94	1.95	1.96	<b>S1</b>	1.96	1.96	1.97	1.96	<b>S</b>	1.97	1.94	1.93	1.94	1.91	1.99	1.95	23			
21	1.94	1.95	1.93	2.04	1.95	1.95	1.95	1.94	1.94	1.93	1.93	1.92	1.93	1.92	1.92	2.01	1.93	1.98	<b>S</b>	1.96	1.92	1.93	1.93	1.94	1.92	2.04	1.95	24			
22	1.93	1.97	1.96	1.96	1.95	1.95	1.93	1.95	1.93	1.94	1.96	1.96	2.17	1.97	1.96	1.96	1.99	1.97	<b>S</b>	1.97	1.96	1.98	1.98	1.97	2.00	1.93	2.17	1.97	24		
23	1.97	1.95	1.97	2.01	2.03	1.97	1.99	2.00	1.98	1.97	1.97	1.97	1.95	1.96	1.96	1.96	2.01	1.99	2.03	1.99	1.98	1.99	1.98	1.95	2.03	1.98	24				
24	1.99	2.00	2.00	1.98	1.99	2.00	2.00	2.01	2.01	2.03	2.04	2.05	2.05	2.04	2.03	2.03	<b>S</b>	2.03	2.07	2.24	2.06	2.05	2.05	2.02	2.01	1.98	2.24	2.03	24		
25	1.99	1.99	1.98	1.97	1.96	1.97	1.98	1.99	1.99	2.00	2.00	2.00	2.03	2.00	<b>S</b>	2.00	2.01	2.02	2.02	2.01	2.01	2.02	2.02	1.96	2.03	2.00	24				
26	2.03	1.99	2.04	1.96	1.98	1.96	2.01	1.94	1.94	1.93	1.93	2.01	1.95	<b>S</b>	1.95	1.96	1.96	1.96	1.96	1.96	1.98	1.95	1.97	1.93	2.04	1.96	24				
27	1.94	1.95	1.94	1.95	1.95	1.97	1.98	1.96	1.94	2.09	1.94	1.95	1.95	1.95	1.95	1.95	1.96	1.95	1.96	1.95	1.94	1.94	1.95	1.93	2.09	1.95	24				
28	1.94	1.94	1.93	1.95	1.95	1.93	1.93	1.92	1.94	1.98	1.93	<b>S</b>	1.92	1.91	2.00	1.94	1.92	1.95	1.92	1.93	1.92	1.92	1.91	2.00	1.94	24					
29	1.92	1.93	1.96	1.94	1.92	1.93	1.92	1.92	1.92	<b>S</b>	1.92	1.93	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.96	2.00	2.05	1.98	1.92	2.05	1.94	24			
30	1.96	1.93	1.93	1.94	1.93	1.93	1.93	1.93	1.93	<b>S</b>	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.93	1.93	1.94	1.94	1.92	1.99	1.94	24			
31	1.92	1.93	1.92	1.95	1.93	1.93	1.95	1.93	1.93	<b>S</b>	1.94	1.94	1.94	1.94	1.94	1.94	1.94	1.95	1.94	1.95	1.94	1.95	1.96	1.97	1.94	1.94	24				
HOURLY MAX	2.44	2.35	2.41	2.38	2.42	2.36	2.35	2.26	2.20	2.18	2.30	2.31	2.29	2.05	2.03	2.12	2.07	2.07	2.24	2.13	2.06	2.11	2.15	2.16							
HOURLY AVG	1.98	1.97	1.99	1.99	1.99	1.98	1.98	1.97	1.96	1.97	1.97	1.96	1.95	1.95	1.97	1.96	1.97	1.98	1.98	1.97	1.96	1.98	1.97	1.96	1.98	1.97	1.94	24			


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	701
MAXIMUM INSTANTANEOUS VALUE:	2.44 ppm @ HOUR(S) 0 ON DAY(S) 2
VAR-VARIOUS	
I2S CALIBRATION TIME: 30 hrs	
MONTHLY CALIBRATION TIME:	6 hrs
STANDARD DEVIATION:	0.07
OPERATIONAL TIME: 737 hrs	

METHANE MAX Instantaneous Maximum (CH<sub>4</sub> ppm)




Wind: THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-CH4[ppm] Monthly: 01/2017 Type: PollutionRose Direction: Blowing From (Wind Frequency) Based On 1 Hr.  
Calm: 5.14% Valid Data: 94.47% Calm Avg: 2.00 [ppm]

Direction	0-2	2-3	3-5	5-10	>10.0	Total
N	13.27	0	0	0	0	13.27
NE	4.85	0.86	0	0	0	5.71
E	5.42	0.71	0	0	0	6.13
SE	6.7	1.71	0	0	0	8.41
S	18.4	3	0	0	0	21.4
SW	26.96	1.71	0	0	0	28.67
W	5.71	0	0	0	0	5.71
NW	5.56	0	0	0	0	5.56
Summary	86.87	7.99	0	0	0	94.86

%	Icon	Classes (ppm)	87	<span style="background-color: orange; border: 1px solid black; padding: 2px 5px;"></span>	0-2	8	<span style="background-color: red; border: 1px solid black; padding: 2px 5px;"></span>	2-3	0	<span style="background-color: darkblue; border: 1px solid black; padding: 2px 5px;"></span>	3-5	0	<span style="background-color: purple; border: 1px solid black; padding: 2px 5px;"></span>	5-10	0	<span style="background-color: magenta; border: 1px solid black; padding: 2px 5px;"></span>	>10.0
---	------	---------------	----	--	-----	---	---	-----	---	--	-----	---	--	------	---	---	-------

THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-CH4[ppm] 01/01/2017 00:00 - 31/01/2017 23:00 Calm: 5.14% Calm Poll Avg: 2.00[ppm]



CH4[ppm] Calibration: THREE CREEKS #842 TRAILER Monthly: 2017/01 Type: Span




## ***NON-METHANE HYDROCARBON***

## NON-METHANE HYDROCARBONS Hourly Averages (NMHC ppm)

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.		
	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59						
DAY																															
1		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24		
2		0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.01	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.00	24		
3		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24	
4		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	C	C	C	C	C	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	24		
5		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	P	P	P	R	R	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	18	
6		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
7		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	24			
8		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
9		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
10		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
11		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
12		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
13		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
14		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
15		0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
16		S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
17		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
18		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
19		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
20		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23		
21		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
22		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
23		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24	
24		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.01	0.00	24			
25		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24	
26		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24	
27		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24		
28		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
29		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
30		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
31		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24			
HOURLY MAX		0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.01	0.00	0.00	0.00	0.00					
HOURLY AVG		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					


## 24 HR AVERAGES January 2017



## MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	6			
MINIMUM 1-HR AVERAGE	0.00	ppm	@ HOUR(S)	VAR
MAXIMUM 1-HR AVERAGE:	0.04	ppm	@ HOUR(S)	10
MAXIMUM 24-HR AVERAGE:	0.00	ppm	ON DAY(S)	ALL
			ON DAY(S)	2
			ON DAY(S)	VAR-VARIOUS
I2S CALIBRATION TIME:	30	hrs	OPERATIONAL TIME:	
MONTHLY CALIBRATION TIME:	5	hrs	AMD OPERATION UPTIME:	99.1 %
STANDARD DEVIATION:	0.00		MONTHLY AVERAGE:	0.00 ppm

NON-METHANE HYDROCARBONS Hourly Averages (NMHC ppm)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE

Three Creeks 842b Station - January 2017

NON-METHANE HYDROCARBONS Instantaneous Maximum (NMHC ppm)

	HR START (MST) HR END (MST)	0:00 0:59	1:00 1:59	2:00 2:59	3:00 3:59	4:00 4:59	5:00 5:59	6:00 6:59	7:00 7:59	8:00 8:59	9:00 9:59	10:00 10:59	11:00 11:59	12:00 12:59	13:00 13:59	14:00 14:59	15:00 15:59	16:00 16:59	17:00 17:59	18:00 18:59	19:00 19:59	20:00 20:59	21:00 21:59	22:00 22:59	23:00 23:59	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.
DAY																													
1	0.05	0.04	0.00	0.06	0.00	0.03	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.01	0.06	S	0.04	0.00	0.01	0.00	0.00	0.00	0.00	0.02	0.00	0.06	0.01	24	
2	0.02	0.12	0.00	0.16	0.00	0.05	0.06	0.04	0.00	0.07	0.21	0.18	0.08	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.21	0.04	24		
3	0.00	0.00	0.00	0.01	0.00	0.01	0.00	0.02	0.03	0.01	0.01	0.01	S	0.00	0.00	0.00	0.00	0.00	0.09	0.01	0.09	0.00	0.03	0.00	0.06	0.00	0.09	0.02	24
4	0.05	0.02	0.02	0.01	0.00	0.05	0.03	0.00	0.04	C	C	C	C	C	C	C	0.00	0.06	0.00	0.15	0.07	0.01	0.00	0.14	0.06	0.00	0.15	0.04	24
5	0.02	0.04	0.00	0.00	0.00	0.00	0.03	0.04	P	P	P	P	R	R	R	R	0.00	0.05	0.00	0.01	0.00	0.03	0.00	0.00	0.03	0.00	0.05	0.01	18
6	0.06	0.01	0.05	0.13	0.00	0.07	0.01	0.00	0.01	0.00	S	0.01	0.00	0.00	0.01	0.04	0.02	0.00	0.02	0.00	0.00	0.01	0.03	0.00	0.13	0.02	24		
7	0.03	0.00	0.00	0.00	0.00	0.01	0.09	0.03	S	0.01	0.00	0.00	0.04	0.05	0.01	0.00	0.01	0.25	0.05	0.05	0.05	0.00	0.00	0.00	0.00	0.25	0.03	24	
8	0.13	0.01	0.00	0.00	0.08	0.01	0.01	0.00	S	0.02	0.00	0.01	0.02	0.06	0.00	0.00	0.01	0.04	0.00	0.06	0.05	0.01	0.01	0.00	0.13	0.02	24		
9	0.04	0.00	0.02	0.04	0.00	0.01	0.01	0.01	S	0.00	0.09	0.01	0.01	0.00	0.04	0.00	0.00	0.03	0.01	0.07	0.00	0.00	0.07	0.00	0.09	0.02	24		
10	0.07	0.00	0.07	0.01	0.04	0.02	0.02	S	0.04	0.00	0.00	0.06	0.02	0.00	0.07	0.00	0.00	0.00	0.00	0.03	0.00	0.00	0.00	0.00	0.07	0.02	24		
11	0.01	0.08	0.01	0.00	0.04	S	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.06	0.00	0.08	0.00	0.00	0.05	0.00	0.00	0.00	0.08	0.02	24			
12	0.03	0.00	0.00	0.00	S	0.01	0.05	0.00	0.00	0.03	0.14	0.04	0.00	0.00	0.06	0.06	0.05	0.04	0.02	0.00	0.01	0.00	0.00	0.00	0.14	0.02	24		
13	0.00	0.03	0.02	S	0.01	0.01	0.00	0.02	0.06	0.00	0.04	0.00	0.00	0.00	0.00	0.03	0.01	0.01	0.02	0.04	0.01	0.07	0.00	0.01	0.07	0.02	24		
14	0.04	0.02	S	0.04	0.01	0.01	0.00	0.00	0.04	0.00	0.00	0.10	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.07	0.00	0.09	0.00	0.00	0.10	0.02	24		
15	0.01	S	0.05	0.00	0.00	0.03	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.02	0.05	0.00	0.09	0.00	0.00	0.09	0.01	24		
16	S	0.12	0.00	0.00	0.02	0.06	0.08	0.01	0.17	0.00	0.06	0.02	0.01	0.01	0.00	0.05	0.16	0.00	0.02	0.00	0.00	0.16	0.00	S	0.00	0.17	0.04	24	
17	0.00	0.00	0.08	0.11	0.09	0.00	0.01	0.00	0.00	0.01	0.12	0.00	0.00	0.00	0.00	0.11	0.05	0.02	0.00	0.12	0.12	0.00	S	0.00	0.00	0.12	0.04	24	
18	0.09	0.05	0.01	0.01	0.00	0.00	0.00	0.01	0.05	0.00	0.00	0.18	0.01	0.00	0.00	0.05	0.13	0.01	0.01	0.15	0.03	S	0.02	0.08	0.00	0.18	0.04	24	
19	0.00	0.01	0.00	0.00	0.00	0.03	0.00	0.00	0.01	0.00	0.11	0.01	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	S	0.05	0.00	0.00	0.11	0.01	24		
20	0.00	0.03	0.00	0.00	0.00	0.00	0.02	0.00	0.09	0.06	0.04	0.08	0.11	S1	0.12	0.18	0.14	0.08	S	0.00	0.01	0.09	0.12	0.00	0.18	0.05	23		
21	0.00	0.00	0.06	0.05	0.01	0.00	0.02	0.00	0.01	0.04	0.01	0.02	0.00	0.00	0.00	0.00	0.01	S	0.01	0.00	0.00	0.00	0.00	0.16	0.00	0.16	0.02	24	
22	0.00	0.00	0.09	0.00	0.00	0.05	0.00	0.00	0.04	0.00	0.05	0.02	0.04	0.00	0.03	0.00	0.01	S	0.01	0.03	0.00	0.01	0.00	0.15	0.00	0.15	0.02	24	
23	0.00	0.03	0.04	0.03	0.01	0.04	0.02	0.03	0.12	0.00	0.01	0.11	0.16	0.09	0.01	0.00	0.11	S	0.02	0.02	0.00	0.04	0.00	0.05	0.01	0.16	0.04	24	
24	0.01	0.18	0.01	0.02	0.00	0.00	0.03	0.09	0.00	0.08	0.06	0.15	0.11	0.07	0.01	S	0.05	0.07	0.09	0.11	0.13	0.18	0.03	0.00	0.18	0.06	24		
25	0.15	0.13	0.00	0.01	0.01	0.15	0.00	0.06	0.00	0.02	0.09	0.00	0.00	0.08	S	0.06	0.02	0.02	0.10	0.00	0.10	0.09	0.01	0.01	0.00	0.15	0.05	24	
26	0.02	0.00	0.00	0.09	0.00	0.04	0.00	0.00	0.02	0.00	0.04	0.01	S	0.00	0.00	0.02	0.16	0.07	0.00	0.00	0.01	0.09	0.06	0.00	0.16	0.03	24		
27	0.00	0.01	0.00	0.13	0.02	0.00	0.00	0.08	0.15	0.00	0.00	S	0.06	0.00	0.08	0.00	0.00	0.03	0.01	0.00	0.05	0.00	0.15	0.03	24				
28	0.00	0.01	0.00	0.06	0.03	0.02	0.12	0.01	0.05	0.09	0.00	S	0.00	0.00	0.02	0.01	0.08	0.02	0.01	0.02	0.00	0.01	0.09	0.00	0.12	0.03	24		
29	0.02	0.00	0.03	0.00	0.05	0.07	0.00	0.06	0.02	0.02	S	0.03	0.11	0.00	0.01	0.12	0.00	0.00	0.03	0.00	0.01	0.16	0.00	0.00	0.16	0.03	24		
30	0.04	0.00	0.00	0.08	0.00	0.00	0.00	0.00	0.02	S	0.11	0.01	0.05	0.04	0.00	0.00	0.02	0.01	0.00	0.03	0.00	0.01	0.00	0.04	0.00	0.11	0.02	24	
31	0.12	0.01	0.02	0.00	0.00	0.08	0.00	0.05	S	0.00	0.01	0.01	0.00	0.00	0.08	0.05	0.08	0.00	0.00	0.04	0.00	0.07	0.00	0.00	0.12	0.03	24		
HOURLY MAX		0.15	0.18	0.09	0.16	0.09	0.15	0.12	0.09	0.17	0.09	0.21	0.18	0.16	0.11	0.06	0.12	0.18	0.16	0.25	0.15	0.13	0.18	0.16	0.16				
HOURLY AVG		0.03	0.03	0.02	0.04	0.01	0.03	0.02	0.02	0.03	0.04	0.04	0.03	0.03	0.01	0.03	0.04	0.03	0.04	0.03	0.03	0.04	0.03	0.04	0.03	0.03	0.04	0.03	


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	391
MAXIMUM INSTANTANEOUS VALUE:	0.25 ppm @ HOUR(S) 18 ON DAY(S) 7
VAR-VARIOUS	
I2S CALIBRATION TIME:	30 hrs
MONTHLY CALIBRATION TIME:	6 hrs
STANDARD DEVIATION:	0.04
OPERATIONAL TIME:	737 hrs

NON-METHANE HYDROCARBONS Instantaneous Maximum (NMHC ppm)




Wind: THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-NMHC[ppm] Monthly: 01/2017 Type: PollutionRose Direction: Blowing From (Wind Frequency) Based On 1 Hr.  
Calm: 5.14% Valid Data: 94.47% Calm Avg: 0.00 [ppm]

Direction	0-0.1	0.1-0.3	0.3-1	1-2	>2.0	Total
N	13.27	0	0	0	0	13.27
NE	5.71	0	0	0	0	5.71
E	6.13	0	0	0	0	6.13
SE	8.42	0	0	0	0	8.42
S	21.4	0	0	0	0	21.4
SW	28.67	0	0	0	0	28.67
W	5.71	0	0	0	0	5.71
NW	5.56	0	0	0	0	5.56
Summary	94.87	0	0	0	0	94.87

% Icon	Classes (ppm)	95	0-0.1	0	0.1-0.3	0	0.3-1	0	1-2	0	>2.0
--------	---------------	----	-------	---	---------	---	-------	---	-----	---	------

THREE CREEKS #842 TRAILER Poll.: THREE CREEKS #842 TRAILER-NMHC[ppm] 01/01/2017 00:00 - 31/01/2017 23:00 Calm: 5.14% Calm Poll Avg: 0.00[ppm]



NMHC[ppm] Calibration: THREE CREEKS #842 TRAILER Monthly: 2017/01 Type: Span



## ***WIND SPEED***

## WIND SPEED Hourly Averages (WS kph)

	HR START (MST)	0:00 0:59	1:00 1:59	2:00 2:59	3:00 3:59	4:00 4:59	5:00 5:59	6:00 6:59	7:00 7:59	8:00 8:59	9:00 9:59	10:00 10:59	11:00 11:59	12:00 12:59	13:00 13:59	14:00 14:59	15:00 15:59	16:00 16:59	17:00 17:59	18:00 18:59	19:00 19:59	20:00 20:59	21:00 21:59	22:00 22:59	23:00 23:59	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.
DAY																													
1	9.7	8.9	8.6	11.5	9.6	10.7	8.2	11.0	10.5	7.1	5.6	9.5	13.0	9.9	5.0	2.8	2.0	1.1	0.9	0.8	1.1	3.8	2.3	2.2	0.8	13.0	5.4	24	
2	4.7	3.2	2.2	3.8	3.0	1.9	2.7	3.5	1.6	0.8	1.7	1.7	1.3	0.9	4.0	2.4	1.1	1.6	4.4	5.2	4.9	4.1	2.4	3.3	0.8	5.2	1.6	24	
3	2.7	3.7	3.3	3.2	4.3	3.8	2.9	2.6	3.0	2.3	1.5	0.9	4.1	4.7	4.7	2.8	3.2	4.4	5.1	5.6	5.4	5.2	4.8	4.0	0.9	5.6	3.1	24	
4	4.2	5.4	3.9	3.2	3.5	4.7	4.5	5.7	3.9	5.8	4.3	5.5	6.4	8.1	5.9	4.9	2.8	2.3	0.9	1.3	0.9	1.1	1.4	2.2	0.9	8.1	3.2	24	
5	1.9	0.8	2.0	3.1	2.3	3.2	4.3	4.5	4.1	P	P	P	P	7.5	7.6	7.8	5.0	3.5	4.4	4.8	8.5	8.9	7.5	8.8	0.8	8.9	4.0	20	
6	9.3	11.0	8.7	9.3	8.6	7.3	5.6	8.4	7.5	6.4	8.3	6.7	7.0	9.5	6.6	7.9	6.5	6.8	5.3	5.7	7.2	8.1	5.1	8.6	5.1	11.0	6.4	24	
7	9.6	7.0	7.4	9.4	8.6	7.7	7.3	8.8	9.8	10.9	8.9	8.6	9.1	8.4	7.8	8.0	6.8	6.6	5.1	5.7	4.9	3.3	2.1	0.5	0.5	10.9	7.1	24	
8	1.7	1.7	1.7	2.0	2.2	3.1	3.5	2.8	2.9	3.0	3.0	5.6	4.2	6.2	6.5	7.8	6.4	4.0	7.6	6.5	6.7	3.1	2.0	1.9	1.7	7.8	2.8	24	
9	4.4	7.1	5.4	4.4	4.5	1.3	3.6	3.3	5.0	3.6	2.3	2.5	4.6	3.8	3.0	3.5	2.1	4.3	5.1	2.7	6.7	4.5	4.4	5.3	1.3	7.1	3.2	24	
10	10.6	12.1	7.0	9.3	12.4	10.9	10.0	9.1	5.9	1.4	2.2	4.6	5.3	10.0	10.7	11.2	9.9	9.5	8.6	9.8	8.0	8.3	11.1	12.7	4.9	24			
11	13.7	14.1	14.0	15.6	16.0	12.1	11.3	14.3	20.1	20.9	20.0	21.1	20.0	19.9	16.3	12.4	6.0	4.5	4.8	1.9	2.8	1.2	3.6	1.2	21.1	7.5	24		
12	5.3	3.5	7.5	8.0	9.1	10.0	10.7	10.8	10.4	15.3	17.8	14.7	11.8	14.8	12.8	12.1	10.5	11.5	11.6	8.9	6.9	6.8	7.6	7.8	3.5	17.8	8.6	24	
13	8.2	6.0	8.0	9.6	10.3	13.3	12.3	12.2	13.8	14.6	13.4	10.6	14.2	13.3	15.0	14.3	12.2	11.8	11.1	13.3	14.9	14.3	14.6	13.1	6.0	15.0	11.6	24	
14	13.7	23.7	24.3	22.3	28.1	24.1	30.7	26.8	23.1	19.2	16.6	16.7	15.1	16.5	24.3	20.5	29.8	14.9	10.9	16.2	19.2	19.2	23.8	22.0	10.9	30.7	20.3	24	
15	24.8	15.8	12.1	11.7	11.0	15.8	20.6	16.6	13.1	14.8	13.0	10.7	12.9	13.2	16.7	19.3	15.5	16.0	14.8	12.8	15.6	16.5	15.3	16.5	10.7	24.8	14.7	24	
16	18.4	20.6	18.7	12.5	15.0	17.7	22.1	20.0	21.6	17.4	12.3	16.3	20.2	19.9	16.3	13.1	15.6	17.7	14.5	13.3	12.3	11.7	10.8	9.3	9.3	22.1	15.7	24	
17	10.6	12.2	15.5	10.8	7.1	12.6	9.8	7.7	15.1	12.8	9.7	7.7	8.6	7.9	5.7	7.7	6.7	7.1	5.6	2.5	6.7	6.3	4.6	5.2	2.5	15.5	7.9	24	
18	5.0	4.5	5.3	4.5	4.8	5.5	5.0	3.2	5.2	7.6	6.0	9.6	7.7	9.1	9.0	8.4	7.2	3.3	3.1	8.2	6.1	3.1	4.8	6.0	3.1	9.6	3.9	24	
19	6.1	8.4	6.4	5.6	6.3	6.2	5.3	5.8	3.5	3.3	3.7	5.5	4.8	3.8	1.8	4.9	2.9	0.6	3.8	0.9	5.9	2.0	3.4	6.7	0.6	8.4	2.3	24	
20	5.0	5.0	5.5	7.1	7.9	7.4	8.7	5.4	5.9	4.7	5.3	5.6	7.9	6.8	4.8	5.7	2.6	0.8	1.7	8.8	9.3	8.3	9.7	11.0	0.8	11.0	2.2	24	
21	9.8	11.0	10.3	10.6	10.4	9.8	9.6	8.6	8.5	7.9	6.8	7.1	8.5	7.5	8.7	7.2	6.2	6.4	5.0	5.1	4.8	5.4	4.6	4.1	4.1	11.0	7.6	24	
22	3.9	3.6	3.1	2.9	2.8	2.8	3.2	3.1	3.1	3.5	3.3	3.5	4.9	5.3	5.5	4.6	5.1	4.9	5.0	5.7	5.0	5.3	4.3	2.8	5.7	3.7	24		
23	5.1	4.8	4.8	3.6	3.5	3.1	3.9	3.4	3.1	2.0	2.2	0.9	0.7	4.0	5.0	4.5	2.7	3.4	5.1	5.1	4.1	3.6	4.3	3.9	0.7	5.1	1.2	24	
24	5.6	6.0	5.1	5.8	6.6	6.9	6.9	7.4	7.6	9.9	9.5	12.8	9.3	9.8	9.4	7.4	6.8	7.0	6.8	4.3	5.4	7.1	8.7	4.3	12.8	7.2	24		
25	4.7	9.1	5.7	6.2	10.3	8.3	7.5	8.1	8.6	10.1	10.6	10.8	11.2	13.2	13.3	15.1	13.8	13.8	10.7	10.0	11.0	9.1	10.2	12.6	4.7	15.1	9.4	24	
26	15.3	15.4	12.8	11.2	10.9	14.1	13.3	11.6	11.3	9.8	12.5	13.3	14.6	13.3	12.2	10.9	7.7	5.7	10.5	8.4	17.1	17.2	18.3	16.1	5.7	18.3	12.1	24	
27	13.1	9.1	11.8	11.3	12.4	10.5	11.4	12.5	14.4	15.8	22.3	20.4	21.5	18.1	17.5	18.2	18.4	17.4	16.5	15.0	14.1	15.3	14.4	12.6	9.1	22.3	14.9	24	
28	11.2	11.3	13.7	14.5	14.0	12.2	13.3	14.6	13.4	15.5	18.0	13.0	17.3	17.1	17.4	15.2	15.8	10.0	15.0	14.0	11.5	11.4	13.7	14.4	10.0	18.0	13.4	24	
29	11.9	10.0	9.1	8.0	9.6	12.4	8.4	11.5	12.1	14.5	15.6	14.5	14.2	14.0	12.3	10.7	11.4	10.3	11.4	8.0	6.8	7.8	10.0	9.9	6.8	15.6	10.4	24	
30	11.3	7.5	5.3	10.7	12.7	13.9	11.8	14.3	15.3	15.8	17.4	18.2	19.9	21.8	18.5	21.0	17.6	16.8	13.6	13.5	12.0	10.9	14.6	10.6	5.3	21.8	13.3	24	
31	8.3	7.4	9.3	8.8	5.3	2.8	3.3	3.6	3.7	3.9	5.6	6.1	6.0	8.1	10.2	7.9	3.4	4.2	3.0	0.7	4.3	5.5	3.4	1.6	0.7	10.2	3.7	24	
HOURLY MAX		24.8	23.7	24.3	22.3	28.1	24.1	30.7	26.8	23.1	20.9	22.3	21.1	21.5	21.8	24.3	21.0	29.8	17.7	16.5	16.2	19.2	19.2	23.8	22.0				
HOURLY AVG		3.6	4.0	3.9	2.8	3.3	3.9	4.3	4.0	4.4	4.9	5.1	5.1	5.8	5.3	5.9	5.6	5.2	4.3	3.9	3.5	4.0	3.9	3.9	3.8				

## STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

LAST CALIBRATION: October 12, 2016

DECLINATION : MAGNETIC DECLINATION 15 DEGREE EAST


## 24 HR AVERAGES January 2017



## MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	740
MINIMUM 1-HR AVERAGE	0.5 kph @ HOUR(S) 23
MAXIMUM 1-HR AVERAGE:	30.7 kph @ HOUR(S) 6
MAXIMUM 24-HR AVERAGE:	20.3 kph @ DAY(S) VAR-VARIOUS
MONTHLY CALIBRATION TIME:	0 hrs
OPERATIONAL TIME:	740 hrs
AMD OPERATION UPTIME:	99.5 %
STANDARD DEVIATION:	5.4 kph
MONTHLY AVERAGE:	4.3 kph

WIND SPEED Hourly Averages (WS kph)





**PEACE RIVER AREA MONITORING PROGRAM COMMITTEE**

**Three Creeks 842b Station - January 2017**

**WIND SPEED Instantaneous Maximum (WS kph)**

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	Avg.	
DAY																												
1	18.7	19.6	19.0	22.1	22.9	24.8	17.6	27.9	28.3	15.5	16.1	25.4	25.0	25.5	13.4	7.4	7.5	4.4	5.3	3.0	4.2	11.0	7.8	7.3	3.0	28.3	15.8	24
2	8.0	7.2	6.4	7.2	5.9	5.0	5.9	6.0	5.8	8.8	4.0	6.0	11.4	4.2	11.5	5.6	3.3	4.3	7.2	11.8	9.5	9.5	5.0	6.2	3.3	11.8	6.9	24
3	7.1	6.7	6.2	5.5	6.4	5.8	4.8	5.4	6.1	5.7	4.3	3.3	8.0	7.4	8.5	5.9	5.9	8.5	7.7	9.9	9.6	10.2	9.4	6.9	3.3	10.2	6.9	24
4	8.0	8.5	6.9	6.4	6.9	8.0	8.2	10.8	9.6	11.1	10.2	9.9	12.0	13.9	11.6	8.7	4.7	4.2	2.7	5.0	3.6	5.4	7.4	9.6	2.7	13.9	8.1	24
5	5.8	3.1	4.4	5.6	5.5	8.3	9.5	10.7	9.1	P	P	P	P	P	20.2	17.6	13.7	8.2	10.5	13.0	19.1	22.3	21.6	21.1	3.1	22.3	12.1	19
6	22.7	26.4	20.4	20.6	21.6	16.7	13.6	18.8	21.2	16.6	20.8	17.4	20.7	23.9	15.9	19.9	19.4	15.8	12.4	11.5	18.1	16.9	14.4	19.0	11.5	26.4	18.5	24
7	21.6	19.9	16.2	22.6	22.7	20.2	17.8	23.6	27.7	28.0	18.2	21.9	21.3	19.3	18.4	18.5	16.1	14.7	11.0	12.9	10.5	8.2	5.0	2.4	28.0	17.4	24	
8	3.9	3.4	3.8	3.8	3.5	5.4	6.5	7.4	6.7	6.4	10.2	9.2	8.0	11.4	11.0	14.5	12.2	8.1	15.8	13.8	13.1	8.5	4.8	5.0	3.4	15.8	8.2	24
9	11.6	14.0	9.1	8.0	9.0	5.8	7.9	7.7	8.1	8.1	5.3	7.0	16.9	12.8	5.8	6.5	5.2	8.1	8.7	9.6	11.9	11.0	7.5	10.2	5.2	16.9	9.0	24
10	20.7	20.0	21.0	27.9	31.0	26.2	24.8	23.2	17.2	4.6	5.6	9.4	11.1	19.2	18.3	18.7	17.2	17.9	15.7	16.7	15.4	18.5	20.9	22.5	4.6	31.0	18.5	24
11	22.9	24.0	23.0	27.2	27.5	22.6	23.4	29.9	44.6	41.5	36.4	49.7	50.6	49.3	40.1	35.0	17.9	11.8	10.3	6.7	6.8	3.9	5.6	7.3	3.9	50.6	25.8	24
12	9.8	9.9	15.1	15.4	17.6	18.8	18.4	18.1	21.3	28.9	33.9	33.6	22.8	25.0	29.1	21.9	20.9	18.9	22.9	16.8	13.5	12.1	15.0	16.4	9.8	33.9	19.8	24
13	13.1	9.6	13.5	16.8	16.5	26.0	21.9	18.1	21.9	22.4	22.8	21.7	27.9	24.4	26.7	24.1	22.2	25.5	22.9	21.0	23.0	23.5	24.5	21.1	9.6	27.9	21.3	24
14	32.7	42.5	44.4	40.1	43.8	42.6	53.4	47.6	40.4	39.0	31.8	34.6	35.7	36.2	40.0	55.9	59.2	31.3	21.2	30.4	34.1	34.9	44.0	40.4	21.2	59.2	39.8	24
15	48.3	33.2	25.4	22.3	20.9	36.8	40.2	30.1	23.3	24.7	22.5	19.5	22.9	25.0	35.2	35.4	28.6	29.0	26.6	24.6	33.9	29.6	25.8	35.6	19.5	48.3	29.1	24
16	32.2	37.1	35.5	31.4	28.4	30.6	40.1	34.9	42.9	37.3	26.7	33.0	34.0	36.6	26.9	23.3	27.6	33.5	25.3	21.0	22.0	20.4	20.8	15.5	42.9	29.9	24	
17	19.2	19.1	28.3	23.0	16.6	21.6	17.5	21.0	25.5	21.5	16.7	15.3	14.7	14.7	13.8	13.4	11.4	13.2	13.0	6.7	14.3	18.0	10.3	11.7	6.7	28.3	16.7	24
18	10.2	11.6	11.5	11.8	9.8	11.9	16.2	11.0	13.2	13.4	19.0	21.5	17.5	16.9	16.3	13.9	9.0	7.2	15.3	12.6	6.6	12.7	14.8	6.6	21.5	13.2	24	
19	14.8	22.0	15.1	14.9	13.2	14.3	11.9	13.5	10.9	7.5	8.8	14.5	12.8	8.9	8.0	11.9	6.0	3.3	8.8	10.9	12.0	6.1	6.8	11.3	3.3	22.0	11.2	24
20	10.0	11.6	12.8	10.5	12.5	13.1	17.1	12.8	14.2	9.0	11.7	15.8	15.2	13.3	10.3	12.1	7.2	4.2	5.9	20.9	23.6	19.3	22.5	23.0	4.2	23.6	13.7	24
21	25.1	24.5	25.4	25.0	24.4	22.3	24.4	20.1	22.6	19.4	15.4	15.7	20.4	18.6	17.9	16.8	14.8	15.3	10.9	11.5	10.2	11.6	8.8	9.1	8.8	25.4	17.9	24
22	7.8	7.6	7.1	5.8	6.4	6.1	6.7	7.1	5.9	7.4	8.6	10.2	7.8	11.0	12.9	13.1	10.0	12.6	12.0	12.7	11.2	11.8	11.1	5.8	13.1	9.4	24	
23	11.6	12.3	11.6	10.3	9.6	7.5	8.1	6.8	6.3	4.6	5.6	4.9	3.5	8.1	8.6	7.3	6.4	10.8	11.2	8.9	7.9	7.4	7.3	9.1	3.5	12.3	8.2	24
24	9.7	9.3	9.6	10.1	12.2	12.4	11.9	15.6	13.0	12.1	17.3	18.1	23.7	18.2	19.6	16.3	13.7	12.1	13.4	11.5	10.4	9.7	12.7	15.7	9.3	23.7	13.7	24
25	13.2	17.9	18.3	13.8	15.2	14.6	13.7	14.6	14.5	16.8	21.0	20.5	19.4	22.8	22.5	26.2	23.1	23.1	23.8	17.9	22.1	18.7	20.6	22.8	13.2	26.2	19.0	24
26	27.7	29.3	22.9	22.1	22.9	21.8	21.2	20.9	20.9	20.2	22.8	22.6	24.0	22.7	19.4	20.0	13.5	18.1	21.3	18.8	33.9	31.6	35.5	30.8	13.5	35.5	23.5	24
27	31.5	16.6	20.1	17.4	23.0	21.0	25.6	27.8	25.2	35.3	38.4	36.7	37.3	31.9	32.4	34.3	31.4	29.0	29.0	26.9	25.1	28.7	26.7	23.2	16.6	38.4	28.1	24
28	19.2	18.0	24.8	26.5	22.6	21.0	22.6	24.4	25.6	26.9	32.2	26.2	34.8	34.1	33.8	30.2	27.6	29.2	45.2	32.9	28.0	25.1	28.0	24.8	18.0	45.2	27.7	24
29	21.0	17.0	16.5	13.1	19.5	23.3	21.1	18.7	20.7	25.5	25.8	25.3	24.5	24.3	20.4	19.8	18.3	18.9	19.5	16.4	12.2	14.5	16.7	17.2	12.2	25.8	19.6	24
30	18.0	14.2	21.8	26.3	27.3	29.9	30.4	36.9	35.4	36.1	35.2	37.8	45.4	41.7	41.4	42.8	36.7	34.8	36.5	34.4	30.5	24.7	34.8	34.2	14.2	45.4	32.8	24
31	20.9	20.9	25.6	20.5	14.9	8.3	6.2	7.1	6.5	6.6	9.1	11.8	10.5	20.9	19.1	14.4	8.6	6.7	5.9	2.8	8.4	9.7	8.1	3.7	2.8	25.6	11.6	24
HOURLY MAX	48.3	42.5	44.4	40.1	43.8	42.6	53.4	47.6	44.6	41.5	38.4	49.7	50.6	49.3	41.4	55.9	59.2	34.8	45.2	34.4	34.1	34.9	44.0	40.4				
HOURLY AVG	17.6	17.3	17.5	17.2	17.4	17.8	18.3	18.7	19.2	18.7	18.4	19.9	21.5	21.4	20.3	19.8	16.9	15.6	15.8	15.3	16.5	15.8	16.2	16.4				


**STATUS FLAG CODES**

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

**MONTHLY SUMMARY**

MAXIMUM INSTANTANEOUS VALUE:	59.2	kph	@ HOUR(S)	16	ON DAY(S)	14
VAR-VARIOUS						
OPERATIONAL TIME:						
739 hrs						

WIND SPEED Instantaneous Maximum (WS kph)




Wind: THREE CREEKS #842 TRAILER Monitor: WSP [kph] Monthly: 01/2017 Type: WindRose Direction: Blowing From (Wind Frequency) Based On 1 Hr.  
Calm: 4.86% Valid Data: 99.73%

Direction	1.8-6.0	6.0-12.0	12.0-20.0	20.0-29.0	29.0-39.0	>39.0	Total
N	5	7.16	0.68	0.14	0	0	12.98
NE	4.73	1.08	0	0	0	0	5.81
E	3.65	2.57	0	0	0	0	6.22
SE	5.68	2.43	0.14	0	0	0	8.25
S	5.81	9.46	5.54	0.41	0	0	21.22
SW	5	8.65	13.24	2.3	0.27	0	29.46
W	2.7	0.81	1.89	0.41	0	0	5.81
NW	1.49	2.7	0.68	0.54	0	0	5.41
Summary	34.06	34.86	22.17	3.8	0.27	0	95.16

%	Icon	Classes (kph)	34	1.8-6.0	35	6.0-12.0	22	12.0-20.0	4	20.0-29.0	0	29.0-39.0	0	>39.0
---	------	---------------	----	---------	----	----------	----	-----------	---	-----------	---	-----------	---	-------

THREE CREEKS #842 TRAILER 01/01/2017 00:00 - 31/01/2017 23:00 Calm: 4.86% Calm Wind Avg Speed: 1.17 (kph)



## ***WIND DIRECTION***



**PEACE RIVER AREA MONITORING PROGRAM COMMITTEE**

**Three Creeks 842b Station - January 2017**

**WIND DIRECTION Hourly Averages (WD)**

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24-HOUR AVG	24-HR QUADRANT	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59				
DAY																												
1	NW	NW	WNW	NW	NNW	NNW	NNW	NNW	NNW	NNW	SSE	SE	ESE	ESE	SE	ESE	E	NW	24									
2	ENE	E	ENE	ENE	ENE	ENE	NE	ENE	ENE	ENE	E	ENE	NNE	WSW	WSW	SSW	SSE	SE	SE	SE	SSE	SE	SSE	ESE	24			
3	SE	SSE	SSE	SE	SSE	SSE	SE	SE	SE	SSE	S	SSE	WSW	WSW	WSW	SW	SSW	S	S	SSW	SW	S	S	S	24			
4	SSW	S	S	SSW	S	SSE	SE	SE	SSE	SSE	S	SSW	SSW	SSW	SW	SSW	S	S	SW	WSW	WSW	WNW	NNE	S	24			
5	NE	N	NNW	NW	NNW	N	N	NNW	P	P	P	P	NE	ENE	ENE	NE	NE	ENE	E	E	E	E	E	NE	20			
6	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	ENE	24			
7	NNW	NNW	NNW	NNW	N	N	N	N	N	N	N	N	N	N	N	N	N	NNW	N	N	NNW	N	E	N	24			
8	ENE	E	ESE	E	E	ESE	ESE	SE	ESE	SE	SSE	S	SW	SW	SW	SSW	SW	SW	SSW	SSW	SW	SSW	SSE	S	24			
9	SW	SW	SW	SW	SW	W	SSW	WSW	WSW	WSW	WSW	WSW	NW	NNW	W	WSW	SW	WSW	SW	SSW	SSE	SE	SW	24				
10	SSE	S	SW	NNW	N	NNW	NNW	NNW	NNW	S	SW	SW	SW	SW	SW	SSW	SW	SW	SSW	SSW	SSW	SSW	SSW	SW	24			
11	SW	SW	SW	SW	WSW	WSW	WSW	W	WNW	WNW	WNW	NW	NNW	NNW	N	NNE	N	NE	E	E	ENE	E	ESE	WNW	24			
12	SE	SE	SE	SE	SE	SSE	SSE	SE	SE	SSE	SSE	S	S	S	S	SSW	S	SSW	SW	SW	SW	SW	SSW	S	24			
13	S	SE	SSE	S	SSE	S	S	S	S	S	S	S	S	S	S	SSW	SSW	SW	SW	SSW	SSE	S	SSW	S	24			
14	SSW	SW	SSW	SW	SW	SW	WSW	SSW	S	S	SSW	SW	SW	SW	SW	24												
15	WSW	SW	SW	SW	SW	WSW	WSW	SW	WSW	SW	WSW	SSW	SW	WSW	WSW	SSW	SSW	SW	SSW	SW	SSW	SSW	SSW	SW	24			
16	SW	SSW	SSW	S	SSW	SSW	SSW	SSW	SSW	S	S	S	S	S	S	SSE	S	S	S	S	S	S	S	24				
17	SSE	S	S	S	SSE	S	SSW	S	SSW	S	S	S	S	S	S	SSW	SSE	SE	SE	SE	SE	SE	ESE	S	24			
18	ESE	ESE	ESE	ESE	E	ESE	SE	SE	SSE	SE	SSE	SE	SSE	S	SSW	SW	SSW	S	SE	ESE	SE	SE	E	ENE	N	SE	24	
19	N	N	N	NNE	NNE	NNE	NNE	NNE	NE	NNW	NNW	NNE	NE	NE	NNW	W	NW	SW	ESE	E	SW	S	S	S	NNE	24		
20	S	S	S	SSE	S	S	S	S	SSW	S	SSE	S	NNE	NNW	N	N	NNE	SSE	24									
21	NNE	N	N	N	N	N	N	N	N	NNE	N	N	N	N	N	N	N	N	N	N	N	N	N	N	24			
22	NNE	N	N	N	N	NNE	N	NNE	NNE	NE	NE	NE	NE	NE	NE	NE	NE	ENE	ENE	ENE	ENE	ENE	E	NE	24			
23	E	E	E	E	ENE	ENE	NE	ENE	ENE	E	E	ESE	SSE	W	W	WSW	SW	SSE	SSE	SSW	S	S	S	SE	24			
24	S	S	S	S	SSW	SSW	SSW	S	S	S	S	SSW	SSW	S	S	S	S	SSW	S	S	SE	SSE	SSE	S	24			
25	SSE	S	S	S	S	S	S	SSW	SSW	SSW	SSW	SW	SSW	SW	SW	S	24											
26	SW	SW	SW	SSW	SSW	SSW	SW	SW	SW	SW	SW	SW	SW	SW	SW	SSW	SSW	S	S	SSW	SW	WSW	WSW	WSW	SW	24		
27	WSW	SW	SSW	SW	SW	SSW	SSW	SW	SW	SW	SW	SW	SW	SW	SW	SW	WSW	WSW	WSW	WSW	WSW	WSW	SSW	SW	24			
28	S	SSE	SW	SW	SW	SW	SW	SW	SSW	SSW	SSW	S	SSW	SW	SW	SW	SW	SW	SW	SSW	SSW	SSW	SSW	SSW	24			
29	SSW	S	S	S	SSW	SSW	S	SSW	SSW	SW	SW	SW	SW	SW	SSW	SW	SW	SW	WSW	WSW	WSW	WSW	WSW	SW	24			
30	WSW	WSW	W	NW	NNW	NNW	NNW	NNW	W	WNW	WNW	WNW	W	WNW	WNW	NNW	24											
31	N	N	NNE	N	N	NNW	NNW	NNW	W	WSW	WSW	W	WNW	WNW	NNW	NNW	NNW	SW	SW	WSW	W	WSW	NNW	NNW	24			


**STATUS FLAG CODES**

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

LAST CALIBRATION: October 12, 2016  
 DECLINATION : MAGNETIC DECLINATION 15 DEGREE EAST

MONTHLY CALIBRATION TIME:	0 hrs	OPERATIONAL TIME:	740 hrs
STANDARD DEVIATION:	89	AMD OPERATION UPTIME:	99.5 %
MONTHLY AVERAGE: 218 (SW)			

WIND DIRECTION Hourly Averages (WD)




## ***RELATIVE HUMIDITY***

**RELATIVE HUMIDITY Hourly Averages (RH %)**

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.
DAY	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59				
1		86	83	82	85	84	84	88	88	84	85	83	81	81	74	77	82	83	86	86	84	82	85	83	81	74	88	83	24
2		82	82	80	79	78	79	78	77	79	78	78	79	79	74	72	74	82	79	81	85	85	83	81	82	72	85	79	24
3		82	82	81	81	82	81	79	80	83	83	84	85	85	86	86	87	88	89	89	89	89	89	89	90	79	90	85	24
4		90	90	90	90	90	90	90	90	91	92	92	92	92	91	92	92	93	93	95	95	95	95	95	94	90	95	92	24
5		92	93	91	91	90	90	89	89	89	P	P	P	P	82	81	81	82	83	85	87	87	88	87	86	81	93	87	20
6		86	86	85	85	85	85	84	83	82	83	82	82	79	77	80	80	80	80	81	80	80	80	79	81	77	86	82	24
7		81	80	80	81	80	80	80	81	80	80	79	78	77	76	75	76	76	77	76	76	75	75	77	75	81	78	24	
8		75	74	73	72	72	71	73	74	77	75	71	73	69	70	74	75	77	79	80	81	82	82	80	79	69	82	75	24
9		82	81	82	81	81	79	81	81	82	82	80	77	79	73	78	80	82	80	82	78	82	80	78	79	73	82	80	24
10		80	81	83	82	81	80	79	78	76	75	76	76	74	74	74	76	78	79	81	81	82	83	83	74	83	79	24	
11		84	84	83	81	79	77	75	75	74	73	72	69	69	80	64	52	46	49	60	65	72	74	73	74	46	84	71	24
12		74	75	74	73	73	71	74	77	79	80	77	71	67	67	68	67	70	75	73	75	75	75	75	67	80	73	24	
13		75	80	82	83	83	81	79	84	82	82	77	78	72	69	69	71	72	71	71	76	76	75	72	73	69	84	76	24
14		73	69	69	68	66	65	61	62	64	67	67	64	63	63	59	58	61	66	70	69	73	72	69	58	73	66	24	
15		66	70	71	71	73	70	66	70	72	72	69	63	62	61	60	59	64	64	67	68	68	71	71	70	59	73	67	24
16		68	64	65	66	65	64	58	58	57	58	62	61	58	58	59	62	60	59	60	61	62	65	62	91	57	63	24	
17		94	92	86	82	88	85	84	88	79	80	81	82	78	77	80	73	81	82	82	82	82	82	84	73	94	83	24	
18		81	81	84	81	77	78	75	77	80	78	74	65	55	49	48	50	54	67	79	75	68	82	80	80	48	84	72	24
19		89	93	92	91	92	91	91	91	90	88	87	84	85	83	81	85	83	88	92	93	96	96	96	91	96	90	24	
20		96	96	97	96	94	93	93	93	91	92	85	76	73	70	65	66	74	90	92	94	94	94	93	92	65	97	87	24
21		91	90	90	88	87	86	86	85	85	83	83	82	80	81	80	83	85	84	85	85	86	85	80	91	85	24		
22		84	84	83	82	82	82	82	82	82	81	82	81	79	80	80	81	81	82	82	83	83	82	83	79	84	82	24	
23		85	85	87	86	84	82	81	81	82	85	86	83	81	83	82	85	85	87	89	90	89	89	90	81	90	85	24	
24		90	90	90	90	90	91	91	91	92	92	91	87	82	80	75	75	78	86	90	90	91	92	93	92	75	93	87	24
25		90	90	88	90	89	89	89	90	89	88	85	82	79	76	73	73	76	78	81	83	83	84	85	73	90	84	24	
26		85	84	84	82	85	83	84	84	85	82	79	76	73	72	68	67	72	78	73	73	70	67	66	66	85	77	24	
27		65	69	71	71	71	71	74	71	72	73	68	66	64	63	64	64	66	68	68	69	70	70	71	70	63	74	69	24
28		77	81	74	76	79	76	73	70	67	66	64	63	58	54	54	55	56	61	61	65	68	68	69	70	54	81	67	24
29		72	75	77	80	77	74	77	76	76	76	74	72	73	74	72	73	73	74	77	78	79	77	78	72	80	75	24	
30		79	75	66	59	57	53	52	45	43	43	42	43	44	47	52	66	74	85	88	83	86	87	78	73	42	88	63	24
31		75	78	78	79	78	80	84	87	90	90	87	80	83	81	75	73	73	78	80	80	81	82	85	88	73	90	81	24
HOURLY MAX		96	96	97	96	94	93	93	92	92	92	92	91	92	92	93	93	93	95	96	96	96	96	96					
HOURLY AVG		82	82	81	81	80	79	79	79	79	77	75	73	72	71	72	74	77	79	80	80	81	81	81	81	81	81	81	


**STATUS FLAG CODES**

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

**24 HR AVERAGES January 2017**

**MONTHLY SUMMARY**

MINIMUM 1-HR AVERAGE:	42	% @ HOUR(S)	10	ON DAY(S)	30
MAXIMUM 1-HR AVERAGE:	97	% @ HOUR(S)	2	ON DAY(S)	20
MAXIMUM 24-HR AVERAGE:	92	%		ON DAY(S)	4
				VAR-VARIOUS	
OPERATIONAL TIME:				740	hrs
AMD OPERATION UPTIME:				99.5	%
STANDARD DEVIATION:	10			MONTHLY AVERAGE:	78 %


RELATIVE HUMIDITY Hourly Averages (RH %)



## ***BAROMETRIC PRESSURE***


**BAROMETRIC PRESSURE Hourly Averages (BP inHg)**

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
DAY	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59					
1	27.93	27.94	27.96	27.97	27.98	28.00	28.00	28.01	28.02	28.04	28.03	28.03	28.02	28.03	28.03	28.04	28.04	28.05	28.05	28.05	28.06	28.06	28.07	28.08	27.93	28.08	28.02	24		
2	28.10	28.11	28.13	28.15	28.17	28.20	28.23	28.25	28.26	28.28	28.29	28.30	28.29	28.28	28.27	28.26	28.30	28.31	28.32	28.31	28.31	28.30	28.30	28.29	28.10	28.32	28.25	24		
3	28.28	28.29	28.29	28.30	28.29	28.28	28.29	28.29	28.28	28.28	28.29	28.29	28.29	28.28	28.28	28.28	28.27	28.28	28.27	28.26	28.25	28.24	28.22	28.21	28.20	28.20	28.27	24		
4	28.20	28.20	28.19	28.18	28.18	28.17	28.16	28.14	28.14	28.13	28.12	28.11	28.09	28.08	28.06	28.05	28.05	28.04	28.04	28.04	28.03	28.02	28.02	28.01	28.01	28.20	28.10	24		
5	28.00	27.99	27.99	27.98	27.97	27.97	27.97	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	27.95	28.01	27.98	20
6	27.93	27.93	27.93	27.93	27.92	27.92	27.93	27.94	27.95	27.95	27.96	27.96	27.97	27.99	28.01	28.03	28.06	28.08	28.10	28.12	28.14	28.17	27.92	28.17	27.99	24				
7	28.19	28.21	28.24	28.26	28.28	28.29	28.30	28.32	28.34	28.36	28.36	28.36	28.34	28.33	28.33	28.32	28.32	28.31	28.31	28.31	28.30	28.29	28.28	28.28	28.19	28.36	28.30	24		
8	28.28	28.27	28.27	28.27	28.26	28.24	28.21	28.19	28.19	28.18	28.16	28.12	28.09	28.07	28.08	28.07	28.03	28.02	28.01	28.00	27.98	27.96	27.93	27.93	28.28	28.12	24			
9	27.90	27.89	27.88	27.87	27.85	27.83	27.80	27.79	27.79	27.77	27.76	27.75	27.74	27.75	27.75	27.75	27.75	27.75	27.75	27.73	27.70	27.69	27.67	27.65	27.65	27.90	27.78	24		
10	27.62	27.58	27.57	27.61	27.68	27.73	27.78	27.81	27.82	27.84	27.85	27.83	27.80	27.78	27.77	27.75	27.73	27.72	27.69	27.68	27.65	27.63	27.59	27.56	27.85	27.71	24			
11	27.51	27.48	27.46	27.44	27.43	27.43	27.42	27.41	27.43	27.44	27.47	27.51	27.57	27.64	27.69	27.76	27.82	27.85	27.87	27.88	27.88	27.88	27.88	27.41	27.88	27.61	24			
12	27.88	27.86	27.84	27.83	27.81	27.78	27.75	27.74	27.73	27.71	27.68	27.64	27.63	27.61	27.62	27.62	27.63	27.66	27.67	27.70	27.71	27.72	27.74	27.61	27.88	27.72	24			
13	27.77	27.79	27.80	27.80	27.81	27.82	27.83	27.84	27.85	27.86	27.87	27.86	27.85	27.86	27.86	27.87	27.87	27.87	27.86	27.85	27.83	27.82	27.81	27.80	27.77	27.83	24			
14	27.79	27.78	27.79	27.77	27.76	27.74	27.72	27.72	27.73	27.74	27.72	27.69	27.68	27.67	27.68	27.69	27.65	27.63	27.61	27.60	27.59	27.59	27.59	27.70	27.70	24				
15	27.59	27.59	27.59	27.60	27.60	27.60	27.61	27.61	27.61	27.63	27.64	27.64	27.63	27.63	27.64	27.65	27.66	27.66	27.66	27.66	27.65	27.65	27.65	27.66	27.63	24				
16	27.65	27.63	27.62	27.60	27.57	27.54	27.53	27.50	27.48	27.48	27.46	27.44	27.43	27.40	27.38	27.35	27.33	27.30	27.26	27.23	27.20	27.19	27.17	27.17	27.65	27.43	24			
17	27.15	27.15	27.14	27.16	27.16	27.16	27.17	27.17	27.17	27.17	27.18	27.18	27.18	27.17	27.16	27.17	27.17	27.15	27.13	27.12	27.12	27.12	27.09	27.07	27.18	27.15	24			
18	27.05	27.05	27.04	27.03	27.01	27.00	26.99	26.99	26.99	27.00	27.00	27.01	27.00	27.01	27.00	27.01	27.01	27.01	27.01	27.03	27.04	27.07	26.99	27.07	27.02	24				
19	27.08	27.09	27.11	27.12	27.13	27.13	27.12	27.12	27.14	27.14	27.14	27.12	27.11	27.11	27.10	27.11	27.11	27.12	27.12	27.12	27.12	27.11	27.11	27.08	27.14	27.12	24			
20	27.12	27.13	27.13	27.14	27.13	27.14	27.14	27.15	27.16	27.18	27.19	27.19	27.19	27.21	27.22	27.22	27.22	27.24	27.26	27.30	27.32	27.35	27.35	27.20	27.20	24				
21	27.37	27.39	27.42	27.45	27.48	27.51	27.53	27.56	27.62	27.65	27.67	27.69	27.71	27.73	27.75	27.77	27.77	27.79	27.81	27.84	27.86	27.87	27.88	27.87	27.88	27.66	24			
22	27.88	27.89	27.90	27.91	27.92	27.91	27.91	27.90	27.90	27.90	27.89	27.88	27.86	27.85	27.84	27.84	27.84	27.83	27.82	27.82	27.82	27.82	27.82	27.92	27.87	24				
23	27.81	27.81	27.80	27.80	27.79	27.80	27.80	27.80	27.81	27.81	27.80	27.79	27.78	27.77	27.77	27.77	27.77	27.77	27.77	27.76	27.76	27.75	27.75	27.81	27.79	24				
24	27.75	27.75	27.75	27.74	27.74	27.75	27.76	27.77	27.77	27.77	27.77	27.77	27.77	27.78	27.78	27.78	27.78	27.78	27.80	27.82	27.82	27.74	27.82	27.78	27.20	24				
25	27.81	27.81	27.81	27.82	27.82	27.81	27.81	27.82	27.82	27.82	27.83	27.82	27.82	27.82	27.83	27.83	27.83	27.84	27.84	27.85	27.85	27.85	27.82	27.85	27.82	24				
26	27.86	27.87	27.88	27.89	27.90	27.90	27.90	27.91	27.92	27.94	27.94	27.93	27.93	27.93	27.92	27.91	27.90	27.89	27.89	27.91	27.92	27.94	27.94	27.94	27.91	24				
27	27.96	27.97	27.97	27.98	27.98	27.99	27.98	27.96	27.94	27.92	27.92	27.91	27.90	27.90	27.91	27.92	27.93	27.93	27.94	27.94	27.94	27.94	27.94	27.94	27.94	24				
28	27.94	27.93	27.91	27.90	27.89	27.88	27.87	27.85	27.83	27.83	27.82	27.82	27.80	27.80	27.81	27.81	27.81	27.81	27.81	27.80	27.80	27.81	27.79	27.94	27.84	24				
29	27.80	27.79	27.78	27.76	27.75	27.74	27.73	27.72	27.71	27.70	27.70	27.68	27.66	27.64	27.62	27.61	27.60	27.59	27.60	27.60	27.62	27.62	27.59	27.59	27.80	27.68	24			
30	27.63	27.66	27.68	27.71	27.73	27.75	27.76	27.78	27.80	27.82	27.84	27.85	27.86	27.87	27.88	27.90	27.91	27.93	27.95	27.97	27.99	28.01	28.04	28.07	27.63	28.07	27.85	24		
31	28.09	28.11	28.12	28.14	28.15	28.16	28.17	28.18	28.18	28.19	28.20	28.20	28.20	28.20	28.21	28.22	28.23	28.23	28.24	28.25	28.26	28.28	28.09	28.28	28.19	24				
HOURLY MAX		28.28	28.29	28.29	28.30	28.29	28.32	28.32	28.34	28.36	28.36	28.34	28.33	28.33	28.32	28.32	28.32	28.31	28.31	28.31	28.30	28.30	28.29							
HOURLY AVG		27.77	27.77	27.77	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.78	27.79	27.79	27.78	27.78	27.79	27.79	27.79	27.79	27.79	24		

**24 HR AVERAGES January 2017**

**MONTHLY SUMMARY**

MINIMUM 1-HR AVERAGE:	26.99	inHg	@ HOUR(S)	6 , 7	ON DAY(S)	18 , 18
MAXIMUM 1-HR AVERAGE:	28.36	inHg	@ HOUR(S)	VAR	ON DAY(S)	7
MAXIMUM 24-HR AVERAGE:	28.30	inHg			ON DAY(S)	7
					VAR-VARIOUS	
OPERATIONAL TIME:						
AMD OPERATION UPTIME:						
STANDARD DEVIATION:	0.34				MONTHLY AVERAGE:	27.78 inHg

BAROMETRIC PRESSURE Hourly Averages (BP inHg)




## ***AMBIENT TEMPERATURE***

## AMBIENT TEMPERATURE Hourly Averages (AmbTPX °C)

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.
	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59				
DAY																													
1	-9.9	-9.6	-9.5	-9.9	-10.3	-9.9	-9.7	-9.7	-10.1	-10.8	-11.1	-10.0	-10.0	-9.4	-10.1	-11.1	-11.7	-13.9	-15.4	-15.4	-17.5	-17.7	-17.8	-18.8	-18.8	-9.4	-12.1	24	
2	-19.9	-17.3	-16.5	-16.8	-18.8	-21.5	-23.1	-23.2	-24.6	-23.2	-21.7	-19.1	-16.9	-14.6	-14.8	-16.0	-20.3	-23.8	-23.7	-23.0	-22.9	-22.3	-22.7	-21.8	-24.6	-14.6	-20.4	24	
3	-21.8	-22.0	-22.0	-22.9	-22.5	-22.3	-24.1	-23.9	-20.7	-20.2	-18.8	-17.2	-16.2	-16.4	-15.8	-15.0	-14.3	-14.2	-14.1	-13.8	-13.5	-13.0	-12.5	-12.0	-24.1	-12.0	-17.9	24	
4	-11.4	-11.2	-10.8	-10.9	-12.4	-12.7	-12.9	-11.9	-10.9	-10.1	-9.4	-8.6	-8.0	-7.4	-7.2	-7.2	-7.0	-7.0	-6.6	-6.1	-5.4	-5.3	-4.7	-4.2	-4.2	-8.7	-2.4	24	
5	-4.3	-5.1	-4.9	-5.3	-5.4	-5.3	-5.6	-5.9	-6.0	P	P	P	P	P	-7.4	-8.3	-8.6	-9.5	-12.1	-14.2	-14.1	-14.3	-13.7	-13.9	-14.1	-14.3	-4.3	-8.9	20
6	-14.6	-14.9	-15.3	-15.7	-15.9	-16.2	-16.7	-17.4	-18.0	-17.9	-17.4	-16.5	-15.4	-15.1	-14.5	-14.4	-15.1	-16.5	-16.3	-16.6	-17.0	-17.5	-17.8	-19.6	-19.6	-14.4	-16.3	24	
7	-20.2	-20.1	-20.0	-20.3	-20.7	-20.7	-20.6	-19.9	-19.6	-19.7	-19.4	-19.1	-18.9	-18.8	-18.9	-19.1	-19.6	-20.0	-20.2	-20.5	-20.9	-21.1	-23.3	-25.9	-25.9	-18.8	-20.3	24	
8	-27.6	-29.0	-29.9	-30.5	-31.0	-31.7	-30.9	-28.7	-26.0	-26.6	-23.5	-21.6	-20.0	-20.0	-20.1	-19.9	-20.2	-20.4	-20.7	-20.9	-21.4	-22.7	-23.8	-24.6	-31.7	-19.9	-24.7	24	
9	-22.4	-21.1	-21.1	-20.9	-20.8	-20.2	-20.4	-20.2	-20.4	-19.3	-19.2	-19.1	-20.9	-21.8	-23.2	-24.9	-24.7	-26.3	-24.0	-23.9	-25.1	-25.4	-26.3	-19.1	-21.9	24			
10	-23.9	-21.7	-19.8	-19.9	-21.4	-21.8	-23.4	-24.9	-25.9	-28.1	-26.7	-24.6	-23.0	-22.6	-23.0	-22.9	-23.3	-23.0	-22.1	-20.8	-19.9	-17.9	-16.6	-28.1	-16.6	-22.5	24		
11	-15.8	-14.9	-13.7	-12.8	-12.0	-10.7	-9.3	-9.0	-7.7	-7.4	-7.4	-7.8	-9.2	-11.5	-12.7	-13.2	-15.6	-19.5	-21.7	-24.8	-26.5	-28.6	-29.7	-30.3	-7.4	-15.5	24		
12	-30.0	-27.9	-26.1	-25.4	-24.5	-23.4	-22.6	-22.2	-21.4	-19.8	-17.6	-15.5	-14.6	-14.2	-14.4	-14.5	-14.9	-16.3	-15.7	-16.2	-14.9	-13.7	-13.7	-30.0	-13.7	-18.9	24		
13	-13.7	-16.9	-17.5	-17.0	-16.1	-14.0	-13.0	-14.7	-13.4	-12.9	-10.3	-9.9	-7.7	-6.4	-6.1	-6.1	-6.2	-5.5	-5.5	-6.7	-5.9	-4.7	-4.9	-17.5	-4.7	-10.1	24		
14	-3.9	-1.2	-0.6	-0.3	0.1	0.4	1.1	1.2	1.2	1.0	0.9	0.9	1.7	2.1	2.5	3.4	3.8	2.8	1.3	1.0	1.7	1.4	1.4	2.1	-3.9	3.8	1.1	24	
15	2.4	1.1	0.7	0.5	0.1	0.8	1.8	0.7	-0.1	0.5	1.9	2.1	2.5	2.9	3.3	2.0	1.8	0.8	0.3	0.3	-0.1	0.0	0.3	-0.1	3.3	1.1	24		
16	0.8	1.8	1.5	1.2	1.6	2.2	3.3	3.5	4.4	3.9	2.8	4.1	5.6	5.9	5.8	5.3	5.4	6.0	5.5	5.3	4.9	4.4	3.3	2.6	0.8	6.0	3.8	24	
17	2.2	2.3	3.1	3.3	1.8	2.5	2.3	1.0	3.5	3.3	3.0	3.1	3.9	4.2	4.0	4.8	3.4	3.0	2.8	2.9	3.1	3.5	3.1	2.4	1.0	4.8	3.0	24	
18	2.6	1.7	1.3	2.2	3.0	2.9	3.6	3.6	3.0	3.6	4.1	6.1	8.3	8.8	8.6	8.0	6.5	2.9	-0.3	0.6	1.3	-2.0	-0.9	0.6	-2.0	8.8	3.3	24	
19	-0.7	-1.9	-2.5	-3.3	-4.0	-4.5	-5.3	-5.6	-5.9	-6.6	-5.6	-5.0	-3.0	-1.1	-3.8	-3.9	-4.3	-1.4	0.2	-1.8	-2.2	-1.9	-1.4	-6.6	0.2	-3.4	24		
20	-1.8	-1.9	-2.6	-2.5	-2.3	-2.8	-2.4	-2.8	-2.9	-3.4	-1.3	1.3	2.6	3.4	4.4	3.3	1.3	-2.6	-4.1	-4.5	-5.6	-6.4	-7.4	-8.3	4.4	-2.1	24		
21	-8.8	-9.7	-10.5	-10.9	-11.3	-11.7	-12.3	-12.7	-13.3	-13.4	-13.6	-13.5	-13.6	-13.4	-13.5	-13.6	-14.1	-14.6	-14.7	-14.8	-15.1	-15.1	-15.1	-8.8	-13.1	24			
22	-14.8	-14.6	-14.4	-14.2	-14.1	-14.0	-14.0	-13.7	-13.1	-12.4	-11.3	-10.1	-9.9	-10.0	-10.2	-10.6	-10.9	-11.1	-11.5	-11.7	-11.8	-11.7	-14.8	-9.9	-12.3	24			
23	-11.8	-11.5	-11.7	-11.5	-11.1	-10.8	-11.0	-11.2	-11.4	-11.4	-11.2	-10.5	-9.6	-9.6	-8.9	-9.4	-9.6	-9.8	-9.5	-9.4	-9.3	-9.2	-9.1	-9.0	-11.8	-8.9	-10.3	24	
24	-8.8	-8.7	-8.7	-8.9	-9.1	-9.3	-10.0	-11.0	-11.8	-12.2	-10.8	-8.8	-8.2	-7.1	-6.4	-5.7	-6.4	-8.5	-10.1	-10.4	-10.1	-9.6	-9.1	-12.2	-5.7	-9.2	24		
25	-9.1	-8.8	-8.9	-9.8	-9.1	-9.8	-10.0	-10.4	-10.2	-9.8	-8.1	-5.9	-4.5	-3.3	-2.3	-2.0	-2.7	-3.4	-4.1	-4.1	-3.7	-3.4	-3.6	-3.8	-10.4	-2.0	-6.3	24	
26	-3.5	-3.4	-3.2	-2.8	-3.7	-3.1	-3.3	-3.4	-3.6	-3.1	-2.4	-1.3	0.0	0.5	1.4	1.6	0.4	-1.1	0.6	0.5	1.5	2.2	2.0	1.7	-3.7	2.2	-1.1	24	
27	1.5	0.3	-0.4	-0.4	-0.4	-0.4	0.6	0.4	0.1	1.6	2.3	3.1	3.5	3.8	4.0	3.8	3.5	3.4	3.3	3.0	2.9	2.6	2.8	-0.4	4.0	1.9	24		
28	0.8	0.0	2.0	1.8	1.3	2.0	3.2	3.7	4.2	4.5	4.8	5.1	6.2	7.0	7.0	6.8	6.2	5.0	5.5	4.8	3.8	3.9	3.8	3.5	0.0	7.0	4.0	24	
29	3.0	2.4	2.1	1.3	2.1	2.2	2.4	2.1	2.3	2.9	3.3	3.3	3.2	3.3	3.0	2.7	2.3	1.7	1.3	1.0	1.0	0.8	0.8	3.3	2.3	24			
30	0.5	0.2	0.4	0.4	0.0	-0.1	-0.5	-1.3	-1.9	-2.4	-1.8	-1.8	-1.4	-1.5	-2.0	-2.9	-3.5	-4.4	-5.2	-5.9	-6.6	-7.0	-7.9	-8.9	-8.9	0.5	-2.7	24	
31	-9.1	-9.9	-10.0	-9.7	-9.6	-9.9	-10.3	-10.8	-11.0	-10.9	-10.1	-9.3	-9.3	-8.5	-7.9	-7.5	-7.9	-8.7	-8.8	-8.5	-8.6	-8.9	-10.5	-13.0	-7.5	-9.5	24		
HOURLY MAX		3.0	2.4	3.1	3.3	3.0	2.9	3.6	3.7	4.4	4.5	4.8	6.1	8.3	8.8	8.6	8.0	6.5	6.0	5.5	5.3	4.9	4.4	3.8	3.5				
HOURLY AVG		-9.5	-9.5	-9.3	-9.4	-9.6	-9.5	-9.6	-9.4	-9.5	-8.7	-7.7	-6.8	-6.4	-6.3	-6.5	-7.2	-8.3	-8.7	-8.9	-8.9	-9.1	-9.3	-9.5					

## 24 HR AVERAGES January 2017



## MINIMUM 1-HR AVERAGE:

-31.7 °C @ HOUR(S)

5

ON DAY(S)

8

MAXIMUM 1-HR AVERAGE:

8.8 °C @ HOUR(S)

13

ON DAY(S)

18


MAXIMUM 24-HR AVERAGE:

4.0 °C

VAR-VARIOUS

VAR-VARIOUS
&lt;/

AMBIENT TEMPERATURE Hourly Averages (AmbTPX °C)



## ***STATION TEMPERATURE***


## STATION TEMPERATURE Hourly Averages (StnTPX °C)

	HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
	HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59					
DAY																														
1	21.7	21.4	21.3	21.3	21.2	21.5	21.1	21.3	21.5	21.2	21.2	21.2	21.3	21.0	20.9	21.2	21.4	21.5	21.7	21.6	21.8	21.9	21.9	20.9	21.9	21.4	24			
2	22.1	21.8	21.7	21.7	21.8	21.9	22.2	22.2	22.1	22.1	21.8	21.6	21.4	21.3	21.5	21.7	22.2	22.4	22.5	22.4	22.3	22.3	22.1	21.3	22.5	22.0	24			
3	22.0	22.2	22.2	22.3	22.3	22.1	22.1	22.1	21.8	21.7	21.5	21.1	20.8	21.0	20.9	21.0	20.7	20.5	21.0	21.2	21.4	20.9	21.4	20.5	22.3	21.5	24			
4	21.1	21.3	21.4	20.7	20.9	21.5	21.5	21.3	21.5	21.6	20.4	21.4	22.0	22.0	21.9	21.4	22.2	20.9	21.1	20.8	20.8	21.0	21.1	20.4	22.2	21.3	24			
5	21.3	21.4	21.4	21.3	21.3	21.2	20.9	21.1	21.1	P	P	P	R	22.8	21.0	20.9	21.3	21.2	21.4	21.7	21.9	21.7	21.7	20.9	22.8	21.4	20			
6	21.8	21.8	21.9	21.9	21.8	21.9	21.7	21.9	22.0	22.0	21.9	21.6	21.6	21.5	21.5	21.3	21.5	21.4	21.6	21.6	21.7	21.5	21.3	22.0	21.7	24				
7	21.3	21.6	21.7	21.5	21.5	21.8	21.9	21.6	21.6	21.4	21.7	21.6	21.6	20.6	20.6	22.2	22.0	22.9	22.8	22.6	20.7	21.8	21.2	21.4	21.6	20.6	22.9	21.7	24	
8	21.9	22.0	22.0	22.0	22.1	22.3	22.3	22.1	21.9	21.8	21.4	21.0	21.1	20.9	21.2	21.3	21.3	21.5	21.4	21.6	21.8	20.9	22.3	21.6	24					
9	21.6	21.4	21.4	21.6	21.5	21.1	21.5	21.2	21.3	21.4	21.3	21.2	21.0	21.3	21.2	21.7	22.0	22.2	21.9	21.8	22.0	21.0	22.2	21.5	24					
10	22.2	22.0	21.4	21.1	20.9	20.8	21.1	21.2	21.4	22.0	22.0	21.8	21.6	21.2	21.3	21.4	21.7	21.9	21.7	21.6	21.7	21.1	20.8	22.2	21.5	24				
11	21.2	20.9	20.7	20.8	20.6	20.7	20.8	20.5	20.4	20.0	19.9	19.8	19.6	19.9	20.3	20.8	21.3	21.5	21.8	21.9	22.1	22.2	19.6	22.2	20.8	24				
12	22.5	22.3	22.2	22.5	22.3	22.6	22.4	22.4	22.5	22.8	22.8	21.7	20.7	20.8	20.7	21.1	20.8	21.2	21.2	21.3	21.2	21.3	20.7	22.8	21.7	24				
13	21.4	21.4	21.8	21.7	21.8	21.7	21.1	21.5	21.4	21.7	21.1	20.9	20.4	19.9	20.1	20.0	20.2	20.4	20.6	20.7	20.8	20.1	20.4	19.9	21.8	20.9	24			
14	20.4	21.2	21.5	22.2	22.1	22.1	22.3	22.2	22.2	22.1	22.4	22.3	22.4	22.4	22.5	22.3	22.5	22.4	22.6	22.3	22.3	22.3	20.4	22.6	22.2	24				
15	22.1	22.3	22.4	22.5	22.4	22.3	22.4	22.4	22.5	22.2	22.3	22.4	21.9	22.2	22.0	22.3	22.2	22.4	22.5	22.2	22.4	22.5	22.2	21.9	22.5	22.3	24			
16	22.4	22.4	22.2	22.4	22.2	22.3	22.0	21.5	21.5	21.6	21.7	21.6	21.6	21.6	21.9	21.9	21.6	21.6	21.6	21.8	21.8	21.4	21.4	22.4	21.8	24				
17	21.4	21.4	21.5	21.3	21.0	21.4	20.6	21.1	21.1	21.2	21.7	21.4	21.5	21.5	21.3	21.3	21.2	21.2	21.0	21.1	21.5	20.9	20.6	21.7	21.2	24				
18	20.5	20.3	20.0	20.0	20.3	20.5	20.8	21.0	20.9	21.3	20.7	21.8	21.2	21.0	21.4	21.6	21.2	20.6	19.9	19.7	19.1	18.6	19.1	18.6	21.8	20.5	24			
19	19.2	19.2	18.8	18.9	19.1	19.0	19.1	19.2	19.2	19.2	19.3	19.4	19.2	19.0	19.0	18.8	19.0	19.0	18.9	18.8	18.6	18.8	18.8	18.9	18.6	19.4	19.0	24		
20	19.0	19.2	19.1	19.1	19.2	19.4	19.2	19.1	19.3	20.1	20.9	22.6	21.5	21.0	21.8	22.1	22.2	22.2	22.3	21.6	21.4	20.8	20.1	19.0	22.6	20.6	24			
21	20.3	20.3	20.3	20.2	20.2	20.0	20.2	20.2	20.2	20.3	20.2	20.0	20.1	20.2	19.9	20.2	20.2	20.2	20.4	20.3	20.2	20.3	19.9	20.4	20.2	24				
22	20.3	20.1	20.1	20.3	20.2	20.1	20.3	20.1	20.2	20.2	20.0	20.0	20.0	19.9	20.0	20.1	20.0	20.2	20.1	20.2	20.0	20.2	19.9	20.3	20.1	24				
23	20.2	20.2	20.1	20.1	20.2	20.1	20.1	20.2	20.1	20.0	20.1	20.0	19.8	19.6	19.4	19.6	19.7	20.0	20.0	20.0	20.1	20.0	20.0	19.4	20.2	20.0	24			
24	20.1	20.0	20.1	20.2	20.2	20.1	20.2	20.1	20.2	20.3	20.1	19.4	19.0	19.2	19.5	20.0	20.1	20.3	20.3	20.1	20.4	20.3	20.3	19.0	20.4	20.0	24			
25	20.2	20.3	20.2	20.2	20.2	20.2	20.2	20.1	20.3	19.8	19.8	19.9	20.7	21.5	21.7	21.8	21.6	21.4	21.4	21.3	21.0	21.0	20.7	19.8	21.8	20.7	24			
26	20.7	20.8	20.9	21.1	21.2	21.1	20.9	20.6	20.4	20.8	21.4	21.4	21.6	21.8	22.1	21.9	22.2	22.2	22.2	22.1	22.2	22.2	20.4	22.2	21.5	24				
27	22.3	22.2	22.1	22.3	22.1	22.2	22.1	21.9	22.0	21.9	22.0	21.8	21.9	22.0	22.1	22.0	22.2	22.2	22.4	22.2	22.2	22.2	21.8	22.4	22.1	24				
28	22.4	22.4	22.3	22.2	22.2	22.1	22.1	21.9	22.0	21.8	22.0	21.8	21.6	21.5	21.6	21.6	21.6	22.1	22.2	22.3	22.1	22.2	21.5	22.4	22.0	24				
29	22.0	22.2	22.3	22.3	22.2	22.1	22.2	22.0	22.1	21.9	21.9	22.0	22.0	21.9	21.9	22.1	22.3	22.4	22.4	22.2	22.4	22.2	21.9	22.4	22.2	24				
30	22.3	22.4	22.5	22.2	22.4	22.2	22.3	22.2	22.3	22.1	22.0	21.9	21.7	21.8	22.0	22.0	21.7	21.6	21.0	20.5	20.1	20.1	20.1	22.5	21.7	24				
31	20.3	20.5	20.3	20.4	20.3	20.2	20.4	20.2	20.3	20.2	19.9	19.9	19.8	19.8	19.7	19.9	20.2	20.1	20.3	20.3	20.4	20.4	19.7	20.5	20.2	24				
HOURLY MAX		22.5	22.4	22.5	22.5	22.4	22.6	22.4	22.5	22.8	22.6	22.4	22.4	22.8	22.3	22.9	22.8	22.6	22.6	22.4	22.4	22.5	22.4							
HOURLY AVG		21.2	21.3	21.2	21.2	21.2	21.3	21.2	21.2	21.3	21.2	21.0	20.9	21.1	21.1	21.2	21.3	21.3	21.2	21.2	21.2	21.2	21.2	20.5	20.2	24				

## STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

## 24 HR AVERAGES January 2017




## MONTHLY SUMMARY

MINIMUM 1-HR AVERAGE:	18.6	°C	@ HOUR(S)	22 , 20	ON DAY(S)	18 , 19

<tbl\_r cells="7" ix="1" maxcspan="1" maxrspan="1" usedcols="7

STATION TEMPERATURE Hourly Averages (StnTPX °C)



***APPENDIX II***  
***EQUIPMENT CALIBRATION RESULTS***


***SULPHUR DIOXIDE***



## API 100A Sulphur Dioxide Analyzer Calibration

Date:	January 4, 2017	Barometric Pressure:	28.07 inHg
Company/Airshed:	PRAMP	Station Temperature °C:	22
Location/Station Name:	842b	Weather Conditions:	Mainly cloudy with light snow
Parameter:	Sulphur Dioxide	Calibration Purpose:	routine monthly
Start Time 24 hr. (mst):	14:02	Performed By/Reviewer:	Raja Abid Trina Whitsitt
End Time 24 hr. (mst):	17:16	Cal Gas Expiry Date:	May 23, 2019
Calibration Method:	Gas Dilution	Converter Model & s/n (if applicable):	n/a
<b>Analyzer:</b> ID# or Serial Number: 838 Range ppb: 500 Last Calibration Date: December 20, 2016 As Found C.F.: 1.006 Previous C.F.: 1.000 New C.F.: 1.000			
<b>Calibrator:</b> Flow Meter ID's: n/a Standard Calibration Points for Ranges Make & Model: Environics 6100 Serial #: 5212 Cal Gas Cylinder I.D. #: LL 119513 Cal Gas Conc. (ppm): 50.6			


ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015						
Calibrator Flow Rates (cc/min)		Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):		
Point	Diluent	Cal Gas	Total	(ppb)	(ppb)	Correction Factors (C.F.):
as found zero	5995	0.00	5995	0.0	0.0	n/a
as found high	5950	45.04	5995	380.2	378.0	1.006
adjusted zero	5995	0.00	5995	0.0	0.0	n/a
adjusted high	5950	45.04	5995	380.2	380.0	1.000
mid	5976	21.32	5997	179.9	180.0	0.999
low	5986	10.65	5997	89.9	90.0	0.999
calibrator zero	5995	0.00	5995	0.0	0.0	n/a
Average C.F.=						0.999



As found:	As left:
SLOPE: 1.028	SLOPE: 1.032
OFFSET: 19.1	OFFSET: 19.1
HVPs: 686	HVPs: 686
DCPS: 2545	DCPS: 2540
RCELL TEMP: 51.1	RCELL TEMP: 49.6
BOX TEMP: 31.2	BOX TEMP: 31.2
PMT TEMP: 7.2	PMT TEMP: 7.2
I2S TEMP: 60.2	I2S TEMP: 60.0
Converter Temp: n/a	Converter Temp: n/a
PRES: 26.8	PRES: 26.3
SAMP FL: 650	SAMP FL: 635
PMT: 58.1	PMT: 57.7
UV LAMP: 2398	UV LAMP: 2362
LAMP RATIO: 96.6	LAMP RATIO: 95.6
STR. LGT: 9.8	STR. LGT: 9.8
DRK PMT: 34.1	DRK PMT: 34.4
DRK LMP: -6.9	DRK LMP: -6.9
Expected Value: 235.2	Expected Value: 229.1

**Comments:**  
 The analyzer sample inlet filter was changed.  
 No zero adjustment was required/made. As found zero value copied to adjusted zero value for linearity calculation purposes.

SO2[ppb] Station: THREE CREEKS #842 TRAILER Daily: 2017/01/04 Type: AVG 1 Min. [1 Min.]



## ***TOTAL REDUCED SULPHUR***



## Thermo 43i Total Reduced Sulphur Analyzer Calibration


<b>Date:</b> January 4, 2017 <b>Company/Airshed:</b> PRAMP <b>Location/Station Name:</b> 842b <b>Parameter:</b> Total Reduced Sulphur <b>Start Time 24 hr. (mst):</b> 10:04 <b>End Time 24 hr. (mst):</b> 12:27 <b>Calibration Method:</b> Gas Dilution		<b>Barometric Pressure:</b> 28.04 inHg <b>Station Temperature °C:</b> 22 <b>Weather Conditions:</b> Mainly cloudy with light snow <b>Calibration Purpose:</b> shut down <b>Performed By/Reviewer:</b> Raja Abid, Trina Whitsitt <input type="checkbox"/> Skip <b>Cal Gas Expiry Date:</b> December 1, 2018 <b>Converter Model &amp; s/n (if applicable):</b> WATLOW 05572																																																																									
<b>Analyzer:</b> <b>ID# or Serial Number:</b> 122654720 <b>Last Calibration Date:</b> December 8, 2016 <b>Previous C.F.:</b> 1.001		<b>Range ppb:</b> 100 <b>As Found C.F.:</b> 1.021 <b>New C.F.:</b> n/a																																																																									
<b>Calibrator:</b> <b>Flow Meter ID's:</b> n/a <b>Make &amp; Model:</b> API 700 <b>Serial #:</b> 830 <b>Cal Gas Cylinder I.D. #:</b> BLM 002197 <b>Cal Gas Conc. (ppm):</b> 10.3		<b>Standard Calibration Points for Ranges</b> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Point</th> <th>ppb</th> </tr> </thead> <tbody> <tr> <td>High</td> <td>78</td> </tr> <tr> <td>Mid</td> <td>38</td> </tr> <tr> <td>Low</td> <td>19</td> </tr> </tbody> </table> <b>SO<sub>2</sub> Scrubber Check (10 mins.)</b> <b>Start/End Time 24 hr.:</b> 10:30:00-10:40 <b>Target Concentration (ppb):</b> 380 <b>Result (ppb):</b> 0 <b>Zero Corrected Result (ppb):</b> 0		Point	ppb	High	78	Mid	38	Low	19																																																																
Point	ppb																																																																										
High	78																																																																										
Mid	38																																																																										
Low	19																																																																										
<b>ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3">Calibrator Flow Rates (cc/min)</th> <th>Calculated Concentration:</th> <th>Indicated Concentration:</th> <th>Correction Factors (C.F.):</th> </tr> <tr> <th>Point</th> <th>Diluent</th> <th>Cal Gas</th> <th>Total</th> <th>(ppb)</th> <th>(ppb)</th> </tr> </thead> <tbody> <tr> <td>as found zero</td> <td>7497</td> <td>0.00</td> <td>7497</td> <td>0.0</td> <td>-0.2</td> </tr> <tr> <td>as found high</td> <td>7440</td> <td>56.80</td> <td>7497</td> <td>78.0</td> <td>76.2</td> </tr> <tr> <td>mid</td> <td>7471</td> <td>27.70</td> <td>7499</td> <td>38.0</td> <td>36.8</td> </tr> <tr> <td>low</td> <td>7482</td> <td>13.80</td> <td>7496</td> <td>19.0</td> <td>18.3</td> </tr> <tr> <td colspan="5"></td> <td>Average C.F. = 1.025</td> </tr> </tbody> </table>				Calibrator Flow Rates (cc/min)			Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):	Point	Diluent	Cal Gas	Total	(ppb)	(ppb)	as found zero	7497	0.00	7497	0.0	-0.2	as found high	7440	56.80	7497	78.0	76.2	mid	7471	27.70	7499	38.0	36.8	low	7482	13.80	7496	19.0	18.3						Average C.F. = 1.025																														
Calibrator Flow Rates (cc/min)			Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):																																																																						
Point	Diluent	Cal Gas	Total	(ppb)	(ppb)																																																																						
as found zero	7497	0.00	7497	0.0	-0.2																																																																						
as found high	7440	56.80	7497	78.0	76.2																																																																						
mid	7471	27.70	7499	38.0	36.8																																																																						
low	7482	13.80	7496	19.0	18.3																																																																						
					Average C.F. = 1.025																																																																						
<b>Linear Regression/Calibration Results:</b> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;"> <b>Correlation Coefficient =</b> 1.000  <b>Slope =</b> 1.021  <b>b (Intercept as % of full scale)=</b> 0.28%  <b>% change in C.F. from last cal=</b> -2.04%         </td> <td style="width: 50%; text-align: right;"> <b>LIMITS</b>  &gt; or = 0.995  0.90-1.10  ± 3% F.S.  ± 10%         </td> </tr> </table>				<b>Correlation Coefficient =</b> 1.000 <b>Slope =</b> 1.021 <b>b (Intercept as % of full scale)=</b> 0.28% <b>% change in C.F. from last cal=</b> -2.04%	<b>LIMITS</b> > or = 0.995 0.90-1.10 ± 3% F.S. ± 10%																																																																						
<b>Correlation Coefficient =</b> 1.000 <b>Slope =</b> 1.021 <b>b (Intercept as % of full scale)=</b> 0.28% <b>% change in C.F. from last cal=</b> -2.04%	<b>LIMITS</b> > or = 0.995 0.90-1.10 ± 3% F.S. ± 10%																																																																										
<b>Thermo 43i Total Reduced Sulphur Analyzer Calibration</b> <div style="border: 1px solid black; padding: 10px; width: 100%;"> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <thead> <tr> <th colspan="2">As found:</th> <th colspan="2">As left:</th> </tr> </thead> <tbody> <tr> <td>BKG:</td> <td>11.9</td> <td>BKG:</td> <td>n/a</td> </tr> <tr> <td>COEF:</td> <td>0.970</td> <td>COEF:</td> <td>n/a</td> </tr> <tr> <td>PMT:</td> <td>-649.7</td> <td>PMT:</td> <td>n/a</td> </tr> <tr> <td>FLASH:</td> <td>921</td> <td>FLASH:</td> <td>n/a</td> </tr> <tr> <td>INTERNAL:</td> <td>32.6</td> <td>INTERNAL:</td> <td>n/a</td> </tr> <tr> <td>CHAMBER:</td> <td>45.0</td> <td>CHAMBER:</td> <td>n/a</td> </tr> <tr> <td>PERM OVEN GAS:</td> <td>45.00</td> <td>PERM OVEN GAS:</td> <td>n/a</td> </tr> <tr> <td>PERM OVEN HEATER:</td> <td>44.33</td> <td>PERM OVEN HEATER:</td> <td>n/a</td> </tr> <tr> <td>PRESSURE:</td> <td>636.9</td> <td>PRESSURE:</td> <td>n/a</td> </tr> <tr> <td>SAMPLE FLOW:</td> <td>0.381</td> <td>SAMPLE FLOW:</td> <td>n/a</td> </tr> <tr> <td>LAMP INTENSITY:</td> <td>91</td> <td>LAMP INTENSITY:</td> <td>n/a</td> </tr> <tr> <td>CONVERTER:</td> <td>851</td> <td>CONVERTER:</td> <td>n/a</td> </tr> <tr> <td>CONVERTER SET:</td> <td>850</td> <td>CONVERTER SET:</td> <td>n/a</td> </tr> <tr> <td>0</td> <td>n/a</td> <td>0</td> <td>n/a</td> </tr> <tr> <td>0</td> <td>n/a</td> <td>0</td> <td>n/a</td> </tr> <tr> <td>0</td> <td>n/a</td> <td>0</td> <td>n/a</td> </tr> <tr> <td>Expected Value:</td> <td>n/a</td> <td>Expected Value:</td> <td>n/a</td> </tr> </tbody> </table> </div>				As found:		As left:		BKG:	11.9	BKG:	n/a	COEF:	0.970	COEF:	n/a	PMT:	-649.7	PMT:	n/a	FLASH:	921	FLASH:	n/a	INTERNAL:	32.6	INTERNAL:	n/a	CHAMBER:	45.0	CHAMBER:	n/a	PERM OVEN GAS:	45.00	PERM OVEN GAS:	n/a	PERM OVEN HEATER:	44.33	PERM OVEN HEATER:	n/a	PRESSURE:	636.9	PRESSURE:	n/a	SAMPLE FLOW:	0.381	SAMPLE FLOW:	n/a	LAMP INTENSITY:	91	LAMP INTENSITY:	n/a	CONVERTER:	851	CONVERTER:	n/a	CONVERTER SET:	850	CONVERTER SET:	n/a	0	n/a	Expected Value:	n/a	Expected Value:	n/a										
As found:		As left:																																																																									
BKG:	11.9	BKG:	n/a																																																																								
COEF:	0.970	COEF:	n/a																																																																								
PMT:	-649.7	PMT:	n/a																																																																								
FLASH:	921	FLASH:	n/a																																																																								
INTERNAL:	32.6	INTERNAL:	n/a																																																																								
CHAMBER:	45.0	CHAMBER:	n/a																																																																								
PERM OVEN GAS:	45.00	PERM OVEN GAS:	n/a																																																																								
PERM OVEN HEATER:	44.33	PERM OVEN HEATER:	n/a																																																																								
PRESSURE:	636.9	PRESSURE:	n/a																																																																								
SAMPLE FLOW:	0.381	SAMPLE FLOW:	n/a																																																																								
LAMP INTENSITY:	91	LAMP INTENSITY:	n/a																																																																								
CONVERTER:	851	CONVERTER:	n/a																																																																								
CONVERTER SET:	850	CONVERTER SET:	n/a																																																																								
0	n/a	0	n/a																																																																								
0	n/a	0	n/a																																																																								
0	n/a	0	n/a																																																																								
Expected Value:	n/a	Expected Value:	n/a																																																																								
<b>Comments:</b> The analyzer sample inlet filter was changed. The analyzer cooling fan filter(s) were cleaned.																																																																											
<small>Shutdown calibration performed to readjust the thermocouple wire of the converter. Low point interrupted by daily z/s check, restarted at 12:06.</small>																																																																											



## Thermo 43i Total Reduced Sulphur Analyzer Calibration

Date: January 4, 2017		Barometric Pressure: 28.07 inHg																																																	
Company/Airshed: PRAMP		Station Temperature °C: 22																																																	
Location/Station Name: 842		Weather Conditions: Mainly cloudy with light snow																																																	
Parameter: Total Reduced Sulphur		Calibration Purpose: post repair																																																	
Start Time 24 hr. (mst): 15:38		Performed By/Reviewer: Raja Abid Trina Whitsitt																																																	
End Time 24 hr. (mst): 18:52		Cal Gas Expiry Date: December 1, 2018																																																	
Calibration Method: Gas Dilution		Converter Model & s/n (if applicable): WATLOW 05572																																																	
<b>Analyzer:</b> ID# or Serial Number: 122654720 Last Calibration Date: December 8, 2016 Previous C.F.: 1.001																																																			
<b>Calibrator:</b> Flow Meter ID's: n/a Make & Model: API 700 Serial #: 830 Cal Gas Cylinder I.D. #: BLM 002197 Cal Gas Conc. (ppm): 10.3																																																			
<b>Standard Calibration Points for Ranges</b> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Point</th> <th style="text-align: center;">ppb</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">High</td> <td style="text-align: center;">78</td> </tr> <tr> <td style="text-align: center;">Mid</td> <td style="text-align: center;">38</td> </tr> <tr> <td style="text-align: center;">Low</td> <td style="text-align: center;">19</td> </tr> </tbody> </table>				Point	ppb	High	78	Mid	38	Low	19																																								
Point	ppb																																																		
High	78																																																		
Mid	38																																																		
Low	19																																																		
<b>ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3" style="text-align: left;">Calibrator Flow Rates (cc/min)</th> <th style="text-align: center;">Calculated Concentration:</th> <th style="text-align: center;">Indicated Concentration:</th> <th style="text-align: center;">Correction Factors (C.F.):</th> </tr> <tr> <th style="text-align: center;">Point</th> <th style="text-align: center;">Diluent</th> <th style="text-align: center;">Cal Gas</th> <th style="text-align: center;">Total</th> <th style="text-align: center;">(ppb)</th> <th style="text-align: center;">(ppb)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">adjusted zero</td> <td style="text-align: center;">7495</td> <td style="text-align: center;">0.00</td> <td style="text-align: center;">7495</td> <td style="text-align: center;">0.0</td> <td style="text-align: center;">0.0</td> </tr> <tr> <td style="text-align: center;">adjusted high</td> <td style="text-align: center;">7440</td> <td style="text-align: center;">56.80</td> <td style="text-align: center;">7497</td> <td style="text-align: center;">78.0</td> <td style="text-align: center;">78.0</td> </tr> <tr> <td style="text-align: center;">mid</td> <td style="text-align: center;">7473</td> <td style="text-align: center;">27.60</td> <td style="text-align: center;">7501</td> <td style="text-align: center;">37.9</td> <td style="text-align: center;">37.4</td> </tr> <tr> <td style="text-align: center;">low</td> <td style="text-align: center;">7480</td> <td style="text-align: center;">13.80</td> <td style="text-align: center;">7494</td> <td style="text-align: center;">19.0</td> <td style="text-align: center;">18.6</td> </tr> <tr> <td style="text-align: center;">calibrator zero</td> <td style="text-align: center;">7495</td> <td style="text-align: center;">0.00</td> <td style="text-align: center;">7495</td> <td style="text-align: center;">0.0</td> <td style="text-align: center;">n/a</td> </tr> <tr> <td colspan="4"></td> <td style="text-align: center;">Average C.F.=</td> <td style="text-align: center;">1.011</td> </tr> </tbody> </table>				Calibrator Flow Rates (cc/min)			Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):	Point	Diluent	Cal Gas	Total	(ppb)	(ppb)	adjusted zero	7495	0.00	7495	0.0	0.0	adjusted high	7440	56.80	7497	78.0	78.0	mid	7473	27.60	7501	37.9	37.4	low	7480	13.80	7494	19.0	18.6	calibrator zero	7495	0.00	7495	0.0	n/a					Average C.F.=	1.011
Calibrator Flow Rates (cc/min)			Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):																																														
Point	Diluent	Cal Gas	Total	(ppb)	(ppb)																																														
adjusted zero	7495	0.00	7495	0.0	0.0																																														
adjusted high	7440	56.80	7497	78.0	78.0																																														
mid	7473	27.60	7501	37.9	37.4																																														
low	7480	13.80	7494	19.0	18.6																																														
calibrator zero	7495	0.00	7495	0.0	n/a																																														
				Average C.F.=	1.011																																														
<b>Linear Regression/Calibration Results:</b> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Correlation Coefficient =</td> <td style="text-align: center;">1.000</td> <td style="width: 50%; text-align: right;">LIMITS</td> </tr> <tr> <td>Slope =</td> <td style="text-align: center;">0.999</td> <td style="text-align: right;">.95-1.05</td> </tr> <tr> <td>b (Intercept as % of full scale)=</td> <td style="text-align: center;">0.24%</td> <td style="text-align: right;">± 3% F.S.</td> </tr> <tr> <td>% change in C.F. from last cal=</td> <td style="text-align: center;">n/a</td> <td style="text-align: right;">± 10%</td> </tr> </table>				Correlation Coefficient =	1.000	LIMITS	Slope =	0.999	.95-1.05	b (Intercept as % of full scale)=	0.24%	± 3% F.S.	% change in C.F. from last cal=	n/a	± 10%																																				
Correlation Coefficient =	1.000	LIMITS																																																	
Slope =	0.999	.95-1.05																																																	
b (Intercept as % of full scale)=	0.24%	± 3% F.S.																																																	
% change in C.F. from last cal=	n/a	± 10%																																																	
<b>Thermo 43i Total Reduced Sulphur Analyzer Calibration</b>																																																			
<b>As found:</b> BKG: 11.9 COEF: 0.970 PMT: -649.7 FLASH: 921 INTERNAL: 34.0 CHAMBER: 44.9 PERM OVEN GAS: 45.00 PERM OVEN HEATER: 44.34 PRESSURE: 636.0 SAMPLE FLOW: 0.381 LAMP INTENSITY: 91 CONVERTER: 845 CONVERTER SET: 845 Expected Value: 58.1		<b>As left:</b> BKG: 12.0 COEF: 0.947 PMT: -649.4 FLASH: 921 INTERNAL: 33.2 CHAMBER: 45.3 PERM OVEN GAS: 44.99 PERM OVEN HEATER: 44.33 PRESSURE: 635.7 SAMPLE FLOW: 0.381 LAMP INTENSITY: 90 CONVERTER: 850 CONVERTER SET: 850 Expected Value: 59.0																																																	
<b>Comments:</b>																																																			

TRS[ppb] Station: THREE CREEKS #842 TRAILER Daily: 2017/01/04 Type: AVG 1 Min. [1 Min.]



TRS[ppb]



## Thermo 43i Total Reduced Sulphur Analyzer Calibration

Date: <u>January 7, 2017</u>	Barometric Pressure: <u>28.2 inHg</u>
Company/Airshed: <u>PRAMP</u>	Station Temperature °C: <u>22</u>
Location/Station Name: <u>842</u>	Weather Conditions: <u>Cloudy &amp; overcast</u>
Parameter: <u>Total Reduced Sulphur</u>	Calibration Purpose: <u>post repair</u>
Start Time 24 hr. (mst): <u>17:27</u>	Performed By/Reviewer: <u>Russell Kirchner</u> <u>Trina Whitsitt</u>
End Time 24 hr. (mst): <u>20:20</u>	Cal Gas Expiry Date: <u>December 1, 2018</u>
Calibration Method: <u>Gas Dilution</u>	Converter Model & s/n (if applicable): <u>CDN-101 s/n 552</u>

<b>Analyzer:</b>			
ID# or Serial Number: <u>1226154720</u>	Range ppb: <u>100</u>		
Last Calibration Date: <u>January 4, 2017</u>	As Found C.F.: <u>n/a</u>		
Previous C.F.: <u>1.000</u>	New C.F.: <u>1.000</u>		


<b>Calibrator:</b>	<b>Standard Calibration Points for Ranges</b>		
Flow Meter ID's: <u>n/a</u>	Point: <u>High</u>	ppb: <u>78</u>	
Make & Model: <u>API 700</u>	Point: <u>Mid</u>	ppb: <u>38</u>	
Serial #: <u>831</u>	Point: <u>Low</u>	ppb: <u>19</u>	
Cal Gas Cylinder I.D. #: <u>BLM001927</u>			
Cal Gas Conc. (ppm): <u>10.3</u>			

<b>ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015</b>								
Calibrator Flow Rates (cc/min)				Calculated Concentration:		Indicated Concentration:		Correction Factors (C.F.):
Point	Diluent	Cal Gas	Total	(ppb)	(ppb)			
adjusted zero	7496	0.00	7496	0.0	0.0			n/a
adjusted high	7442	56.80	7499	78.0	78.0			1.000
mid	7469	27.70	7497	38.1	37.5			1.015
low	7484	13.80	7498	19.0	18.5			1.025
calibrator zero	7496	0.00	7496	0.0	-0.4			n/a
Average C.F.=								1.013

### Linear Regression/Calibration Results:


Correlation Coefficient = <u>1.000</u>	LIMITS <u>&gt; or = 0.995</u>
Slope = <u>0.999</u>	.95-1.05
b (Intercept as % of full scale)= <u>0.30%</u>	± 3% F.S.
% change in C.F. from last cal= <u>n/a</u>	± 10%

### Thermo 43i Total Reduced Sulphur Analyzer Calibration



Comments:

TRS[ppb] Station: THREE CREEKS #842 TRAILER Daily: 2017/01/07 Type: AVG 1 Min. [1 Min.]



TRS[ppb]



## Thermo 43i Total Reduced Sulphur Analyzer Calibration

Date:	January 20, 2017	Barometric Pressure:	27.15 inHg
Company/Airshed:	PRAMP	Station Temperature °C:	20
Location/Station Name:	842b	Weather Conditions:	Mainly sunny
Parameter:	Total Reduced Sulphur	Calibration Purpose:	repeat
Start Time 24 hr. (mst):	10:05	Performed By/Reviewer:	Raja Abid Trina Whitsitt
End Time 24 hr. (mst):	13:14	Cal Gas Expiry Date:	December 1, 2018
Calibration Method:	Gas Dilution	Converter Model & s/n (if applicable):	WATLOW 05572


Analyzer:	
ID# or Serial Number:	122615470
Last Calibration Date:	January 7, 2017
Previous C.F.:	1.000
Range ppb:	100
As Found C.F.:	0.985
New C.F.:	1.000

Calibrator:	Standard Calibration Points for Ranges		
Flow Meter ID's:	n/a	Point	ppb
Make & Model:	Envirotronics 6100	High	78
Serial #:	5212	Mid	38
Cal Gas Cylinder I.D. # :	BLM 002197	Low	19
Cal Gas Conc. (ppm):	10.3		

ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015						
Calibrator Flow Rates (cc/min)			Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):	
Point	Diluent	Cal Gas	Total	(ppb)	(ppb)	
as found zero	7493	0.00	7493	0.0	-1.9	n/a
as found high	7441	56.76	7498	78.0	77.3	0.985
adjusted zero	7493	0.00	7493	0.0	0.0	n/a
adjusted high	7441	56.76	7498	78.0	78.0	1.000
mid	7468	27.64	7496	38.0	37.4	1.016
low	7480	13.80	7494	19.0	18.8	1.009
calibrator zero	7493	0.00	7493	0.0	0.4	n/a
			Average C.F. =		1.008	

### Linear Regression/Calibration Results:

Correlation Coefficient =	1.000	> or = 0.995
Slope =	1.000	.95-1.05
b (Intercept as % of full scale)=	0.19%	± 3% F.S.
% change in C.F. from last cal=	1.55%	± 10%



As found:	As left:
BKG: 14.4	BKG: 12.0
COEF: 0.989	COEF: 0.953
PMT: -650.1	PMT: -649.7
FLASH: 919	FLASH: 919
INTERNAL: 32.2	INTERNAL: 32.3
CHAMBER: 44.9	CHAMBER: 45.0
PERM OVEN GAS: 45.00	PERM OVEN GAS: 44.99
PERM OVEN HEATER: 44.34	PERM OVEN HEATER: 44.32
PRESSURE: 616.0	PRESSURE: 615.7
SAMPLE FLOW: 0.372	SAMPLE FLOW: 0.371
LAMP INTENSITY: 91	LAMP INTENSITY: 91
CONVERTER: 850	CONVERTER: 850
CONVERTER SET: 850	CONVERTER SET: 850
Expected Value: 59.0	Expected Value: 61.7

### Comments:

10:06-10:56 AS found performed.

TRS[ppb] Station: THREE CREEKS #842 TRAILER Daily: 2017/01/20 Type: AVG 1 Min. [1 Min.]




***TOTAL HYDROCARBON***




## Thermo 55i Methane/Non-Methane Analyzer Calibration

remove

Date: January 4, 2017		Barometric Pressure: 28.07 inHg																																																																																																									
Company/Airshed: PRAMP		Station Temperature °C: 22																																																																																																									
Location/Station Name: 842b		Weather Conditions: Mainly cloudy with light snow																																																																																																									
Parameter: CH <sub>4</sub> / NMHC / THC		Calibration Purpose: routine monthly																																																																																																									
Start/End Time 24 hr. (mst): 10:04/14:46		Performed By/Reviewer: Raja Abid   Trina Whitsitt																																																																																																									
Calibration Method: Gas Dilution		Cal Gas Expiry Date: January 9, 2021																																																																																																									
<b>Analyzer:</b> ID# or Serial Number: 1433563261 Measured Flow: 1208 Last Calibration Date: December 8, 2016 Range ppm: 20 CH <sub>4</sub> /20 NMHC/40 THC																																																																																																											
<b>Correction Factors:</b> Previous C.F.: As Found C.F.: New C.F.: CH <sub>4</sub> = 1.000   1.013   1.000 NMHC = 1.000   1.012   1.001 THC = 1.001   1.013   1.001																																																																																																											
<b>Calibrator:</b> Flow Meter ID's: n/a Make & Model: Environics 6100 Serial #: 5212 Cal Gas Cylinder I.D. #: LL 19638 CH <sub>4</sub> Cylinder Conc.= 880.0   304.0 =C <sub>2</sub> H <sub>6</sub> Cylinder Conc. CH <sub>4</sub> as CH <sub>2</sub> = 836.0   1716.0 =total CH <sub>4</sub> equivalent																																																																																																											
<b>Standard Calibration Points for Analyzer Range of 20/20/40 ppm</b> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Point</th> <th>CH<sub>4</sub></th> <th>NMHC</th> <th>THC</th> </tr> </thead> <tbody> <tr> <td>High</td> <td>13.00</td> <td>13.00</td> <td>26.00</td> </tr> <tr> <td>Mid</td> <td>7.00</td> <td>7.00</td> <td>14.00</td> </tr> <tr> <td>Low</td> <td>3.00</td> <td>3.00</td> <td>6.00</td> </tr> </tbody> </table>				Point	CH <sub>4</sub>	NMHC	THC	High	13.00	13.00	26.00	Mid	7.00	7.00	14.00	Low	3.00	3.00	6.00																																																																																								
Point	CH <sub>4</sub>	NMHC	THC																																																																																																								
High	13.00	13.00	26.00																																																																																																								
Mid	7.00	7.00	14.00																																																																																																								
Low	3.00	3.00	6.00																																																																																																								
<b>ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015</b>																																																																																																											
<b>Calibrator Flow Rates (cc/min)</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Point</th> <th>Diluent</th> <th>Cal Gas</th> <th>Total Flow</th> <th>Calculated CH<sub>4</sub> (ppm)</th> <th>Calculated NMHC (ppm)</th> <th>Calculated THC (ppm)</th> <th>Indicated CH<sub>4</sub> (ppm)</th> <th>Indicated NMHC (ppm)</th> <th>Indicated THC (ppm)</th> <th>CH<sub>4</sub></th> <th>NMHC</th> <th>THC</th> </tr> </thead> <tbody> <tr> <td>as found zero</td> <td>2997</td> <td>0.00</td> <td>2997</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>n/a</td> <td>n/a</td> <td>n/a</td> </tr> <tr> <td>as found high</td> <td>2947</td> <td>49.94</td> <td>2997</td> <td>14.66</td> <td>13.93</td> <td>28.59</td> <td>14.47</td> <td>13.76</td> <td>28.24</td> <td>1.013</td> <td>1.012</td> <td>1.013</td> </tr> <tr> <td>adjusted zero</td> <td>2997</td> <td>0.00</td> <td>2997</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>n/a</td> <td>n/a</td> <td>n/a</td> </tr> <tr> <td>adjusted high</td> <td>2947</td> <td>49.94</td> <td>2997</td> <td>14.66</td> <td>13.93</td> <td>28.59</td> <td>14.66</td> <td>13.92</td> <td>28.56</td> <td>1.000</td> <td>1.001</td> <td>1.001</td> </tr> <tr> <td>mid</td> <td>2972</td> <td>24.95</td> <td>2997</td> <td>7.33</td> <td>6.96</td> <td>14.29</td> <td>7.37</td> <td>6.99</td> <td>14.36</td> <td>0.994</td> <td>0.996</td> <td>0.995</td> </tr> <tr> <td>low</td> <td>2986</td> <td>11.97</td> <td>2998</td> <td>3.51</td> <td>3.34</td> <td>6.85</td> <td>3.55</td> <td>3.40</td> <td>6.94</td> <td>0.990</td> <td>0.982</td> <td>0.987</td> </tr> <tr> <td>calibrator zero</td> <td>2997</td> <td>0.00</td> <td>2997</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>n/a</td> <td>n/a</td> <td>n/a</td> </tr> </tbody> </table>				Point	Diluent	Cal Gas	Total Flow	Calculated CH <sub>4</sub> (ppm)	Calculated NMHC (ppm)	Calculated THC (ppm)	Indicated CH <sub>4</sub> (ppm)	Indicated NMHC (ppm)	Indicated THC (ppm)	CH <sub>4</sub>	NMHC	THC	as found zero	2997	0.00	2997	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a	as found high	2947	49.94	2997	14.66	13.93	28.59	14.47	13.76	28.24	1.013	1.012	1.013	adjusted zero	2997	0.00	2997	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a	adjusted high	2947	49.94	2997	14.66	13.93	28.59	14.66	13.92	28.56	1.000	1.001	1.001	mid	2972	24.95	2997	7.33	6.96	14.29	7.37	6.99	14.36	0.994	0.996	0.995	low	2986	11.97	2998	3.51	3.34	6.85	3.55	3.40	6.94	0.990	0.982	0.987	calibrator zero	2997	0.00	2997	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a
Point	Diluent	Cal Gas	Total Flow	Calculated CH <sub>4</sub> (ppm)	Calculated NMHC (ppm)	Calculated THC (ppm)	Indicated CH <sub>4</sub> (ppm)	Indicated NMHC (ppm)	Indicated THC (ppm)	CH <sub>4</sub>	NMHC	THC																																																																																															
as found zero	2997	0.00	2997	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a																																																																																															
as found high	2947	49.94	2997	14.66	13.93	28.59	14.47	13.76	28.24	1.013	1.012	1.013																																																																																															
adjusted zero	2997	0.00	2997	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a																																																																																															
adjusted high	2947	49.94	2997	14.66	13.93	28.59	14.66	13.92	28.56	1.000	1.001	1.001																																																																																															
mid	2972	24.95	2997	7.33	6.96	14.29	7.37	6.99	14.36	0.994	0.996	0.995																																																																																															
low	2986	11.97	2998	3.51	3.34	6.85	3.55	3.40	6.94	0.990	0.982	0.987																																																																																															
calibrator zero	2997	0.00	2997	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a																																																																																															
Average C.F.= 0.995   0.993   0.994																																																																																																											
<b>Linear Regression/Calibration Results:</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>CH<sub>4</sub></th> <th>NMHC</th> <th>THC</th> <th>LIMITS</th> </tr> </thead> <tbody> <tr> <td>Correlation Coeffecient = 1.000</td> <td>1.000</td> <td>1.000</td> <td>&gt; or = 0.995</td> </tr> <tr> <td>Slope = 0.999</td> <td>0.998</td> <td>0.998</td> <td>.95-1.05</td> </tr> <tr> <td>b (Intercept as % of full scale)= 0.12%</td> <td>0.17%</td> <td>0.14%</td> <td>± 3% F.S.</td> </tr> <tr> <td>% change in C.F. from last cal= -1.34%</td> <td>-1.24%</td> <td>-1.16%</td> <td>± 10%</td> </tr> </tbody> </table>				CH <sub>4</sub>	NMHC	THC	LIMITS	Correlation Coeffecient = 1.000	1.000	1.000	> or = 0.995	Slope = 0.999	0.998	0.998	.95-1.05	b (Intercept as % of full scale)= 0.12%	0.17%	0.14%	± 3% F.S.	% change in C.F. from last cal= -1.34%	-1.24%	-1.16%	± 10%																																																																																				
CH <sub>4</sub>	NMHC	THC	LIMITS																																																																																																								
Correlation Coeffecient = 1.000	1.000	1.000	> or = 0.995																																																																																																								
Slope = 0.999	0.998	0.998	.95-1.05																																																																																																								
b (Intercept as % of full scale)= 0.12%	0.17%	0.14%	± 3% F.S.																																																																																																								
% change in C.F. from last cal= -1.34%	-1.24%	-1.16%	± 10%																																																																																																								
<b>As found:</b> Interface Board Voltages: Bias Supply: -299.6 Temperatures: Detector Oven: 175.0 Column Oven: 75.1 Internal: 26.2 Cylinder Pressures/reg.: Carrier: 1250   50 Fuel: 900   50 Span Gas: 500   Zero Air Generator: 45 Internal Pressures: Carrier: 28.6 Fuel: 37.6 Air: 34.2 FID Status: Status: LIT Counts: 21882 Flame: 344.1 Det Base: 175.0 Flameouts: 1 Det Oven at Start: 173.9 Col Oven at Start: 74.8 Calibration History: Time: 08Dec2016@12:40 Type: SPAN Status: GOOD Check/Adjust: ADJUST CH <sub>4</sub> Span Conc: 14.67 CH <sub>4</sub> SP Ratio: 0.000692 CH <sub>4</sub> RT: 12.4 CH <sub>4</sub> PK IDX: 22 CH <sub>4</sub> PK HT: 23201 NM Span Conc: 13.94 NM SP Ratio: 0.000149																																																																																																											
<b>As left:</b> Calibration History cnt'd: NM Peak Area: 93804 Crucial Settings: Methane Start: n/a Methane End: n/a Backflush: n/a NMHV Start: n/a NMHC End: n/a Run History>1: Date: 04Jan17 Time: 10:12 CH <sub>4</sub> PK HT: 0 CH <sub>4</sub> RT: 12.0 CH <sub>4</sub> Baseline: 1769 CH <sub>4</sub> LOD: 31 CH <sub>4</sub> SD: 10 CH <sub>4</sub> CONC: 0.00 NM PK HT: 0 NM Peak Area: 0 NM CONC: 0 NM Base Start: 1779 NM Base End: 1800 NM LOD: 34 NM Start IDX: 14 NM End IDX: 91 NM Max Slope: 1.6e+00 NM Min Slope: -8.3e-01 NM PT Count: 0 Expected Values: Previous CH4: 8.82 Previous NMHC: 10.13 Previous THC: 18.96 New CH4: 8.79 New NMHC: 10.12 New THC: 18.92																																																																																																											
<b>Comments:</b> The analyzer sample inlet filter was changed.  No zero adjustment was required/made. As found zero values were copied to adjusted zero values for linearity calculation purposes.  The analyzer cooling fan filter(s) were cleaned.																																																																																																											
10:09-10:10: Flow check performed. 4:01-14:02 Drift in calibrator zero was due to disconnecting the calibration set up and start IZS.																																																																																																											



Station: THREE CREEKS #842 TRAILER Daily: 2017/01/04 Type: AVG 1 Min. [1 Min.]



## ***WIND SYSTEM***

## Meteorological Sensor Audit

Location Information				
Company:	Three Creek	Performed By:	Limin Li	
Audit Location:	842B	Reviewed By:	not yet reviewed	
Audit Date:	October 12, 2016	Start Time (mst):	16:30	
Previous Audit Date:	n/a	End Time (mst):	17:30	
Wind Speed Sensor Information		Calibrator Information		
Sensor make:	RM Young	Make:	RM Young	
Sensor model:	5305VK. SN:92411	Model:	18802	
Calibrator:	See calibrator information " Make"	I.D.#/Serial#:	4309	
Voltage range:	0-1V/output single range: 0-200kph	Ceritification Date:	October 9, 2013	
Wind Speed Audit Data **+/- 2% of the average correction factor is the limit**				
RPM	Wind Speed Generated kph	Clockwise Wind Speed kph	Counter Clockwise Wind Speed kph	Correction Factor
0	0	0.1	0.1	-
1000	17.6	17.6	17.5	1.003
2000	35.3	35.1	35.1	1.005
3000	52.9	52.6	52.6	1.007
4000	70.6	70.1	70.1	1.007
5000	88.2	87.6	87.6	1.007
6000	105.8	105.1	105.1	1.007
7000	123.5	122.6	122.6	1.007
8000	141.1	140.1	140.1	1.007
9000	158.8	157.6	157.6	1.007
10000	176.4	175.0	175.0	1.008
		The audit meets AMD requirements.	Average Correction Factor=	1.006
Wind Direction Audit Data **+/- 3° of the average degrees difference is the limit**				
Generated Wind Direction	Indicated Wind Direction	Degrees Difference		
0	0.4	-0.4		
45	46.5	-1.5		
90	91.0	-1.0		
135	135.5	-0.5		
180	180.2	-0.2		
225	224.2	0.8		
270	268.3	1.7		
315	313.0	2.0		
355	351.4	3.6		
The audit meets AMD requirements.		Average Degrees Difference=	1.3	
Recommendations: The wind calibrator is non-Maxxam property.				

## ***CALIBRATORS***

# Calibrator Performance Audit

## Oxides Of Nitrogen

File No. 2016-510A

Company	Maxxam		Operator:	Mike			
<b>Calibrator:</b> Make/Model Environics 6100 Serial Number 5212 Last Verification Date February 3, 2016 NO Cylinder S/N EY0000597 NO [PPM] 49.0 NOx [PPM] 49.0 Expiry Date December 8, 2019			<b>Flow Measurement Device:</b> Make/Model Bios Defender 530 Serial Number HI148944 Lo 152019 Temperature (°C) 24.6 Barometric Pressure 701.4mmHg				
Dilution Flow (sccm) Pt. #1 4919 Pt. #2 4934 Pt. #3 4960 Gas Flow (sccm) Pt. #1 79.2 Pt. #2 38.3 Pt. #3 19.1							
Calibrator Flow (sccm)		Calculated Conc.(ppm)		Indicated Conc.(ppm)		% Difference vs Audit Gas	
Dilution	Gas	NO	NOx	NO	NO <sub>2</sub>	NOx	NO
4987	0.0	0.0000	0.0000	0.0000	0.0002	0.0002	Limit ± 10%
4998	79.2	0.7765	0.7765	0.7801	-0.0003	0.7798	0%
4977	38.3	0.3775	0.3775	0.3790	0.0000	0.3790	0%
4979	19.1	0.1880	0.1880	0.1888	-0.0001	0.1887	0%
Absolute Average Percent Difference						0%	0%
<b>LINEAR REGRESSION ANALYSIS</b>							
<i>y=mx+b (where x=calculated concentration, y=indicated concentration)</i>							
<b>NO</b>		<b>LIMITS</b>		<b>NO<sub>x</sub></b>			
Correlation=	1.0000	≥ 0.990		Correlation=	1.0000		
m (Slope)=	1.0046	0.90-1.10		m (Slope)=	1.0041		
b (Intercept % of FS)=	-0.0080	± 3% F.S.		b (Intercept % of FS)=	0.0057		
<b>LINEAR REGRESSION ANALYSIS</b>							
<i>y=mx+b (where x=calculated concentration, y=indicated concentration)</i>							
<b>NO<sub>2</sub></b>		<b>LIMITS</b>					
Correlation=	1.0000	≥ 0.995					
m (Slope)=	0.9936	0.90-1.10					
b (Intercept % of FS)=	-0.0733	± 3% F.S.					
<b>AENV Standards</b>				<b>NO<sub>x</sub> Analyzer</b>			
<b>Audit Calibrator</b> Make/Model Thermo 146i Serial/AMU Number 1809 SRM Gas Cylinder No. CAL018140 Cylinder Conc. (ppm) 48.79				Make/Model Thermo 42i Serial/AMU Number 1868 Last Calibration Date February 13, 2017 Full Scale (ppm) 1.0 Cylinder Gas Expiry Date March 28, 2019			
<b>COMMENTS:</b> Gas has ~50ppm SO <sub>2</sub>							
Auditor: <u>Shea Beaton</u>				Date: February 14, 2017			
Operator Signature:				Location: McIntyre Center Edmonton			

# Calibrator Performance Audit

## Sulphur Dioxide (by Cylinder Dilution)

 File No. 2016-509A
**Company:** Maxxam      **Operator:** Mike

<b>Calibrator:</b>		<b>Flow Measurement Device:</b>	
Make/Model	API 700	Make/Model	Bios Defender 530+
Serial Number	830	Serial Number	Hi148944 Lo 152019
Last Verification Date	January 19, 2016	Temperature (°C)	24.6
SO <sub>2</sub> Cylinder Conc.	50.5	Barometric Pressure	701.4mmHg
SO <sub>2</sub> Cylinder S/N	EY0000769		
Expiry Date	December 8, 2019		

**Flow Measurements**
Pt. No. 1 78.0    Pt. No. 2 37.7    Pt. No. 3 18.6

Calibrator Flow (sccm)	Calculated Concentration (ppm)	Indicated Concentration (ppm)	% Difference	
			vs Audit Gas	% Diff. Limit
4978	0.0000	0.0000		
4974	0.7920	0.7912	0%	± 10%
4978	0.3825	0.3825	0%	± 10%
4975	0.1900	0.1908	0%	± 10%
Absolute Average Percent Difference			0%	± 10%

**LINEAR REGRESSION ANALYSIS**
*y=mx+b (where x=calculated concentration, y=indicated concentration)*
**SO<sub>2</sub>**
**LIMITS**

Correlation=	1.0000	≥ 0.995
m (Slope)=	0.9986	0.90-1.10
b (Intercept % of FS)=	0.0477	± 3% F.S.

**AENV Standards**
**Audit Calibrator**

Make/Model	R&R MFC 201
Serial/AMU Number	1690
SO <sub>2</sub>	
SRM Gas Cylinder No.	CAL016625
Cylinder Conc. (ppm)	98.07

**SO<sub>2</sub> Analyzer**

Make/Model	Themro 43i
Serial/AMU Number	1623
Last Calibration Date	January 31, 2017
Full Scale (ppm)	1.0
Expiry Date	January 5, 2019

**COMMENTS:** Analyzer verified prior to audit
**Auditor:** J. Shea Beaton  
**Operator Signature:** Mike
**Date:** February 14, 2017  
**Location:** McIntyre Center Edmonton

Company: <u>Maxxam</u>	Operator: <u>Mike</u>	
<b>Calibrator:</b> Make/Model <u>API 700</u> Serial Number <u>831</u> Last Verification Date <u>January 19, 2016</u> SO <sub>2</sub> Cylinder Conc. <u>50.5</u> SO <sub>2</sub> Cylinder S/N <u>EY0000769</u> Expiry Date <u>December 8, 2019</u>		<b>Flow Measurement Device:</b> Make/Model <u>Bios Defender 530+</u> Serial Number <u>Hi148944 Lo 152019</u> Temperature (°C) <u>24.6</u> Barometric Pressure <u>701.4mmHg</u>

**Flow Measurements**

 Pt. No. 1 77.3 Pt. No. 2 37.5 Pt. No. 3 18.8

Calibrator Flow (sccm)	Calculated Concentration (ppm)	Indicated Concentration (ppm)	% Difference	
			vs Audit Gas	% Diff. Limit
Zero Air	0.0000	0.0001		
4995	0.7815	0.7889	1%	± 10%
5003	0.3785	0.3840	1%	± 10%
5007	0.1896	0.1911	1%	± 10%
Absolute Average Percent Difference			1%	± 10%

**LINEAR REGRESSION ANALYSIS**
 $y=mx+b$  (where x=calculated concentration, y=indicated concentration)

<b>SO<sub>2</sub></b>	<b>LIMITS</b>
Correlation=	<u>1.0000</u>
m (Slope)=	<u>1.0097</u>
b (Intercept % of FS)=	<u>0.0341</u>
<b>± 0.995</b>	
<b>0.90-1.10</b>	
<b>± 3% F.S.</b>	

<b>AENV Standards</b>		<b>SO<sub>2</sub> Analyzer</b>	
<b>Audit Calibrator</b>		Make/Model <u>R&amp;R MFC 201</u> Serial/AMU Number <u>1690</u>	
Make/Model <u>R&amp;R MFC 201</u> Serial/AMU Number <u>1690</u>		Make/Model <u>Thermo 43i</u> Serial/AMU Number <u>1623</u> Last Calibration Date <u>January 31, 2017</u> Full Scale (ppm) <u>1.0</u>	
SRM Gas Cylinder No. <u>CAL016625</u> Cylinder Conc. (ppm) <u>98.07</u>		Expiry Date <u>January 5, 2019</u>	

 COMMENTS: Analyzer verified prior to audit

Auditor: <u>Shea Beaton</u>	Date: <u>February 14, 2017</u>
Operator Signature: <u>[Signature]</u>	Location: <u>McIntyre Center Edmonton</u>

## ***CALIBRATION GASES***



## Calibration Gas Audit

### Single Component Cylinder Gas

File No. 2016-086CGA

Company: Maxxam

Operator's Name: Chris Wesson

Cylinder #: LL119513 Concentration PPM: 50.6 Tolerance(%) 1 Certified By: Praxair

#### Reference Calibrator and Gas:

Make/Model: Teco 146i

Serial Number: AMU 1809

Last Verification Date: June 17, 2016

Gas Type: SO<sub>2</sub> Conc. 98.07

Cylinder Number: CAL016625

#### Flow Measurement Device:

Make/Model: Bios DC2

Serial Number: AMU 1659

Temp.°C: 23.0 C

B.P. 700 mmhg

#### Reference Analyzer:

Make/Model: Teco 43C

Serial/AMU Number: 1623

Instrument Settings: Zero: 8.7 Span: 1.027 Range: 1.0

Last Calibration: Date: June 17/16 C.F. 1.000 Done By: Al Clark

Calibrator Flows (sccm)		Indicated Concentration (PPM)	Gas Flow/ Dilution Flow	Concentration Factor	Cylinder Concentration
Dilution	Gas				
5000	0.0	0.000	X	X	X
4976	82.3	0.828	0.01654	60.462	50.1
4985	40.8	0.411	0.00818	122.181	50.2
4965	20.2	0.203	0.00407	245.792	49.9
Average Cylinder Concentration:					50.1

Previous Stated Concentration PPM: 50.6

Percent variance from Stated: 1.1

Meets Manufacturer Tolerance. Use manufacturers stated concentration  COMMENTS: \_\_\_\_\_

<=5% Outside Manufacturer Tolerance. Use manufacturers concentration  \_\_\_\_\_

> 5% Outside Manufacturer Tolerance. DO NOT USE this cylinder  \_\_\_\_\_

Auditor: Al Clark

Date: June 17, 2016

Operator Signature: Al Clark

Location: McIntyre Center Edmonton



## Calibration Gas Audit Single Component Cylinder Gas

File No. 2015-112CGA

Company: Maxxam

Operator's Name: Chris Wesson

Cylinder #: BLM002197 Concentration PPM: 10.3 Tolerance(%) 2 Certified By: Air Liquide

### Reference Calibrator and Gas:

Make/Model: R&R MFC 201

Serial Number: AMU 1690

Last Verification Date: February 2, 2016

Gas Type: H2S Conc. 20.43

Cylinder Number: CAL015584

### Flow Measurement Device:

Make/Model: Bios DC-2

Serial Number: Bios D

Temp. °C: 24.5

B.P. 702mmHg

### Reference Analyzer:

Make/Model: Thermo 450i Serial/AMU Number: 1980

Instrument Settings: Zero: 15.3 Span: 1.126 Range: 0.1

Last Calibration: Date: 1-Feb-16 C.F. 1.000 Done By: SB

Calibrator Flows (sccm)		Indicated Concentration (PPM)	Gas Flow/ Dilution Flow	Concentration Factor	Cylinder Concentration
Dilution	Gas				
5017	0.0	0.000	X	X	X
5054	37.96	0.078	0.00751	133.140	10.4
5055	17.78	0.037	0.00352	284.308	10.4
5029	9.07	0.019	0.00180	554.465	10.3
Average Cylinder Concentration:					10.3

Previous Stated Concentration PPM: 10.3

Percent variance from Stated: 0.5

Meets Manufacturer Tolerance. Use manufacturers stated concentration  COMMENTS: \_\_\_\_\_

<=5% Outside Manufacturer Tolerance. Use manufacturers concentration  \_\_\_\_\_

> 5% Outside Manufacturer Tolerance. DO NOT USE this cylinder  \_\_\_\_\_

Auditor: Shea Beaton

Date: February 2, 2016

Operator Signature:

Location: McIntyre Center Edmonton



## Calibration Gas Audit Single Component Cylinder Gas

File No. 2015-109CGA

Company: Maxxam

Operator's Name: Chris Wesson

Cylinder #: BLM001927 Concentration PPM: 10.3 Tolerance(%) 2 Certified By: Air Liquide

### Reference Calibrator and Gas:

Make/Model: R&R MFC 201

Serial Number: AMU 1690

Last Verification Date: February 2, 2016

Gas Type: H2S Conc. 20.43

Cylinder Number: CAL015584

### Flow Measurement Device:

Make/Model: Bios DC-2

Serial Number: Bios D

Temp. °C: 24.5

B.P. 702mmHg

### Reference Analyzer:

Make/Model: Thermo 450i Serial/AMU Number: 1980

Instrument Settings: Zero: 15.3 Span: 1.126 Range: 0.1

Last Calibration: Date: 1-Feb-16 C.F. 1.000 Done By: SB

Calibrator Flows (scm)		Indicated Concentration (PPM)	Gas Flow/ Dilution Flow	Concentration Factor	Cylinder Concentration
Dilution	Gas				
5025	0.0	0.000	X	X	X
5058	37.84	0.078	0.00748	133.668	10.4
5059	17.85	0.036	0.00353	283.417	10.3
5031	9.15	0.019	0.00182	549.836	10.2
Average Cylinder Concentration:					10.3

Previous Stated Concentration PPM: 10.3

Percent variance from Stated: 0.1

Meets Manufacturer Tolerance. Use manufacturers stated concentration  COMMENTS: \_\_\_\_\_

<=5% Outside Manufacturer Tolerance. Use manufacturers concentration  \_\_\_\_\_

> 5% Outside Manufacturer Tolerance. **DO NOT USE** this cylinder  \_\_\_\_\_

Auditor: Shea Beaton

Date: February 2, 2016

Operator Signature:

Location: McIntyre Center Edmonton



# Calibration Gas Audit

## CH4 / C3H8 Cylinder Gas

File No. 2013-298CGA

Company: <u>Maxxam</u>	Operators name: <u>Theo</u>
Cylinder #: <u>LL19638</u>	Conc CH4 (PPM) <u>880/304</u> Tolerance (%) <u>2</u> Certified By: <u>Praxair</u>
<b>Reference Calibrator and Gas:</b> Make/Model <u>R&amp;R MFC 201</u> Serial Number <u>AMU 1690</u> Last Verification Date <u>October 17, 2013</u> Gas Type <u>CH4</u> Conc. <u>999.2</u> Cylinder Number <u>D751932</u> Gas Type <u>C3H8</u> Conc. <u>246.5</u> Cylinder Number <u>XF0037998</u>	
<b>Flow Measurement Device:</b> Make/Model <u>Bios DC2</u> Serial Number <u>AMU 1659</u> Temp. °C <u>21.0</u> C B.P. <u>706 mmhg</u>	

<b>Reference Analyzer:</b> Make/Model <u>Teco 55C</u> Instrument Settings Zero: <u>N/A</u> Span: <u>N/A</u> Range: <u>20</u> Last Calibration: Date: <u>Oct 17/13</u> C.F. <u>1.000</u> Done By: <u>Al Clark</u>	
---	--

Calibrator Flows (scem)		Indicated Conc. (ppm)		Gas Flow/ Dilution Flow	Concentration Factor	Cylinder Concentration	
Dilution	Gas	CH4	C3H8			CH4	C3H8
3500	0.0	0.04	0.00	XX	XX	XX	XX
3505	51.9	13.16	12.58	0.01481	67.534	889	309
3487	22.2	5.64	5.43	0.00637	157.072	886	310
3458	10.8	2.80	2.73	0.00312	320.185	897	318
Average Cylinder Concentration:						<u>890</u>	<u>312</u>

<u>CH4</u>	<u>C3H8</u>
Previous Stated Concentration PPM: <u>880</u>	<u>304</u>
Percent variance from Stated: <u>1.2</u>	<u>2.7</u>

**Cylinder gas tolerances based on CH4 only**

Meets Manufacturer Tolerance. Use manufacturers stated concentration  COMMENTS: \_\_\_\_\_

<=5% Outside Manufacturer Tolerance, Use manufacturers concentration

> 5% Outside Manufacturer Tolerance, DO NOT USE this cylinder

Auditor: Al Clark  
Operator Signature: Al Clark

Date: October 17, 2013  
Location: McIntyre Center Edmonton

**APPENDIX III**  
***REPORT CERTIFICATION FORM***

## Report Certification Form

---

Alberta Airshed (if applicable)	EPA Approval or Code of Practice Registration # (if applicable)
NO	NA
Company Name (if applicable)	Industrial Operation Name (if applicable)
Peace River Area Monitoring Program Committee	Three Creeks 842b Station
Name of the Representative of the Person Responsible (Last, First, Middle)	Position / Title of the Representative of the Person Responsible
Wunmi Adekanmbi	Project Manager, Customer Service, Air Services
Is an External Party Certifying the Report? (If 'Yes', fill in the fields below for the external person.)	
<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Name of External Person Certifying the Report (Last, First, Middle)	Position / Title of External Person Certifying the Report
NA	NA
Company Name for the External Person Certifying the Report	Identification of Qualifications / Professional Designations of the External Person Certifying the Report
NA	NA

I certify that I have reviewed and verified the submitted report. I also certify that the report presented with this certification form is complete, accurate and representative of the monitoring results and timeframe.




---

Signature of the Representative of the Person  
Responsible / External Person Certifying the Report

22-02-2017

---

Report Issued Date (dd-mm-yyyy)

**APPENDIX IV**  
**DATA VALIDATION CERTIFICATION FORM**



## Validation Certificate Form

**Client:** Peace River Area Monitoring Program Committee

**Site:** Three Creeks 842b Station

**Project #:** 8449-2017-01-80-C

**Contact:** Mike Bisaga

Level 0 Preliminary Verification

Date

16-Feb-17

Level 1 Primary Validation

Date

16-Feb-17

Level 2 Final Validation

Date

22-Feb-17

Level 3 Independent Data Review

  
Chris Sinclair

Date

23-Feb-17

Post-Final Validation

NA

Date

NA

Notes
The Post-Final Validation step serves to re-evaluate the data that errors or omissions are discovered and/or suspected after the initial submittal of data. This validation is performed on an annual basis.