



MAXXAM ANALYTICS
#1 2080 39 Ave. NE, Calgary, AB
T2E 6P7

maxxam.ca
Toll Free 800-386-7247
Fax 403-219-3673

**AMBIENT AIR MONITORING MONTHLY DATA REPORT
PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
THREE CREEKS 842B STATION**

JOB #: 8449-2017-06-80-C

June 2017

Prepared for:

PEACE RIVER AREA MONITORING PROGRAM COMMITTEE

Attention: LILY LIN

DATE: **July 26, 2017**

Prepared by: *Maram Ghaleb*

Maram Ghaleb, B.Sc.
Project Manager, Customer Service, Air Services

Reviewed by: *Wunmi Adekanmbi*

Wunmi Adekanmbi, M.Sc., EPT.
Project Manager, Customer Service, Air Services

SUMMARY

In June 2017, Maxxam Analytics was contracted to manage the ambient air quality monitoring and maintenance activities at the Three Creeks 842b Station, near Peace River Oil Sands Area 2, Alberta. The monitoring station provides continuous meteorological measurements and air quality data for compliance parameters, as requested by the PRAMP Committee.

All data collected this month was compliant with the requirements outlined in the Air Monitoring Directive (Alberta Environment and Parks, 2016).

The operational time for all continuous ambient air analyzers, meteorological systems and data acquisition systems were above the 90% requirement.

All Parameters (except wind data): One hour of downtime was recorded due to a power failure that occurred on June 28, at hour 08:00.

THC/CH₄/NMHC: The analyzer was replaced on June 14, in response to the ongoing situation where low-impact noise was being recorded on the NMHC parameter. Nine hours of downtime were recorded due to this event.

Wind System: The wind system malfunctioned on June 27, it was subsequently replaced on June 29. Thirty-five hours of wind data were discarded due to this event.

The summary of results is presented on the following pages.

Any deviations or modifications made to the sampling or analytical methods are outlined in Section 1.0, Discussion. On this basis, Maxxam Analytics is issuing this completed report to Peace River Area Monitoring Program Committee, Three Creeks 842b Station.

Should you have any questions concerning the results or if we can be of further assistance, please contact us at 403-219-3678 or toll-free at 1-800-386-7247.

Monthly Continuous Data Summary

Peace River Area Monitoring Program Committee						MAXIMUM VALUES							OPERATIONAL TIME (%)
Three Creeks 842b Station						1-HOUR					24-HOUR		
PARAMETER	OBJECTIVES		EXCEEDANCES		MONTHLY AVERAGE	READING	DAY	HOUR	WIND SPEED (kph)	WIND DIRECTION (sector)	READING	DAY	
	1-hr	24-hr	1-hr	24-hr									
SO ₂ (ppb)	172	48	0	0	0	1	1	8	7.9	SW	0	1	99.9
TRS (ppb)	-	-	-	-	0.19	0.73	18	5	4.3	SE	0.29	2	99.9
THC (ppm)	-	-	-	-	1.88	2.25	20	4	4.3	E	1.96	5	98.6
CH ₄ (ppm)	-	-	-	-	1.88	2.25	20	4	4.3	E	1.96	5	98.6
NMHC (ppm)	-	-	-	-	0.00	0.00	1	0	2.2	SE	0.00	1	98.6
RELATIVE HUMIDITY (%)	-	-	-	-	60	96	11	4	4.0	NNW	83	14	99.9
BAROMETRIC PRESSURE (millibar)	-	-	-	-	940	954	24	5	0.9	E	953	24	99.9
AMBIENT TEMPERATURE (°C)	-	-	-	-	15.1	27.1	7	15	9.0	E	21.4	8	99.9
STATION TEMPERATURE (°C)	-	-	-	-	20.6	23.2	30	5	4.4	WNW	22.5	30	99.9
VECTOR WS (kph)	-	-	-	-	2.6	22.9	3	17	-	WSW	12.7	9	95.1
VECTOR WD (sec)	-	-	-	-	239 (WSW)	-	-	-	-	-	-	-	95.1

SOUR GAS PROCESSING INDUSTRY
MONTHLY REPORT SUMMARY

Three Creeks 842b Station

Peace River Area Monitoring Program Committee

Plant Name / Location

Company

Licence Number	Report Date	
	YEAR	MONTH
N/A	2017	June

CONTINUOUS AMBIENT MONITORING								
PARAMETER	STN No.	% TIME OPERATIONAL	ONE - HOUR AVERAGE			24 - HOUR AVERAGE		
			MAXIMUM VALUES	NO. READINGS > REGULATION		MAXIMUM VALUES	NO. READINGS > REGULATION	
SO ₂	1	99.9	0.001 ppm	0		0.000 ppm	0	
TRS	1	99.9	0.001 ppm	-		0.000 ppm	-	
THC	1	98.6	2.25 ppm	-		1.96 ppm	-	
CH ₄	1	98.6	2.25 ppm	-		1.96 ppm	-	
NMHC	1	98.6	0.00 ppm	-		0.00 ppm	-	
RH	1	99.9	96 %	-		83 %	-	
BP	1	99.9	954 mb	-		953 mb	-	
Ambient TPX	1	99.9	27.1 °C	-		21.4 °C	-	
Station TPX	1	99.9	23.2 °C	-		22.5 °C	-	
Wind Speed	1	95.1	23 kph	-		13 kph	-	
Wind Direction	1	95.1	-	-		-	-	

SIGNATURE OF COMPANY REPRESENTATIVE

FOR ALBERTA ENVIRONMENT USE ONLY

Exceedance Summary Report

SO₂ 1-Hour Exceedances

Measured concentrations of sulphur dioxide were below the 1-hour AAAQO of 172 ppb.

SO₂ 24-Hour Exceedances

Measured concentrations of sulphur dioxide were below the 24-hour AAAQO of 48.0 ppb.

In accordance with EPEA and the Substance Release Regulation.

In accordance with A Guide to Release Reporting and the Alberta Ambient Air Quality Objectives and Guidelines Summary.

TABLE OF CONTENTS

<u>Title</u>	<u>Page</u>
SUMMARY	1
MONTHLY CONTINUOUS DATA SUMMARY REPORT	2
SOUR GAS SUMMARY REPORT	3
EXCEEDANCE SUMMARY REPORT	4
TABLE OF CONTENTS	5
<hr/>	
1.0 Discussion	6
<hr/>	
2.0 Project Personnel	9
<hr/>	
3.0 Plant Monthly Required AMD Summary	9
<hr/>	
4.0 Calculations and Results	9
<hr/>	
5.0 Methods and Procedures	10
<hr/>	
Appendix I	Continuous Monitoring Data Results 13
	Sulphur Dioxide 14
	Total Reduced Sulphur 22
	Total Hydrocarbon 30
	Methane 38
	Non-Methane Hydrocarbon 46
	Wind Speed 54
	Wind Direction 61
	Relative Humidity 64
	Barometric Pressure 67
	Ambient Temperature 70
	Station Temperature 73
Appendix II	Equipment Calibration Results 76
	Sulphur Dioxide 77
	Total Reduced Sulphur 80
	Total Hydrocarbon 83
	Wind System 92
	Calibrators 95
	Calibration Gases 98
Appendix III	Report Certification Form 102
Appendix IV	Data Validation Certification Form 104

1.0 Discussion

This monthly report consists of continuous monitoring results for the following parameters: Sulphur Dioxide (SO₂), Total Reduced Sulphur (TRS), Total Hydrocarbon (THC), Methane (CH₄), Non-Methane Hydrocarbon (NMHC), Relative Humidity (RH), Barometric Pressure (BP), Ambient Temperature (AmbTPX), Station Temperature (StnTPX), Wind Speed (WS) and Wind Direction (WD).

Sample filters for all continuous air monitors are changed before the calibration begins. The sample manifold is cleaned during the site visit each month.

Control checks, consisting of a zero and span, are conducted daily on all continuous air monitors. In place of the air sample, zero air (from scrubbed air or gas cylinders) is used for zero checks, and a known concentration of the pollutant being analyzed is used for span checks. These checks are controlled by automatic timers and valves. The total zero span cycle is completed within an hour, the commencement of the zero span cycle is at the beginning of the hour.

Multipoint calibrations are done a minimum of once a month for each continuous air monitor. An additional calibration is required under the following conditions: 1) within three days after the initial start-up and stabilization of a newly installed instrument, 2) prior to shut-down or moving of an instrument which has been working to specification, and 3) when major repair has been done on the instrument.

Time during the first multi-point calibration is not considered downtime (Data is flagged as C). If more than one calibration is performed during the month, the time during the additional calibration is considered as downtime (Data is flagged as C1).

Only one zero/span check is run per day. Time during the zero/span check is not considered as downtime (Data is flagged as S). If an extra zero/span check is performed, the time during the additional check is considered as downtime (Data is flagged as S1).

The AMD requires each instrument and accompanying data recording system to be operational 90% of the time, at a minimum, for each monthly monitoring period.

All sampling, analysis, and QA/QC for this project was performed by Maxxam Analytics and complies with the Alberta Air Monitoring Directive.

Data contained in this monthly report has undergone the verification and validation based on the requirements of the AMD Chapter 6: Ambient Data Quality (December, 2016). The descriptions of the data verification and validation process can be found in Section 5 of this report. Instantaneous data, where applicable, is provided for reference purposes and has not undergone zero correction. The minimum and maximum statistics are highlighted in the data table and are for reference only. The highlighted cells are based on the software's interpretation of the exact position of the minimum or maximum value. The visual presentation of these statistics may not be the obvious choice in a data range due to rounding, truncating or analyzer specifications.

Hourly/minute data have been reviewed based on daily zero/span results and multi-point calibration results. Data may be considered invalid if a zero-corrected span check in excess of +/- 10% of the span concentration (established by the previous multi-point calibration) is encountered and/or significant differences in the calibration factor occurs (greater than 10%).

SULPHUR DIOXIDE (SO₂)

- Operational time, for the monitoring period was 99.9%, equivalent to one hour of downtime. This was incurred due to a power failure that occurred on June 28 at hour 08:00.
- The routine monthly calibration was performed on June 6.
- Seven instances of maximum instantaneous data were discarded this month due to brief power outages.

TOTAL REDUCED SULPHUR (TRS)

- Operational time, for the monitoring period was 99.9%, equivalent to one hour of downtime. This was incurred due to a power failure that occurred on June 28 at hour 08:00.
- The routine monthly calibration was performed on June 6.
- Seven instances of maximum instantaneous data were discarded this month due to brief power outages.

TOTAL HYDROCARBONS (THC), METHANE (CH₄) and NON-METHANE HYDROCARBONS (NMHC)

- Operational time, for the monitoring period was 98.6%, equivalent to ten hours of downtime.
- The routine monthly calibration was performed on June 6.
- The NMHC parameter was recording some noise when sampling ambient air over the past few weeks, and this was reflecting in the NMHC instantaneous maximum data. The situation was being monitored as this noise had minimal effect on hourly average and the analyzer was demonstrated to be operating within accepted limits. However, as this observation has persisted over an extended period of time, the Thermo 55i (s/n:1433563261) analyzer was replaced on June 14, following a successful shut-down calibration. A successful installation calibration was subsequently performed on Thermo 55i (s/n: 1236656188), the replacement analyzer. Nine hours of downtime were recorded due to this event.
- One hour of downtime was recorded due to a power failure that occurred on June 28, at hour 08:00.
- Seven instances of maximum instantaneous data were discarded this month due to brief power outages.
- The canister sampler is programmed to draw in a whole air sample when the 5-minute average concentration of NMHC is above 0.30 ppm. A representative sample of ambient air is collected over a one-hour period when the canister event is triggered. No canister event was recorded this month.

WIND SPEED (WS) and WIND DIRECTION (WD)

- Operational time, for the monitoring period was 95.1%, equivalent to thirty-five hours of downtime. These were incurred due to a malfunction of the wind system that occurred on June 27. The wind system, RM Young (s/n: 92411), was replaced with RM Young (s/n: 110980) on May 29, followed by a successful installation calibration.
- Five instances of maximum instantaneous data were discarded this month due to brief power outages.
- Wind data is reported as vector wind speed and vector wind direction. Wind direction is defined as the direction from which the wind is blowing from and is measured in degrees from true north.

RELATIVE HUMIDITY (RH)

- Operational time, for the monitoring period was 99.9%, equivalent to one hour of downtime. This was incurred due to a power failure that occurred on June 28 at hour 08:00.

BAROMETRIC PRESSURE (BP)

- Operational time, for the monitoring period was 99.9%, equivalent to one hour of downtime. This was incurred due to a power failure that occurred on June 28 at hour 08:00.

AMBIENT TEMPERATURE (AmbTPX)

- Operational time, for the monitoring period was 99.9%, equivalent to one hour of downtime. This was incurred due to a power failure that occurred on June 28 at hour 08:00.

STATION TEMPERATURE (StnTPX)

- Operational time, for the monitoring period was 99.9%, equivalent to one hour of downtime. This was incurred due to a power failure that occurred on June 28 at hour 08:00.

2.0 Project Personnel

Karla Reesor was the contact for Peace River Area Monitoring Program Committee and the Maxxam field technician was Limin Li.

3.0 Plant Monthly Required AMD Summary

All data collected this month was compliant with the requirements outlined in the Air Monitoring Directive (Alberta Environment and Parks, 2016).

The operational time for all continuous ambient air analyzers, meteorological systems and data acquisition systems were above the 90% requirement.

4.0 Calculations and Results

All calculations and reporting of results follow the methods described in the AMD, 2016.

5.0 Methods and Procedures

The following methods and procedures were used to complete the monitoring program:

Maxxam AIR SOP-00001: Methane, Non-Methane Hydrocarbon Analyzer Monitoring

Maxxam AIR SOP-00208: RM Young Wind Monitor Calibration

Maxxam AIR SOP-00209: Ambient Sulphur Monitoring

There were no deviations from the prescribed methods.

The following instruments were used to perform the test program:

Sulphur Dioxide - API 100A UV Fluorescent Analyzer

Total Reduced Sulphur - Thermo 43i UV Fluorescent Analyzer

Methane, Non-Methane Hydrocarbon - Thermo 55i FID Analyzer

Wind System - RM Young Unit

Relative Humidity - RM Young Unit

Barometric Pressure - RM Young Unit

Ambient Temperature - RM Young Unit

Datalogger - ESC 8832

The following steps were used to complete the data verification and validation process:

Level 0 Preliminary Verification

Level 0 data are raw data obtained directly from the data acquisition system (DAS). Under the step of Level 0, these data undergo a certain amount of manual or automated screening and flagging. It included a) identification of periods of missing data; b) verification of time stamps against reference time; c) verification that instrument diagnostics/datalogger flags indicate normal operation; d) comparison of data to upper and lower limits; e) rate of change flagging indicating that data changed too rapidly or not at all; and f) verification that zero, span and multipoint performance checks are within specifications. This level of verification is performed on a daily basis.

Level 1 Primary Validation

Validation actions under the step of Level 1 include a) review of all screening flags assigned during preliminary verification; b) review of all supporting site information and documentation; c) review of operational acceptance limits for each parameter/analyzer; d) review of daily zero/span and monthly calibration results for all gaseous parameters; and e) application of any necessary adjustments to data (e.g. baseline adjustments, below zero adjustments). This level of validation is performed on a monthly basis.

Level 2 Final Validation


The purpose of Level 2 validation is to verify that there are no inconsistencies among related data, or among regional data measured at nearby sites.

Level 3 Independent Data Review

Level 3 validation is the last step of data review, and it is completed by an individual that is independent of both field operations and primary data validation. A final independent QA review and endorsement is performed during this step before data is submitted to Alberta Environment.

Post-Final Validation

The Post-Final Validation step serves to re-evaluate the data that errors or omissions are discovered and/or suspected after the initial submittal of data. Any data issues or patterns which were not clear on a monthly basis are highlighted during this step. This validation is performed on an annual basis.



Source: Air Monitoring Directive (December 2016), Chapter 6, Ambient Data Quality; Figure 1 Data Collection and Management Process Flow Chart

APPENDIX I
CONTINUOUS MONITORING DATA RESULTS

SULPHUR DIOXIDE



SULPHUR DIOXIDE Hourly Averages (SO₂ ppb)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.		
DAY 1	0	0	S	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	24
DAY 2	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 3	S	0	0	0	0	0	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	1	0	24
DAY 4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	24
DAY 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	24
DAY 6	0	0	0	0	0	0	0	0	C	C	C	C	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	24
DAY 7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	24
DAY 8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	24
DAY 9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	24
DAY 10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 12	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 13	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 14	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 15	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 16	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 17	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 18	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 19	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 20	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 21	0	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 22	0	0	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 23	0	0	0	S	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	24
DAY 24	0	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 25	0	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24
DAY 26	S	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	24
DAY 27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	24
DAY 28	0	0	0	0	0	0	0	0	P	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	23
DAY 29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	24
DAY 30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	S	0	0	0	0	0	0	0	0	24
HOURLY MAX	0	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
HOURLY AVG	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT:	1-HR	172	ppb	24-HR	48	ppb
----------------------	------	-----	-----	-------	----	-----


24 HR AVERAGES June 2017



MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDANCES:	0
NUMBER OF 24-HR EXCEEDANCES:	0
NUMBER OF NON-ZERO READINGS:	6
MINIMUM 1-HR AVERAGE:	0 ppb @ HOUR 0 ON DAY 1
MAXIMUM 1-HR AVERAGE:	1 ppb @ HOUR 8 ON DAY 1
MAXIMUM 24-HR AVERAGE:	0 ppb ON DAY 1
IZS CALIBRATION TIME:	32 hrs
MONTHLY CALIBRATION TIME:	4 hrs
OPERATIONAL TIME:	719 hrs
AMD OPERATION UPTIME:	99.9 %
STANDARD DEVIATION:	0
MONTHLY AVERAGE:	0 ppb

SULPHUR DIOXIDE Hourly Averages (SO₂ ppb)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
Three Creeks 842b Station - June 2017

SULPHUR DIOXIDE Instantaneous Maximum (SO₂ ppb)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.		
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59						
DAY 1	1	1	S	1	1	1	1	1	1	1	1	1	1	1	0	0	1	1	1	1	1	0	1	1	0	1	1	24		
2	0	S	1	1	1	1	1	1	1	0	1	1	1	1	0	0	1	1	1	1	1	1	0	1	1	0	1	1	24	
3	S	0	0	0	0	1	P	1	1	P	1	1	1	0	0	0	1	1	1	1	1	1	1	S	0	1	1	22		
4	0	0	0	0	1	0	0	1	1	0	0	0	0	1	1	1	0	0	0	1	1	0	1	0	S	1	0	1	0	24
5	1	1	0	1	1	0	1	0	1	0	1	1	0	1	1	0	0	0	1	1	0	S	1	0	0	0	1	1	24	
6	0	0	0	0	0	1	1	1	C	C	C	C	C	1	1	1	1	1	1	1	S	1	1	1	0	1	1	24		
7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	S	1	1	1	1	1	1	1	24	
8	0	0	1	1	P	0	1	1	1	1	1	1	1	1	1	1	1	1	S	1	1	1	1	1	1	0	1	1	23	
9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	S	1	1	1	1	1	1	1	1	1	1	24	
10	0	1	0	1	1	0	1	1	1	1	1	1	1	1	1	1	S	1	1	1	1	1	1	1	0	1	1	1	24	
11	1	1	0	0	0	1	0	1	1	1	1	1	0	0	1	S	1	1	1	1	0	0	1	1	0	1	1	1	24	
12	1	1	0	0	0	1	1	1	1	1	1	0	1	1	S	1	1	0	0	1	1	1	1	1	0	1	1	1	24	
13	1	0	0	1	1	1	1	1	1	1	1	1	1	S	1	0	1	0	0	1	0	1	1	1	0	1	1	1	24	
14	1	1	0	0	0	1	1	1	1	1	0	1	S	1	1	1	1	1	1	1	1	1	1	1	1	0	1	1	24	
15	1	0	1	0	0	0	0	1	1	1	1	0	S	0	1	0	1	1	1	1	1	1	1	1	0	1	1	1	24	
16	1	1	1	1	1	1	1	1	1	1	S	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	24	
17	1	1	1	0	1	1	1	1	1	S	1	1	1	1	1	1	0	0	1	0	0	1	1	1	0	1	1	1	24	
18	1	0	1	1	1	1	1	1	S	1	1	1	0	0	1	0	1	0	1	0	1	1	1	0	0	1	1	1	24	
19	0	0	0	0	1	0	1	S	0	0	1	1	1	0	1	0	1	0	1	1	1	1	1	1	0	1	0	1	24	
20	1	1	1	1	1	1	S	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	24	
21	1	0	1	0	0	S	1	1	1	1	1	1	1	0	0	1	1	1	1	0	0	0	1	0	0	1	1	1	24	
22	0	0	0	0	S	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	1	1	1	1	0	1	0	1	0	24
23	0	0	0	S	0	0	1	1	2	1	1	0	0	1	1	1	0	1	1	0	0	1	1	0	0	1	1	0	2	24
24	0	0	S	0	0	0	1	1	0	0	0	0	0	1	0	0	1	1	1	1	0	0	1	1	0	1	0	1	0	24
25	1	S	1	0	0	1	0	0	1	1	1	1	1	1	1	1	1	2	2	1	1	1	1	1	0	2	1	1	24	
26	S	1	1	1	1	1	1	1	1	1	1	1	1	1	1	P	1	1	1	1	1	1	1	1	S	1	1	1	23	
27	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	S	1	1	1	1	1	24
28	1	1	1	1	1	1	1	1	1	P	0	1	1	1	0	1	1	1	0	1	1	S	1	1	0	1	1	1	23	
29	0	0	1	1	1	1	1	1	P	1	1	1	1	0	1	1	1	1	1	0	S	1	1	0	0	1	1	1	23	
30	0	0	0	1	1	1	1	1	1	1	2	1	1	1	1	1	1	1	1	1	S	1	1	1	P	0	2	1	23	
HOURLY MAX	1	1	1	1	1	1	1	1	2	1	2	1	1	1	1	1	1	2	2	1	1	1	1	1	1	1	1	1	1	
HOURLY AVG	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	510
MAXIMUM INSTANTANEOUS VALUE:	2 ppb @ HOUR 8 ON DAY 23
IZS CALIBRATION TIME:	32 hrs
MONTHLY CALIBRATION TIME:	5 hrs
OPERATIONAL TIME:	713 hrs
STANDARD DEVIATION:	0

SULPHUR DIOXIDE Instantaneous Maximum (SO₂ ppb)



Wind: PRAMP_842
 Poll.: PRAMP_842-SO2[ppb]
 Monthly: 17/06
 Type: PollutionRose
 Direction: Blowing From (Wind Frequency)
 Based On 1 Hr.


Calm: 7.96%

Calm Avg: 0.05 [ppb]

Direction	0-3	3-10	10-85	85-170	>170.0	Total
N	6.1	0.0	0.0	0.0	0.0	6.1
NE	5.3	0.0	0.0	0.0	0.0	5.3
E	13.3	0.0	0.0	0.0	0.0	13.3
SE	12.0	0.0	0.0	0.0	0.0	12.0
S	8.4	0.0	0.0	0.0	0.0	8.4
SW	17.0	0.0	0.0	0.0	0.0	17.0
W	20.0	0.0	0.0	0.0	0.0	20.0
NW	10.0	0.0	0.0	0.0	0.0	10.0
Summary	92.0	0.0	0.0	0.0	0.0	92.0

% Icon Classes (ppb) 92 0-3 0 3-10 0 10-85 0 85-170 0 >170.0

PRAMP_842 Poll.: PRAMP_842-SO2[ppb] 2017/06/01 00:00 - 2017/06/30 23:00 Calm: 7.96% Calm Poll Avg: 0.05[ppb]



SO2[ppb] Calibration: PRAMP_842 Monthly: 17/06 Type: Span



■ Span Meas — Span Ref — Span Low — Span High

TOTAL REDUCED SULPHUR




TOTAL REDUCED SULPHUR Hourly Averages (TRS ppb)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.					
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.						
DAY																																	
1	0.25	0.33	S	0.51	0.60	0.66	0.49	0.41	0.33	0.26	0.22	0.17	0.16	0.14	0.12	0.12	0.14	0.12	0.12	0.13	0.13	0.23	0.17	0.18	0.12	0.66	0.26	24					
2	0.18	S	0.28	0.27	0.33	0.46	0.34	0.37	0.32	0.41	0.30	0.37	0.47	0.33	0.26	0.23	0.17	0.15	0.16	0.20	0.24	0.27	0.28	0.21	0.15	0.47	0.29	24					
3	S	0.32	0.29	0.33	0.48	0.58	0.38	0.30	0.23	0.19	0.18	0.15	0.11	0.10	0.10	0.10	0.09	0.11	0.10	0.10	0.12	0.13	0.13	S	0.09	0.58	0.21	24					
4	0.21	0.26	0.42	0.41	0.48	0.38	0.42	0.21	0.16	0.13	0.13	0.11	0.08	0.08	0.08	0.08	0.08	0.07	0.08	0.08	0.10	0.11	S	0.16	0.07	0.48	0.19	24					
5	0.17	0.17	0.20	0.29	0.29	0.30	0.25	0.23	0.20	0.17	0.12	0.10	0.09	0.10	0.09	0.10	0.10	0.10	0.11	0.12	0.13	S	0.24	0.26	0.09	0.30	0.17	24					
6	0.24	0.19	0.22	0.26	0.22	0.20	0.22	0.29	C	C	C	C	C	0.19	0.12	0.11	0.11	0.12	0.14	0.15	S	0.20	0.20	0.20	0.11	0.29	0.19	24					
7	0.22	0.25	0.27	0.30	0.30	0.26	0.23	0.22	0.20	0.17	0.14	0.14	0.13	0.13	0.14	0.14	0.14	0.13	0.13	S	0.17	0.17	0.18	0.19	0.13	0.30	0.19	24					
8	0.16	0.14	0.16	0.17	0.16	0.16	0.16	0.16	0.16	0.16	0.14	0.13	0.11	0.11	0.13	0.13	0.13	0.13	S	0.13	0.13	0.14	0.15	0.15	0.11	0.17	0.14	24					
9	0.15	0.15	0.13	0.16	0.21	0.24	0.20	0.18	0.16	0.15	0.16	0.15	0.13	0.13	0.13	0.12	0.12	S	0.10	0.10	0.09	0.09	0.10	0.12	0.09	0.24	0.14	24					
10	0.13	0.16	0.19	0.24	0.30	0.32	0.26	0.30	0.27	0.19	0.15	0.22	0.20	0.13	0.14	0.14	S	0.18	0.16	0.15	0.24	0.25	0.20	0.17	0.13	0.32	0.20	24					
11	0.15	0.16	0.19	0.31	0.36	0.43	0.54	0.40	0.32	0.31	0.26	0.27	0.29	0.20	0.17	S	0.16	0.16	0.16	0.16	0.16	0.18	0.20	0.24	0.15	0.54	0.25	24					
12	0.22	0.25	0.20	0.18	0.20	0.26	0.31	0.24	0.23	0.22	0.16	0.13	0.13	0.11	S	0.11	0.11	0.10	0.10	0.11	0.12	0.21	0.22	0.25	0.10	0.31	0.18	24					
13	0.19	0.16	0.17	0.23	0.45	0.60	0.24	0.24	0.19	0.17	0.14	0.13	0.14	S	0.13	0.12	0.12	0.13	0.13	0.12	0.13	0.14	0.15	0.14	0.12	0.60	0.19	24					
14	0.16	0.17	0.18	0.23	0.25	0.25	0.26	0.21	0.18	0.18	0.17	0.18	S	0.15	0.13	0.12	0.11	0.13	0.13	0.13	0.19	0.21	0.18	0.18	0.15	0.11	0.26	0.18	24				
15	0.18	0.22	0.20	0.30	0.25	0.20	0.21	0.23	0.23	0.19	0.17	S	0.16	0.13	0.13	0.11	0.10	0.12	0.11	0.14	0.15	0.12	0.12	0.13	0.10	0.30	0.17	24					
16	0.13	0.13	0.15	0.16	0.19	0.20	0.28	0.24	0.17	0.16	S	0.20	0.17	0.16	0.15	0.13	0.15	0.12	0.13	0.12	0.10	0.11	0.20	0.15	0.10	0.28	0.16	24					
17	0.16	0.23	0.26	0.40	0.65	0.37	0.31	0.33	0.25	S	0.13	0.10	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.10	0.09	0.17	0.15	0.13	0.09	0.65	0.19	24					
18	0.21	0.31	0.41	0.48	0.50	0.73	0.49	0.29	S	0.23	0.15	0.13	0.11	0.12	0.10	0.11	0.12	0.11	0.12	0.11	0.12	0.11	0.15	0.15	0.16	0.10	0.73	0.23	24				
19	0.26	0.31	0.33	0.26	0.36	0.49	0.54	S	0.18	0.16	0.20	0.19	0.11	0.10	0.09	0.07	0.07	0.08	0.08	0.20	0.30	0.26	0.23	0.13	0.07	0.54	0.22	24					
20	0.11	0.16	0.15	0.16	0.25	0.23	S	0.26	0.23	0.23	0.18	0.16	0.13	0.11	0.11	0.12	0.13	0.13	0.14	0.16	0.21	0.12	0.16	0.11	0.11	0.26	0.16	24					
21	0.11	0.12	0.13	0.19	0.26	S	0.21	0.21	0.15	0.13	0.13	0.13	0.13	0.12	0.13	0.14	0.13	0.14	0.16	0.17	0.20	0.20	0.21	0.17	0.11	0.26	0.16	24					
22	0.14	0.14	0.19	0.17	S	0.20	0.23	0.22	0.15	0.15	0.13	0.12	0.13	0.13	0.13	0.12	0.12	0.12	0.14	0.12	0.16	0.21	0.19	0.23	0.12	0.23	0.16	24					
23	0.23	0.22	0.29	S	0.32	0.27	0.32	0.23	0.21	0.16	0.15	0.10	0.11	0.11	0.14	0.10	0.09	0.09	0.10	0.09	0.12	0.19	0.14	0.15	0.09	0.32	0.17	24					
24	0.18	0.17	S	0.24	0.24	0.25	0.24	0.17	0.13	0.13	0.12	0.12	0.11	0.10	0.09	0.09	0.09	0.10	0.10	0.12	0.13	0.20	0.24	0.21	0.09	0.25	0.16	24					
25	0.19	S	0.16	0.16	0.17	0.20	0.17	0.17	0.16	0.14	0.13	0.12	0.12	0.12	0.11	0.12	0.13	0.13	0.14	0.13	0.13	0.13	0.13	0.15	0.11	0.20	0.14	24					
26	S	0.18	0.16	0.17	0.16	0.20	0.21	0.21	0.35	0.27	0.20	0.18	0.16	0.14	0.11	0.04	0.10	0.12	0.13	0.12	0.16	0.17	0.20	S	0.04	0.35	0.17	24					
27	0.44	0.33	0.30	0.40	0.35	0.29	0.29	0.27	0.26	0.26	0.18	0.11	0.10	0.12	0.17	0.15	0.19	0.23	0.18	0.15	0.22	0.19	S	0.15	0.10	0.44	0.23	24					
28	0.14	0.13	0.13	0.13	0.15	0.14	0.15	0.16	P	0.15	0.15	0.14	0.12	0.14	0.16	0.13	0.14	0.13	0.13	0.13	0.16	S	0.20	0.20	0.12	0.20	0.15	23					
29	0.19	0.19	0.22	0.36	0.58	0.51	0.28	0.27	0.27	0.26	0.19	0.17	0.15	0.14	0.13	0.13	0.14	0.14	0.14	0.17	S	0.25	0.20	0.22	0.13	0.58	0.23	24					
30	0.22	0.20	0.22	0.30	0.24	0.30	0.34	0.28	0.29	0.17	0.17	0.14	0.15	0.12	0.10	0.10	0.09	0.07	0.07	S	0.12	0.14	0.15	0.13	0.07	0.34	0.18	24					
HOURLY MAX	0.44	0.33	0.42	0.51	0.65	0.73	0.54	0.41	0.35	0.41	0.30	0.37	0.47	0.33	0.26	0.23	0.19	0.23	0.18	0.20	0.30	0.27	0.28	0.26									
HOURLY AVG	0.19	0.21	0.22	0.27	0.32	0.33	0.30	0.25	0.22	0.20	0.17	0.16	0.15	0.13	0.13	0.12	0.12	0.12	0.12	0.14	0.15	0.18	0.18	0.17									

STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE


24 HR AVERAGES June 2017



MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	682
MINIMUM 1-HR AVERAGE:	0.04 ppb @ HOUR 15 ON DAY 26
MAXIMUM 1-HR AVERAGE:	0.73 ppb @ HOUR 5 ON DAY 18
MAXIMUM 24-HR AVERAGE:	0.29 ppb ON DAY 2
IZS CALIBRATION TIME:	32 hrs OPERATIONAL TIME: 719 hrs
MONTHLY CALIBRATION TIME:	5 hrs AMD OPERATION UPTIME: 99.9 %
STANDARD DEVIATION:	0.09 MONTHLY AVERAGE: 0.19 ppb

TOTAL REDUCED SULPHUR Hourly Averages (TRS ppb)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
Three Creeks 842b Station - June 2017

TOTAL REDUCED SULPHUR Instantaneous Maximum (TRS ppb)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59				
DAY 1	0.20	0.28	S	0.43	0.67	0.62	0.51	0.36	0.28	0.17	0.15	0.09	0.05	0.05	0.02	0.02	0.07	0.04	0.05	0.05	0.02	0.49	0.07	0.12	0.02	0.67	0.21	24
2	0.14	S	0.28	0.20	0.36	0.70	0.49	0.41	0.30	0.46	0.30	0.33	0.54	0.33	0.17	0.17	0.09	0.07	0.05	0.12	0.17	0.17	0.25	0.17	0.05	0.70	0.27	24
3	S	0.35	0.30	0.35	0.51	0.57	P	0.22	0.17	P	0.12	0.09	0.05	0.05	0.02	0.04	0.02	0.02	0.04	0.05	0.09	0.07	0.09	S	0.02	0.57	0.16	22
4	0.28	0.25	0.75	0.46	0.59	0.56	0.43	0.36	0.15	0.09	0.09	0.07	0.07	0.07	0.07	0.09	0.07	0.07	0.07	0.12	0.09	0.09	S	0.25	0.07	0.75	0.22	24
5	0.17	0.20	0.28	0.28	0.36	0.38	0.25	0.25	0.20	0.17	0.12	0.07	0.09	0.09	0.07	0.09	0.07	0.09	0.09	0.09	0.12	S	0.28	0.33	0.07	0.38	0.18	24
6	0.25	0.22	0.25	0.28	0.30	0.28	0.30	0.43	C	C	C	C	C	0.67	0.20	0.17	0.15	0.20	0.17	0.17	S	0.25	0.28	0.22	0.15	0.67	0.27	24
7	0.28	0.28	0.30	0.38	0.36	0.30	0.28	0.28	0.22	0.17	0.17	0.15	0.14	0.17	0.15	0.17	0.15	0.15	0.15	S	0.17	0.17	0.20	0.17	0.14	0.38	0.22	24
8	0.17	0.15	0.17	0.22	P	0.17	0.20	0.17	0.22	0.20	0.20	0.17	0.15	0.15	0.17	0.17	0.17	0.17	S	0.17	0.15	0.17	0.19	0.17	0.15	0.22	0.18	23
9	0.15	0.17	0.15	0.17	0.30	0.25	0.25	0.17	0.17	0.15	0.15	0.15	0.15	0.12	0.12	0.12	0.15	S	0.09	0.09	0.09	0.07	0.12	0.15	0.07	0.30	0.15	24
10	0.15	0.17	0.25	0.30	0.51	0.33	0.28	0.33	0.28	0.20	0.15	0.25	0.22	0.12	0.17	0.17	S	0.25	0.17	0.17	0.30	0.28	0.22	0.17	0.12	0.51	0.24	24
11	0.20	0.17	0.20	0.56	0.72	0.67	0.67	0.56	0.38	0.41	0.28	0.30	0.36	0.22	0.20	S	0.17	0.17	0.17	0.17	0.17	0.20	0.25	0.33	0.17	0.72	0.33	24
12	0.22	0.25	0.25	0.22	0.22	0.28	0.33	0.28	0.25	0.25	0.20	0.15	0.12	0.12	S	0.15	0.12	0.15	0.12	0.12	0.14	0.28	0.28	0.28	0.12	0.33	0.21	24
13	0.22	0.22	0.20	0.30	0.75	0.75	0.30	0.28	0.17	0.17	0.17	0.15	S	0.15	0.15	0.12	0.12	0.15	0.12	0.15	0.12	0.17	0.17	0.15	0.12	0.75	0.23	24
14	0.17	0.20	0.28	0.30	0.30	0.28	0.28	0.22	0.20	0.17	0.17	0.38	S	0.17	0.15	0.15	0.14	0.17	0.17	0.25	0.25	0.20	0.22	0.17	0.14	0.38	0.22	24
15	0.22	0.28	0.25	0.46	0.30	0.25	0.28	0.28	0.28	0.25	0.22	S	0.22	0.17	0.17	0.17	0.17	0.17	0.15	0.20	0.25	0.15	0.15	0.17	0.15	0.46	0.23	24
16	0.17	0.17	0.17	0.20	0.22	0.25	0.30	0.28	0.20	0.15	S	0.22	0.20	0.17	0.17	0.15	0.17	0.20	0.17	0.12	0.15	0.12	0.43	0.20	0.12	0.43	0.20	24
17	0.20	0.33	0.30	0.59	1.06	0.51	0.36	0.41	0.36	S	0.20	0.15	0.15	0.15	0.15	0.15	0.12	0.14	0.15	0.15	0.17	0.33	0.22	0.20	0.12	1.06	0.28	24
18	0.28	0.46	0.51	0.56	0.62	0.98	0.75	0.38	S	0.36	0.25	0.22	0.20	0.17	0.20	0.17	0.20	0.17	0.17	0.17	0.20	0.25	0.22	0.25	0.17	0.98	0.34	24
19	0.36	0.49	0.49	0.38	0.59	0.85	0.80	S	0.28	0.33	0.30	0.33	0.20	0.20	0.15	0.15	0.15	0.17	0.17	0.43	0.43	0.41	0.30	0.22	0.15	0.85	0.36	24
20	0.17	0.30	0.22	0.28	0.33	0.36	S	0.33	0.30	0.30	0.25	0.22	0.17	0.20	0.17	0.17	0.17	0.20	0.17	0.22	0.36	0.17	0.30	0.17	0.17	0.36	0.24	24
21	0.17	0.17	0.17	0.22	0.41	S	0.25	0.25	0.25	0.20	0.15	0.17	0.17	0.17	0.15	0.17	0.15	0.17	0.15	0.20	0.20	0.23	0.25	0.20	0.15	0.41	0.21	24
22	0.15	0.17	0.20	0.20	S	0.25	0.28	0.28	0.15	0.17	0.15	0.14	0.17	0.17	0.17	0.15	0.17	0.20	0.17	0.17	0.25	0.28	0.25	0.36	0.14	0.36	0.20	24
23	0.30	0.30	0.51	S	0.43	0.38	0.41	0.30	0.28	0.25	0.22	0.20	0.17	0.20	0.22	0.17	0.17	0.17	0.17	0.15	0.28	0.36	0.25	0.28	0.15	0.51	0.27	24
24	0.28	0.28	S	0.33	0.36	0.30	0.33	0.25	0.28	0.20	0.20	0.20	0.20	0.17	0.12	0.15	0.15	0.15	0.17	0.17	0.25	0.25	0.30	0.28	0.12	0.36	0.23	24
25	0.25	S	0.22	0.20	0.20	0.23	0.20	0.20	0.20	0.15	0.14	0.17	0.15	0.14	0.14	0.15	0.17	0.15	0.17	0.17	0.15	0.15	0.17	0.17	0.14	0.25	0.18	24
26	S	0.17	0.17	0.20	0.20	0.22	0.25	0.25	0.41	0.33	0.22	0.20	0.22	0.17	0.12	P	0.12	0.17	0.17	0.20	0.20	0.20	0.30	S	0.12	0.41	0.21	23
27	0.56	0.38	0.38	0.46	0.54	0.41	0.38	0.36	0.30	0.30	0.28	0.15	0.12	0.20	0.26	0.20	0.28	0.33	0.28	0.20	0.41	0.23	S	0.20	0.12	0.56	0.31	24
28	0.20	0.17	0.17	0.17	0.23	0.17	0.18	0.20	P	0.20	0.18	0.17	0.12	0.15	0.20	0.15	0.17	0.15	0.15	0.15	0.15	S	0.25	0.20	0.12	0.25	0.18	23
29	0.22	0.20	0.25	0.46	0.67	0.57	0.36	0.25	P	0.25	0.20	0.17	0.17	0.15	0.12	0.15	0.15	0.15	0.15	0.15	S	0.28	0.22	0.23	0.12	0.67	0.25	23
30	0.22	0.28	0.30	0.38	0.25	0.41	0.38	0.33	0.46	0.20	0.22	0.15	0.22	0.12	0.12	0.12	0.09	0.09	0.15	S	0.12	0.17	0.17	P	0.09	0.46	0.23	23
HOURLY MAX	0.56	0.49	0.75	0.59	1.06	0.98	0.80	0.56	0.46	0.46	0.30	0.38	0.54	0.67	0.26	0.20	0.28	0.33	0.28	0.43	0.43	0.49	0.43	0.36				
HOURLY AVG	0.23	0.25	0.28	0.33	0.44	0.42	0.36	0.30	0.26	0.23	0.20	0.19	0.18	0.17	0.15	0.14	0.14	0.15	0.15	0.16	0.20	0.22	0.23	0.22				


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	676
MAXIMUM INSTANTANEOUS VALUE:	1.06 ppb @ HOUR 4 ON DAY 17
IZS CALIBRATION TIME:	32 hrs
MONTHLY CALIBRATION TIME:	5 hrs
STANDARD DEVIATION:	0.13
OPERATIONAL TIME:	713 hrs

TOTAL REDUCED SULPHUR Instantaneous Maximum (TRS ppb)




Wind: PRAMP_842
 Poll.: PRAMP_842-TRS[ppb]
 Monthly: 17/06
 Type: PollutionRose
 Direction: Blowing From (Wind Frequency)
 Based On 1 Hr.

Calm: 7.96% Calm Avg: 0.22 [ppb]


Direction	0-1	1-3	3-10	>10.0	Total
N	6.1	0.0	0.0	0.0	6.1
NE	5.3	0.0	0.0	0.0	5.3
E	13.3	0.0	0.0	0.0	13.3
SE	12.0	0.0	0.0	0.0	12.0
S	8.4	0.0	0.0	0.0	8.4
SW	17.0	0.0	0.0	0.0	17.0
W	20.0	0.0	0.0	0.0	20.0
NW	10.0	0.0	0.0	0.0	10.0
Summary	92.0	0.0	0.0	0.0	92.0

% Icon Classes (ppb) 92 0-1 0 1-3 0 3-10 0 >10.0

PRAMP_842 Poll.: PRAMP_842-TRS[ppb] 2017/06/01 00:00 - 2017/06/30 23:00 Calm: 7.96% Calm Poll Avg: 0.22[ppb]



TRS[ppb] Calibration: PRAMP_842 Monthly: 17/06 Type: Span



■ Span Meas
 — Span Ref
 — Span Low
 — Span High

TOTAL HYDROCARBON




TOTAL HYDROCARBONS Hourly Averages (THC ppm)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.		
DAY 1	1.96	1.96	S	1.98	1.98	1.98	1.96	1.95	1.94	1.93	1.92	1.91	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.93	1.91	1.91	1.90	1.98	1.93	24	
2	1.91	S	1.93	1.93	1.94	1.94	1.94	1.95	1.93	1.91	1.92	1.92	1.93	1.93	1.92	1.92	1.92	1.92	1.92	1.92	1.93	1.93	1.95	1.96	1.93	1.91	1.96	1.93	24
3	S	1.95	1.95	1.97	1.97	1.98	1.96	1.95	1.93	1.93	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.93	1.93	1.93	S	1.92	1.98	1.94	24
4	1.94	1.96	2.02	2.03	2.01	1.99	2.00	1.96	1.94	1.94	1.94	1.94	1.94	1.94	1.93	1.93	1.92	1.92	1.92	1.92	1.93	1.93	1.94	S	1.95	1.92	2.03	1.95	24
5	1.96	1.96	1.99	2.01	2.00	2.03	2.00	1.97	1.96	1.95	1.95	1.94	1.94	1.94	1.94	1.94	1.93	1.94	1.94	1.94	1.95	1.95	S	1.98	1.97	1.93	2.03	1.96	24
6	2.00	1.99	2.02	2.02	2.03	2.01	2.00	1.96	1.95	1.94	C	C	C	C	C	C	1.87	1.87	1.88	1.88	S	1.93	1.95	1.92	1.87	2.03	1.96	24	
7	1.97	2.03	2.10	2.10	2.00	2.02	1.96	1.93	1.94	1.91	1.88	1.89	1.88	1.88	1.88	1.88	1.88	1.89	1.89	S	1.92	1.94	1.96	1.96	1.88	2.10	1.94	24	
8	1.91	1.92	1.92	1.94	1.92	1.93	1.93	1.93	1.91	1.91	1.89	1.88	1.87	1.88	1.87	1.88	1.87	1.88	1.87	S	1.88	1.91	1.90	1.93	1.97	1.87	1.97	1.91	24
9	1.97	1.92	1.93	1.93	1.91	1.93	1.91	1.89	1.89	1.88	1.88	1.88	1.87	1.87	1.86	1.86	1.85	S	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.85	24
10	1.85	1.85	1.85	1.86	1.87	1.88	1.86	1.87	1.86	1.85	1.85	1.85	1.85	1.84	1.85	1.84	S	1.84	1.84	1.84	1.84	1.84	1.85	1.85	1.85	1.84	1.88	1.85	24
11	1.85	1.85	1.84	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.86	1.86	1.85	1.85	1.85	S	1.84	1.85	1.85	1.84	1.85	1.85	1.85	1.86	1.88	1.84	1.88	1.85	24
12	1.88	1.86	1.85	1.86	1.86	1.88	1.88	1.88	1.87	1.86	1.85	1.84	S	1.84	1.84	1.83	1.83	1.83	1.83	1.83	1.84	1.84	1.86	1.86	1.87	1.83	1.88	1.85	24
13	1.84	1.84	1.83	1.85	1.87	1.88	1.86	1.87	1.85	1.84	1.84	1.84	S	1.84	1.83	1.84	1.83	1.83	1.83	1.84	1.84	1.84	1.84	1.79	1.79	1.88	1.84	24	
14	1.82	1.85	1.85	1.87	1.88	1.87	1.87	1.87	C1	C1	C1	Y	Y	Y	Y	C1	C1	C1	1.87	1.95	1.93	1.90	1.90	1.87	1.82	1.95	1.88	15	
15	1.91	1.99	1.89	1.88	1.88	1.89	1.90	1.88	1.87	1.86	1.86	S	1.87	1.86	1.86	1.86	1.86	1.86	1.86	1.85	1.86	1.86	1.86	1.86	1.86	1.85	1.99	1.88	24
16	1.84	1.87	1.87	1.87	1.88	1.86	1.85	1.84	1.83	1.82	S	1.83	1.82	1.82	1.82	1.82	1.82	1.82	1.82	1.83	1.83	1.83	1.83	1.84	1.82	1.82	1.88	1.84	24
17	1.83	1.84	1.86	1.88	1.91	1.86	1.85	1.85	1.84	S	1.83	1.83	1.83	1.83	1.83	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.85	1.84	1.85	1.83	1.91	1.85	24
18	1.86	1.87	1.88	1.88	1.89	1.89	1.89	1.88	S	1.86	1.85	1.85	1.85	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.85	1.86	1.88	1.84	1.89	1.86	24
19	1.91	1.90	1.89	1.90	1.99	1.96	1.91	S	1.86	1.85	1.85	1.85	1.84	1.84	1.84	1.84	1.84	1.84	1.81	1.84	1.87	1.87	1.88	1.91	1.86	1.81	1.99	1.87	24
20	1.90	2.00	1.96	1.94	2.25	2.00	S	1.88	1.84	1.86	1.83	1.83	1.82	1.81	1.81	1.81	1.82	1.82	1.80	1.83	1.85	1.82	1.83	1.82	1.80	2.25	1.88	24	
21	1.83	1.83	1.83	1.83	1.85	S	1.82	1.85	1.85	1.85	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.85	1.85	1.85	1.82	1.85	1.84	24
22	1.85	1.86	1.86	1.87	S	1.87	1.88	1.87	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.85	1.85	1.85	1.85	1.85	1.82	1.87	1.88	1.89	1.82	1.89	1.86	24	
23	1.90	1.91	2.01	S	2.03	2.04	2.05	1.92	1.88	1.87	1.86	1.86	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.86	1.87	1.88	1.90	1.92	1.85	2.05	1.90	24
24	1.91	1.89	S	1.92	1.93	1.93	1.91	1.86	1.88	1.88	1.87	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.87	1.88	2.01	2.00	1.86	2.01	1.89	24
25	1.92	S	1.85	1.86	1.90	1.90	1.90	1.89	1.88	1.87	1.87	1.86	1.86	1.86	1.84	1.83	1.85	1.85	1.88	1.87	1.87	1.87	1.88	1.89	1.83	1.92	1.87	24	
26	S	1.89	1.86	1.85	1.87	1.90	1.90	1.90	1.90	1.90	1.88	1.88	1.87	1.83	1.84	1.82	1.83	1.82	1.81	1.82	1.82	1.83	1.82	S	1.81	1.90	1.86	24	
27	1.84	1.84	1.83	1.82	1.81	1.84	1.84	1.83	1.79	1.82	1.83	1.81	1.79	1.82	1.82	1.82	1.82	1.82	1.82	1.83	1.82	1.83	1.83	S	1.84	1.79	1.84	1.82	24
28	1.82	1.83	1.83	1.79	1.82	1.82	1.84	1.85	P	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.86	1.86	1.85	1.86	1.88	S	1.87	1.87	1.79	1.88	1.85	23	
29	1.86	1.87	1.88	1.90	1.91	1.93	1.92	1.91	1.90	1.89	1.88	1.87	1.86	1.87	1.86	1.86	1.86	1.86	1.86	1.84	1.84	S	1.89	1.86	1.86	1.84	1.93	1.88	24
30	1.88	1.88	1.90	2.03	1.97	1.90	1.88	1.86	1.87	1.86	1.86	1.85	1.85	1.85	1.84	1.84	1.84	1.83	1.83	S	1.83	1.84	1.85	1.85	1.83	2.03	1.87	24	
HOURLY MAX	2.00	2.03	2.10	2.10	2.25	2.04	2.05	2.00	1.96	1.95	1.95	1.94	1.94	1.94	1.94	1.94	1.93	1.94	1.94	1.94	1.95	1.95	1.95	2.01	2.00				
HOURLY AVG	1.89	1.90	1.90	1.91	1.93	1.92	1.91	1.89	1.88	1.88	1.87	1.87	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.87	1.87	1.87	1.89	1.89				

STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

24 HR AVERAGES June 2017




MONTHLY SUMMARY


NUMBER OF NON-ZERO READINGS:	674				
MINIMUM 1-HR AVERAGE:	1.79	ppm @ HOUR	23	ON DAY	
MAXIMUM 1-HR AVERAGE:	2.25	ppm @ HOUR	4	ON DAY	
MAXIMUM 24-HR AVERAGE:	1.96	ppm		ON DAY	
IZS CALIBRATION TIME:	31	hrs	OPERATIONAL TIME:	710	hrs
MONTHLY CALIBRATION TIME:	5	hrs	AMD OPERATION UPTIME:	98.6	%
STANDARD DEVIATION:	0.05		MONTHLY AVERAGE:	1.88	ppm



TOTAL HYDROCARBONS Hourly Averages (THC ppm)



TOTAL HYDROCARBONS Instantaneous Maximum (THC ppm)



Wind: PRAMP_842
 Poll.: PRAMP_842-THC55[ppm]
 Monthly: 17/06
 Type: PollutionRose
 Direction: Blowing From (Wind Frequency)
 Based On 1 Hr.

Calm: 8.37%

Calm Avg: 1.89 [ppm]

Direction	0-2	2-3	3-5	5-10	>10.0	Total
N	6.2	0.0	0.0	0.0	0.0	6.2
NE	5.2	0.0	0.0	0.0	0.0	5.2
E	10.7	1.4	0.0	0.0	0.0	12.2
SE	10.1	1.9	0.0	0.0	0.0	12.0
S	8.1	0.3	0.0	0.0	0.0	8.4
SW	17.4	0.0	0.0	0.0	0.0	17.4
W	20.2	0.0	0.0	0.0	0.0	20.2
NW	10.1	0.0	0.0	0.0	0.0	10.1
Summary	88.0	3.6	0.0	0.0	0.0	91.6

THC55[ppm] Calibration: PRAMP_842 Monthly; 17/06 Type: Span



Span Meas Span Ref Span Low Span High

METHANE




METHANE Hourly Averages (CH₄ ppm)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.		
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.			
DAY 1	1.96	1.96	S	1.98	1.98	1.98	1.96	1.95	1.94	1.93	1.92	1.91	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.93	1.91	1.91	1.90	1.98	1.93	24		
2	1.91	S	1.93	1.93	1.94	1.94	1.94	1.95	1.93	1.91	1.92	1.92	1.93	1.93	1.92	1.92	1.92	1.92	1.92	1.92	1.93	1.93	1.95	1.96	1.93	1.91	1.96	1.93	24	
3	S	1.95	1.95	1.97	1.97	1.98	1.96	1.95	1.93	1.93	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.93	1.93	1.93	S	1.92	1.98	1.94	24	
4	1.94	1.96	2.02	2.03	2.01	1.99	2.00	1.96	1.94	1.94	1.94	1.94	1.94	1.94	1.93	1.93	1.92	1.92	1.92	1.92	1.93	1.93	1.94	S	1.95	1.92	2.03	1.95	24	
5	1.96	1.96	1.99	2.01	2.00	2.03	1.99	1.97	1.96	1.95	1.95	1.94	1.94	1.94	1.94	1.94	1.93	1.94	1.94	1.95	1.95	S	1.98	1.97	1.93	2.03	1.96	24		
6	2.00	1.99	2.02	2.02	2.02	2.03	2.01	2.00	1.96	1.95	1.94	C	C	C	C	C	1.87	1.87	1.88	S	1.92	1.95	1.92	1.87	2.03	1.96	24			
7	1.97	2.03	2.10	2.09	2.00	2.02	1.96	1.93	1.94	1.91	1.88	1.89	1.88	1.88	1.88	1.88	1.88	1.89	1.89	S	1.92	1.94	1.96	1.95	1.88	2.10	1.94	24		
8	1.91	1.92	1.92	1.94	1.92	1.93	1.93	1.93	1.91	1.90	1.89	1.88	1.87	1.88	1.87	1.87	1.87	1.87	1.88	S	1.88	1.90	1.90	1.93	1.97	1.87	1.97	1.90	24	
9	1.97	1.92	1.93	1.92	1.91	1.92	1.91	1.89	1.89	1.88	1.88	1.88	1.87	1.87	1.86	1.86	1.85	S	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.85	24	
10	1.85	1.85	1.85	1.86	1.87	1.88	1.86	1.87	1.86	1.85	1.85	1.85	1.85	1.84	1.85	1.84	S	1.84	1.84	1.84	1.84	1.84	1.85	1.85	1.85	1.84	1.88	1.85	24	
11	1.85	1.85	1.84	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.86	1.86	1.85	1.85	1.85	S	1.84	1.85	1.85	1.84	1.85	1.85	1.86	1.88	1.84	1.88	1.85	24		
12	1.88	1.86	1.85	1.86	1.86	1.88	1.88	1.88	1.87	1.86	1.85	1.84	1.85	1.84	S	1.84	1.84	1.83	1.83	1.83	1.84	1.84	1.86	1.86	1.87	1.83	1.88	1.85	24	
13	1.84	1.84	1.83	1.85	1.87	1.88	1.86	1.87	1.85	1.84	1.84	1.84	1.84	S	1.84	1.83	1.83	1.83	1.83	1.83	1.84	1.84	1.84	1.84	1.79	1.79	1.88	1.84	24	
14	1.82	1.85	1.85	1.87	1.88	1.87	1.87	1.87	C1	C1	C1	Y	Y	Y	Y	C1	C1	C1	1.87	1.87	1.95	1.93	1.90	1.90	1.87	1.82	1.95	1.88	15	
15	1.91	1.99	1.89	1.88	1.88	1.89	1.90	1.88	1.87	1.86	1.86	S	1.87	1.86	1.86	1.86	1.86	1.86	1.86	1.85	1.86	1.86	1.86	1.86	1.86	1.86	1.85	1.99	1.88	24
16	1.84	1.87	1.87	1.87	1.88	1.86	1.85	1.84	1.83	1.82	S	1.83	1.82	1.82	1.82	1.82	1.82	1.82	1.82	1.83	1.83	1.83	1.83	1.83	1.84	1.82	1.82	1.88	1.84	24
17	1.83	1.84	1.86	1.88	1.91	1.86	1.85	1.85	1.84	S	1.83	1.83	1.83	1.83	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.85	1.84	1.85	1.83	1.91	1.85	24	
18	1.86	1.87	1.88	1.88	1.89	1.89	1.89	1.88	S	1.86	1.85	1.85	1.85	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.85	1.86	1.88	1.84	1.89	1.86	24
19	1.91	1.90	1.89	1.90	1.99	1.96	1.91	S	1.86	1.85	1.85	1.85	1.84	1.84	1.84	1.84	1.84	1.84	1.81	1.84	1.87	1.87	1.88	1.91	1.86	1.81	1.99	1.87	24	
20	1.90	2.00	1.96	1.94	2.25	2.00	S	1.88	1.84	1.86	1.83	1.83	1.82	1.81	1.81	1.81	1.82	1.82	1.80	1.83	1.85	1.82	1.83	1.82	1.80	2.25	1.88	24		
21	1.83	1.83	1.83	1.83	1.85	S	1.82	1.85	1.85	1.85	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.84	1.85	1.85	1.85	1.82	1.85	1.84	24	
22	1.85	1.86	1.86	1.87	S	1.87	1.88	1.87	1.86	1.86	1.86	1.86	1.85	1.86	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.82	1.87	1.88	1.89	1.82	1.89	1.86	24	
23	1.90	1.91	2.00	S	2.03	2.04	2.05	1.92	1.88	1.87	1.86	1.85	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.86	1.87	1.90	1.92	1.85	2.05	1.90	24	
24	1.91	1.89	S	1.92	1.93	1.93	1.91	1.86	1.88	1.88	1.87	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.87	1.88	2.01	2.00	1.86	2.01	1.89	24	
25	1.92	S	1.85	1.86	1.90	1.90	1.90	1.89	1.88	1.87	1.87	1.86	1.86	1.86	1.84	1.83	1.85	1.85	1.88	1.87	1.87	1.87	1.88	1.89	1.83	1.92	1.87	24		
26	S	1.89	1.85	1.85	1.87	1.90	1.90	1.90	1.90	1.90	1.89	1.88	1.87	1.83	1.83	1.82	1.83	1.82	1.81	1.82	1.82	1.83	1.82	S	1.81	1.90	1.86	24		
27	1.84	1.84	1.83	1.82	1.81	1.84	1.84	1.83	1.79	1.82	1.82	1.81	1.79	1.82	1.82	1.82	1.82	1.82	1.82	1.83	1.82	1.83	1.83	S	1.84	1.79	1.84	1.82	24	
28	1.82	1.83	1.83	1.79	1.82	1.82	1.84	1.85	P	1.86	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.86	1.85	1.86	1.88	S	1.87	1.87	1.79	1.88	1.85	23		
29	1.86	1.87	1.88	1.90	1.91	1.93	1.92	1.91	1.90	1.89	1.88	1.87	1.86	1.87	1.86	1.86	1.86	1.86	1.86	1.84	1.84	S	1.89	1.86	1.86	1.84	1.93	1.88	24	
30	1.88	1.88	1.90	2.03	1.97	1.90	1.88	1.86	1.87	1.86	1.86	1.85	1.85	1.85	1.84	1.84	1.84	1.83	1.83	S	1.83	1.84	1.85	1.85	1.83	2.03	1.87	24		
HOURLY MAX	2.00	2.03	2.10	2.09	2.25	2.04	2.05	2.00	1.96	1.95	1.95	1.94	1.94	1.94	1.94	1.94	1.93	1.94	1.94	1.94	1.95	1.95	1.95	2.01	2.00					
HOURLY AVG	1.89	1.90	1.90	1.91	1.93	1.92	1.91	1.89	1.88	1.88	1.87	1.87	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.86	1.87	1.87	1.87	1.89	1.88					

STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE


24 HR AVERAGES June 2017



MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	674
MINIMUM 1-HR AVERAGE:	1.79 ppm @ HOUR 23 ON DAY 13
MAXIMUM 1-HR AVERAGE:	2.25 ppm @ HOUR 4 ON DAY 20
MAXIMUM 24-HR AVERAGE:	1.96 ppm ON DAY 5
IZS CALIBRATION TIME:	31 hrs
MONTHLY CALIBRATION TIME:	5 hrs
OPERATIONAL TIME:	710 hrs
AMD OPERATION UPTIME:	98.6 %
STANDARD DEVIATION:	0.05
MONTHLY AVERAGE:	1.88 ppm

METHANE Hourly Averages (CH₄ ppm)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
Three Creeks 842b Station - June 2017

METHANE MAX Instantaneous Maximum (CH₄ ppm)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59					
DAY 1	2.00	1.97	S	2.06	2.04	2.00	1.99	1.96	1.96	1.95	1.94	1.92	1.92	1.92	1.91	1.91	1.91	1.91	1.91	1.91	1.91	2.01	1.93	1.93	1.91	2.06	1.95	24	
2	1.93	S	1.96	1.95	1.96	1.97	1.95	1.97	1.95	1.92	1.93	1.94	1.95	1.94	1.93	1.94	1.94	1.93	1.94	1.94	1.96	1.97	1.97	1.95	1.92	1.97	1.95	24	
3	S	1.99	1.98	2.00	2.00	2.01	P	1.96	1.94	P	1.94	1.93	1.93	1.93	1.94	1.93	1.94	1.93	1.94	1.93	1.94	1.94	1.95	1.94	S	1.93	2.01	1.95	22
4	1.96	2.01	2.12	2.06	2.06	2.01	2.02	1.99	1.96	1.95	1.95	1.95	1.95	1.95	1.95	1.94	1.94	1.94	1.93	1.95	1.94	1.95	S	2.00	1.93	2.12	1.98	24	
5	1.99	1.97	2.05	2.07	2.05	2.07	2.02	1.99	1.97	1.96	1.97	1.95	1.96	1.95	1.95	1.94	1.94	1.99	1.95	1.96	1.97	S	2.01	2.02	1.94	2.07	1.99	24	
6	2.03	2.01	2.04	2.04	2.04	2.05	2.03	2.03	1.97	1.96	2.00	C	C	C	C	C	1.88	1.88	1.89	1.90	S	2.01	2.00	1.94	1.88	2.05	1.98	24	
7	2.02	2.08	2.30	2.19	2.06	2.05	2.04	1.94	1.97	1.95	1.90	1.95	1.89	1.89	1.89	1.90	1.91	1.91	1.90	S	1.94	1.96	1.98	1.99	1.89	2.30	1.98	24	
8	1.93	1.93	1.93	1.97	P	1.95	1.95	1.94	1.93	1.92	1.91	1.89	1.89	1.90	1.90	1.89	1.88	1.90	S	1.89	1.94	1.92	1.98	2.00	1.88	2.00	1.92	23	
9	2.00	1.94	1.96	1.95	1.94	1.94	1.92	1.91	1.91	1.91	1.90	1.89	1.89	1.89	1.88	1.87	1.87	S	1.86	1.86	1.86	1.86	1.86	1.87	1.86	2.00	1.90	24	
10	1.86	1.86	1.88	1.88	1.88	1.89	1.91	1.89	1.88	1.88	1.86	1.86	1.86	1.86	1.86	1.86	S	1.85	1.86	1.85	1.85	1.86	1.86	1.86	1.86	1.85	1.91	1.87	24
11	1.86	1.86	1.87	1.93	1.90	1.88	1.86	1.88	1.87	1.87	1.87	1.88	1.87	1.87	1.86	S	1.86	1.86	1.87	1.86	1.86	1.86	1.86	1.88	1.91	1.86	1.93	1.87	24
12	1.90	1.88	1.87	1.87	1.88	1.89	1.90	1.90	1.88	1.88	1.86	1.85	1.86	1.84	S	1.85	1.85	1.85	1.83	1.84	1.86	1.89	1.89	1.89	1.84	1.93	1.87	24	
13	1.87	1.86	1.84	1.88	1.88	1.91	1.88	1.88	1.87	1.86	1.85	1.85	1.86	S	1.85	1.88	1.86	1.85	1.84	1.85	1.85	1.86	1.85	1.84	1.84	1.91	1.86	24	
14	1.86	1.89	1.86	1.88	1.92	1.88	1.88	1.89	1.89	C1	C1	C1	Y	Y	Y	C1	C1	C1	1.88	2.01	2.00	1.93	1.95	1.90	1.86	2.01	1.91	15	
15	1.96	2.03	1.92	1.88	1.89	1.89	1.90	1.89	1.88	1.87	1.87	S	1.87	1.87	1.87	1.86	1.86	1.87	1.86	1.87	1.86	1.87	1.88	1.86	1.86	2.03	1.89	24	
16	1.89	1.88	1.88	1.90	1.88	1.87	1.87	1.86	1.83	S	1.84	1.83	1.82	1.82	1.82	1.83	1.83	1.84	1.84	1.84	1.85	1.88	1.85	1.82	1.90	1.85	24		
17	1.85	1.90	1.90	1.92	2.01	1.89	1.87	1.86	1.86	S	1.85	1.85	1.86	1.86	1.86	1.86	1.85	1.86	1.85	1.87	1.86	1.88	1.85	1.86	1.85	2.01	1.87	24	
18	1.87	1.87	1.89	1.89	1.90	1.90	1.89	S	1.87	1.85	1.85	1.85	1.85	1.85	1.84	1.85	1.84	1.85	1.85	1.86	1.86	1.96	1.91	1.89	1.84	1.96	1.87	24	
19	1.97	1.92	1.90	1.94	2.06	2.02	1.94	S	1.86	1.86	1.86	1.87	1.85	1.92	1.84	1.86	1.86	1.85	1.87	1.88	1.89	1.91	1.93	1.93	1.85	2.06	1.90	24	
20	1.92	2.40	2.22	2.16	2.42	2.30	S	1.89	1.88	1.87	1.85	1.84	1.84	1.82	1.83	1.82	1.82	1.83	1.83	1.85	1.87	1.85	1.84	1.83	1.82	2.42	1.95	24	
21	1.97	1.89	1.84	1.84	1.89	S	1.86	1.87	1.86	1.86	1.85	1.85	1.85	1.85	1.85	1.85	2.02	1.85	1.85	1.97	1.87	1.86	1.86	1.84	2.02	1.87	24		
22	1.86	1.86	1.87	1.88	S	1.88	1.89	1.88	1.87	1.87	1.87	1.87	1.86	1.86	1.87	1.87	1.87	1.87	1.87	1.87	1.91	1.91	1.90	1.91	1.86	1.91	1.88	24	
23	1.94	1.94	2.13	S	2.12	2.12	2.09	2.01	1.90	1.88	1.87	1.86	1.87	1.87	1.86	1.86	1.86	1.87	1.87	1.87	1.87	1.87	1.87	2.06	1.86	2.13	1.94	24	
24	1.95	1.95	S	1.95	1.95	1.94	1.93	1.89	1.88	1.88	1.87	1.87	1.87	1.87	1.86	1.87	1.86	1.87	1.87	1.87	1.88	1.88	1.91	2.20	2.13	1.86	2.20	1.92	24
25	1.97	S	1.91	1.91	1.91	1.91	1.90	1.90	1.89	1.88	1.88	1.87	1.87	1.93	1.87	1.87	1.87	1.87	1.87	1.88	1.88	1.87	1.88	1.88	1.89	1.87	1.97	1.89	24
26	S	1.90	1.89	1.90	1.94	1.91	1.90	1.90	1.91	1.90	1.90	1.90	1.89	1.87	1.85	P	1.84	1.85	1.83	1.83	1.83	1.85	1.84	S	1.83	1.94	1.88	23	
27	1.85	1.85	1.85	1.87	1.85	1.85	1.85	1.83	1.84	1.84	1.84	1.82	1.83	1.83	1.83	1.84	1.82	1.83	1.85	1.83	1.85	1.84	S	1.85	1.82	1.87	1.84	24	
28	1.84	1.83	1.83	1.83	1.83	1.84	1.85	1.86	P	1.86	1.86	1.87	1.86	1.86	1.86	1.86	1.86	1.87	1.97	1.88	1.91	S	1.88	1.88	1.83	1.97	1.86	23	
29	1.87	1.88	1.89	1.91	1.92	1.94	1.93	1.91	P	1.90	1.89	1.87	1.88	1.88	1.87	1.87	1.87	1.87	1.87	1.86	1.85	S	1.90	1.89	1.88	1.85	1.94	1.89	23
30	1.89	1.90	2.02	2.08	2.02	1.92	1.90	1.89	1.89	1.87	1.87	1.85	1.85	1.85	1.85	1.85	1.85	1.85	1.84	S	1.84	1.86	1.87	P	1.84	2.08	1.89	23	
HOURLY MAX	2.03	2.40	2.30	2.19	2.42	2.30	2.09	2.03	1.97	1.96	2.00	1.95	1.96	1.95	1.95	1.94	1.94	2.02	1.97	2.01	2.00	2.01	2.20	2.13					
HOURLY AVG	1.92	1.94	1.95	1.95	1.97	1.96	1.93	1.91	1.90	1.89	1.89	1.88	1.88	1.88	1.87	1.87	1.87	1.88	1.88	1.88	1.89	1.90	1.92	1.92					


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	668
MAXIMUM INSTANTANEOUS VALUE:	2.42 ppm @ HOUR 4 ON DAY 20
IZS CALIBRATION TIME:	31 hrs
MONTHLY CALIBRATION TIME:	5 hrs
STANDARD DEVIATION:	0.07
OPERATIONAL TIME:	704 hrs

METHANE MAX Instantaneous Maximum (CH₄ ppm)



Wind: PRAMP_842
 Poll.: PRAMP_842-CH4[ppm]
 Monthly: 17/06
 Type: PollutionRose
 Direction: Blowing From (Wind Frequency)
 Based On 1 Hr.


Calm: 8.37%

Calm Avg: 1.89 [ppm]

Direction	0-2	2-3	3-5	5-10	>10.0	Total
N	6.2	0.0	0.0	0.0	0.0	6.2
NE	5.2	0.0	0.0	0.0	0.0	5.2
E	10.7	1.4	0.0	0.0	0.0	12.2
SE	10.1	1.9	0.0	0.0	0.0	12.0
S	8.1	0.3	0.0	0.0	0.0	8.4
SW	17.4	0.0	0.0	0.0	0.0	17.4
W	20.2	0.0	0.0	0.0	0.0	20.2
NW	10.1	0.0	0.0	0.0	0.0	10.1
Summary	88.0	3.6	0.0	0.0	0.0	91.6

% Icon Classes (ppm) 88 0-2 4 2-3 0 3-5 0 5-10 0 >10.0

PRAMP_842 Poll.: PRAMP_842-CH4[ppm] 2017/06/01 00:00 - 2017/06/30 23:00 Calm: 8.37% Calm Poll Avg: 1.89[ppm]



CH4[ppm] Calibration: PRAMP_842 Monthly: 17/06 Type: Span



■ Span Meas
 — Span Ref
 — Span Low
 — Span High

NON-METHANE HYDROCARBON




NON-METHANE HYDROCARBONS Hourly Averages (NMHC ppm)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.	
DAY 1	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
2	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
3	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	24
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	24
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	24
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	C	C	C	C	C	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	24
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	C1	C1	C1	Y	Y	Y	C1	C1	C1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	15
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
20	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
21	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
22	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
23	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
24	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
25	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
26	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	24
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	24
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	P	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	23
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	24
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24
HOURLY MAX	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
HOURLY AVG	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				

STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

24 HR AVERAGES June 2017




MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	0			
MINIMUM 1-HR AVERAGE:	0.00	ppm @ HOUR	0	ON DAY 1
MAXIMUM 1-HR AVERAGE:	0.00	ppm @ HOUR	0	ON DAY 1
MAXIMUM 24-HR AVERAGE:	0.00	ppm		ON DAY 1
IZS CALIBRATION TIME:	31	hrs	OPERATIONAL TIME:	710 hrs
MONTHLY CALIBRATION TIME:	5	hrs	AMD OPERATION UPTIME:	98.6 %
STANDARD DEVIATION:	0.00		MONTHLY AVERAGE:	0.00 ppm



NON-METHANE HYDROCARBONS Hourly Averages (NMHC ppm)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
Three Creeks 842b Station - June 2017

NON-METHANE HYDROCARBONS Instantaneous Maximum (NMHC ppm)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59					
DAY 1	0.10	0.05	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.10	0.00	0.00	0.00	0.00	0.10	0.01	24
2	0.00	S	0.00	0.00	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.06	0.06	0.00	0.00	0.00	0.00	0.00	0.08	0.01	24
3	S	0.00	0.00	0.00	0.03	0.01	P	0.00	0.00	P	0.03	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.04	0.01	22	
4	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.08	0.01	0.00	0.00	0.01	0.00	0.00	0.00	0.00	S	0.00	0.00	0.08	0.01	24	
5	0.00	0.00	0.00	0.00	0.00	0.00	0.16	0.01	0.00	0.00	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	S	0.00	0.00	0.00	0.16	0.01	24	
6	0.01	0.00	0.09	0.02	0.00	0.00	0.00	0.01	0.01	0.07	0.08	C	C	C	C	C	0.01	0.00	0.14	0.00	S	0.10	0.00	0.00	0.00	0.14	0.03	24	
7	0.14	0.14	0.00	0.09	0.00	0.15	0.01	0.00	0.00	0.04	0.03	0.01	0.15	0.00	0.14	0.03	0.03	0.13	0.09	S	0.07	0.14	0.16	0.17	0.00	0.17	0.07	24	
8	0.04	0.00	0.01	0.06	P	0.00	0.00	0.12	0.00	0.07	0.00	0.02	0.02	0.18	0.03	0.11	0.01	0.18	S	0.01	0.11	0.06	0.00	0.14	0.00	0.18	0.05	23	
9	0.15	0.00	0.03	0.22	0.00	0.17	0.01	0.00	0.03	0.00	0.08	0.00	0.00	0.09	0.01	0.00	0.00	S	0.04	0.00	0.00	0.03	0.00	0.00	0.00	0.22	0.04	24	
10	0.00	0.05	0.06	0.12	0.00	0.13	0.02	0.00	0.01	0.00	0.05	0.01	0.08	0.02	0.01	0.01	S	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.13	0.03	24	
11	0.00	0.08	0.00	0.01	0.06	0.00	0.00	0.07	0.00	0.12	0.00	0.00	0.06	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.00	0.00	0.12	0.02	24	
12	0.03	0.00	0.00	0.01	0.01	0.00	0.00	0.01	0.01	0.00	0.02	0.01	0.00	0.00	S	0.00	0.01	0.01	0.00	0.03	0.00	0.02	0.01	0.00	0.00	0.03	0.01	24	
13	0.01	0.00	0.10	0.00	0.01	0.00	0.03	0.01	0.00	0.00	0.00	0.00	0.02	S	0.00	0.00	0.07	0.00	0.00	0.00	0.07	0.00	0.00	0.06	0.00	0.10	0.02	24	
14	0.08	0.00	0.00	0.00	0.00	0.00	0.01	0.17	0.07	C1	C1	C1	Y	Y	Y	C1	C1	C1	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.17	0.02	15	
15	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.02	S	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.05	0.00	24	
16	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.02	0.00	0.02	0.00	24	
17	0.00	0.00	0.00	0.00	0.00	0.02	0.02	0.00	0.00	S	0.00	0.00	0.00	0.01	0.03	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.05	0.00	0.05	0.01	24	
18	0.11	0.02	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.00	0.00	0.01	0.01	0.01	0.00	0.03	0.00	0.00	0.11	0.01	24	
19	0.02	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.04	0.00	0.00	0.02	0.00	0.01	0.00	0.00	0.00	0.00	0.04	0.00	24	
20	0.01	0.02	0.00	0.00	0.11	0.00	S	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.11	0.01	24	
21	0.00	0.02	0.00	0.01	0.00	S	0.01	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	24	
22	0.00	0.00	0.00	0.01	S	0.00	0.00	0.00	0.00	0.00	0.03	0.01	0.00	0.01	0.00	0.02	0.00	0.01	0.00	0.00	0.01	0.00	0.01	0.00	0.00	0.03	0.00	24	
23	0.00	0.00	0.01	S	0.00	0.00	0.01	0.00	0.00	0.01	0.00	0.00	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.08	0.01	24	
24	0.00	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.00	0.04	0.00	24	
25	0.00	S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	24	
26	S	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	P	0.01	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.01	0.00	23	
27	0.00	0.00	0.02	0.01	0.00	0.01	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	S	0.00	0.00	0.02	0.00	24
28	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	P	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.09	0.00	23	
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	P	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.01	0.00	0.01	0.00	23	
30	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	S	0.00	0.00	0.03	P	0.00	0.03	0.00	23
HOURLY MAX	0.15	0.14	0.10	0.22	0.11	0.17	0.16	0.17	0.07	0.12	0.08	0.04	0.15	0.18	0.14	0.11	0.07	0.18	0.14	0.06	0.11	0.14	0.16	0.17					
HOURLY AVG	0.03	0.01	0.01	0.02	0.01	0.02	0.01	0.01	0.00	0.01	0.01	0.01	0.02	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.01	0.02				


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	191
MAXIMUM INSTANTANEOUS VALUE:	0.22 ppm @ HOUR 3 ON DAY 9
IZS CALIBRATION TIME:	31 hrs
MONTHLY CALIBRATION TIME:	5 hrs
STANDARD DEVIATION:	0.03
OPERATIONAL TIME:	704 hrs

NON-METHANE HYDROCARBONS Instantaneous Maximum (NMHC ppm)



Wind: PRAMP_842
 Poll.: PRAMP_842-NMHC[ppm]
 Monthly: 17/06
 Type: PollutionRose
 Direction: Blowing From (Wind Frequency)
 Based On 1 Hr.


Calm: 8.37%

Calm Avg: 0.00 [ppm]

Direction	0-0.1	0.1-0.3	0.3-1	1-2	>2.0	Total
N	6.2	0.0	0.0	0.0	0.0	6.2
NE	5.2	0.0	0.0	0.0	0.0	5.2
E	12.2	0.0	0.0	0.0	0.0	12.2
SE	12.0	0.0	0.0	0.0	0.0	12.0
S	8.4	0.0	0.0	0.0	0.0	8.4
SW	17.4	0.0	0.0	0.0	0.0	17.4
W	20.2	0.0	0.0	0.0	0.0	20.2
NW	10.1	0.0	0.0	0.0	0.0	10.1
Summary	91.6	0.0	0.0	0.0	0.0	91.6

% Icon Classes (ppm) 92 0-0.1 0 0.1-0.3 0 0.3-1 0 1-2 0 >2.0

PRAMP_842 Poll.: PRAMP_842-NMHC[ppm] 2017/06/01 00:00 - 2017/06/30 23:00 Calm: 8.37% Calm Poll Avg: 0.00[ppm]



NMHC[ppm] Calibration: PRAMP_842 Monthly: 17/06 Type: Span



Span Meas Span Ref Span Low Span High

WIND SPEED



WIND SPEED Hourly Averages (WS kph)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.		
DAY																													
1	2.2	3.2	3.7	4.1	4.1	4.2	5.7	6.1	7.9	11.1	14.7	16.4	12.4	11.7	11.7	11.9	13.2	18.2	13.3	11.9	9.9	5.0	3.5	4.6	2.2	18.2	7.5	24	
2	5.4	3.5	3.9	11.7	13.2	13.9	13.0	9.7	11.4	9.6	10.1	6.5	7.9	10.3	13.4	18.6	15.3	13.9	8.2	2.9	1.5	1.2	6.0	6.5	1.2	18.6	7.6	24	
3	4.5	7.1	2.3	3.8	2.5	4.4	4.7	6.4	7.6	10.1	10.5	12.0	11.0	16.7	17.8	18.8	16.1	22.9	18.0	16.3	9.1	8.3	7.8	2.6	2.3	22.9	8.3	24	
4	1.5	0.9	1.1	2.1	2.6	3.6	2.1	6.9	10.9	14.3	14.1	10.2	11.0	9.9	8.7	7.5	8.4	5.7	7.1	6.0	7.2	6.9	5.1	2.6	0.9	14.3	5.1	24	
5	3.2	3.5	2.8	1.8	1.4	0.6	2.1	6.2	8.6	7.8	13.3	17.3	16.9	14.6	13.4	15.5	13.5	14.0	14.0	11.4	6.2	2.4	1.9	1.8	0.6	17.3	7.0	24	
6	3.6	3.5	3.5	3.1	3.4	3.4	2.2	4.8	2.2	1.3	1.8	2.3	3.1	6.8	5.4	2.4	0.5	5.2	8.6	6.8	4.4	3.7	4.8	2.9	0.5	8.6	2.5	24	
7	2.3	5.8	6.6	5.6	7.9	5.2	5.4	5.5	4.4	6.6	9.4	8.1	7.1	7.5	10.6	9.0	10.2	6.8	8.5	10.1	7.2	6.5	5.9	6.9	2.3	10.6	6.8	24	
8	9.9	9.3	8.8	8.4	10.9	11.7	11.4	11.6	12.2	12.6	15.1	17.2	16.7	14.5	10.7	11.4	12.5	12.3	11.1	9.9	9.3	8.8	6.4	6.3	6.3	17.2	11.1	24	
9	7.3	8.2	7.4	7.4	7.5	7.6	10.2	14.9	18.5	15.5	15.7	17.5	15.9	15.9	16.3	17.1	17.7	17.3	17.4	14.9	12.9	11.2	11.5	10.0	7.3	18.5	12.7	24	
10	7.4	6.0	5.6	2.6	2.4	4.5	4.7	5.7	4.0	6.6	7.7	5.9	8.8	7.5	7.7	4.6	1.8	1.6	12.0	15.1	11.6	10.7	11.6	11.2	1.6	15.1	5.9	24	
11	7.2	3.4	5.9	3.6	4.0	1.7	0.9	2.4	2.4	5.3	5.9	6.6	8.0	7.5	9.1	11.4	9.9	10.6	9.0	6.4	5.6	3.3	5.0	4.7	0.9	11.4	3.8	24	
12	8.4	9.0	12.1	13.6	15.0	13.1	9.5	12.6	14.4	17.7	19.9	19.2	15.8	14.7	13.6	15.2	15.6	12.4	12.2	9.2	7.8	4.8	4.3	3.6	3.6	19.9	9.3	24	
13	4.3	5.5	5.7	2.5	2.7	2.4	5.9	7.7	5.2	1.6	0.8	6.0	5.6	9.1	8.0	8.3	8.7	8.3	13.1	11.1	7.5	7.5	5.8	4.3	0.8	13.1	2.0	24	
14	3.2	4.7	5.3	3.0	3.3	5.3	6.9	9.6	8.7	9.6	9.3	9.2	11.1	11.5	12.4	11.8	7.1	4.2	3.5	1.8	4.1	3.2	2.9	5.8	1.8	12.4	6.1	24	
15	4.5	3.9	1.8	1.2	0.4	1.3	1.3	5.9	6.2	5.8	5.8	4.2	3.4	1.4	2.5	1.6	3.8	3.2	6.4	4.6	3.6	5.8	7.4	7.2	0.4	7.4	1.9	24	
16	8.3	7.5	7.0	6.1	4.7	9.0	9.1	11.6	12.1	11.8	14.2	14.1	12.5	17.6	20.4	20.8	20.7	21.1	20.0	16.0	13.7	9.8	6.7	6.4	4.7	21.1	9.8	24	
17	1.8	1.0	1.7	0.5	2.0	4.1	6.6	9.8	10.0	7.2	12.8	17.3	19.8	21.5	21.3	21.1	19.8	16.6	16.5	12.4	14.1	6.8	6.5	3.2	0.5	21.5	10.5	24	
18	4.2	6.4	8.2	7.7	2.8	4.3	4.9	8.6	3.1	6.8	13.5	17.0	17.3	17.4	8.6	10.6	10.6	4.2	1.2	7.6	5.3	1.5	1.0	1.4	1.0	17.4	3.1	24	
19	0.8	2.3	3.0	3.1	3.3	3.5	4.2	7.4	9.5	9.1	7.3	7.0	7.9	8.0	8.9	7.1	6.4	6.4	9.9	5.2	1.5	1.4	1.6	4.8	0.8	9.9	4.5	24	
20	4.0	3.6	5.8	3.9	4.3	3.6	7.7	7.6	10.6	11.3	13.5	12.9	13.0	14.1	17.6	20.7	21.3	19.6	16.1	10.2	12.2	14.5	15.5	15.1	3.6	21.3	9.0	24	
21	17.6	14.8	12.5	10.9	7.3	9.2	10.9	13.8	19.0	13.6	15.0	16.1	19.0	22.1	22.2	20.5	16.8	14.1	10.1	8.3	6.8	6.7	5.9	6.5	5.9	22.2	12.7	24	
22	5.8	6.6	3.6	3.4	2.5	2.9	6.6	10.2	9.9	10.5	11.2	8.7	7.5	7.7	11.4	10.9	6.4	9.1	8.1	2.4	0.6	0.6	1.7	0.6	0.6	11.4	5.7	24	
23	1.2	1.6	2.0	2.1	2.2	2.6	2.1	1.5	4.5	7.4	8.3	8.2	6.7	10.2	12.2	9.9	8.7	10.8	11.5	5.5	1.9	0.8	0.9	0.5	0.5	12.2	3.1	24	
24	2.7	1.4	2.7	1.7	1.2	0.9	2.4	4.5	5.6	7.4	7.6	8.1	6.2	8.2	8.7	7.2	6.9	5.8	1.7	3.5	2.7	3.9	3.0	2.3	0.9	8.7	3.0	24	
25	1.7	4.5	4.7	5.0	5.2	6.0	5.8	6.6	9.3	10.4	14.0	15.0	16.3	14.1	16.6	14.7	16.3	16.7	13.8	16.4	12.7	10.9	9.8	10.8	1.7	16.7	10.4	24	
26	9.2	10.3	18.0	8.6	3.6	7.3	12.0	10.2	9.7	9.3	8.4	7.8	7.5	7.6	10.6	6.5	5.1	11.5	14.1	8.0	7.3	4.1	10.0	5.2	3.6	18.0	6.3	24	
27	6.6	6.4	4.8	3.6	8.0	8.4	7.1	9.5	7.7	12.0	11.9	10.7	16.6	21.9	16.8	16.6	12.9	8.3	12.5	12.9	11.5	X	X	X	3.6	21.9	9.7	21	
28	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	0.9	15.2	9.1	16
29	X	X	X	X	X	X	X	X	X	C	C	12.6	13.1	13.8	15.2	14.5	13.7	8.0	10.4	0.9	4.2	3.6	0.9	3.3	0.9	15.2	9.1	16	
30	2.0	1.9	2.3	3.7	2.6	4.4	3.8	4.8	7.4	7.4	12.2	14.3	13.7	11.6	8.2	6.4	3.8	5.2	3.0	1.2	2.3	2.6	5.0	6.8	1.2	14.3	5.7	24	
HOURLY MAX	17.6	14.8	18.0	13.6	15.0	13.9	13.0	14.9	19.0	17.7	19.9	19.2	19.8	22.1	22.2	21.1	21.3	22.9	20.0	16.4	14.1	14.5	15.5	15.1					
HOURLY AVG	1.1	1.6	2.2	2.2	1.5	1.9	2.1	3.0	3.9	4.4	5.5	5.8	5.8	6.2	6.3	6.0	5.4	5.2	4.0	2.4	1.3	0.8	0.5	1.0					

STATUS FLAG CODES


C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

LAST CALIBRATION:	June 29, 2017
DECLINATION :	MAGNETIC DECLINATION 15 DEGREE EAST


MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	683
MINIMUM 1-HR AVERAGE	0.4 kph @ HOUR 4 ON DAY 15
MAXIMUM 1-HR AVERAGE:	22.9 kph @ HOUR 17 ON DAY 3
MAXIMUM 24-HR AVERAGE:	12.7 kph ON DAY 9
MONTHLY CALIBRATION TIME:	2 hrs
OPERATIONAL TIME:	685 hrs
AMSD OPERATION UPTIME:	95.1 %
STANDARD DEVIATION:	5.0
MONTHLY AVERAGE:	2.6 kph

24 HR AVERAGES June 2017



WIND SPEED Hourly Averages (WS kph)





PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
Three Creeks 842b Station - June 2017

WIND SPEED Instantaneous Maximum (WS kph)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.		
DAY 1	9.1	7.7	8.0	7.5	9.0	6.7	11.2	13.0	16.1	20.9	29.7	33.0	26.6	29.8	26.8	28.7	30.6	34.0	26.9	23.9	22.4	11.9	7.2	11.0	6.7	34.0	18.8	24	
2	11.7	9.8	13.2	22.4	23.9	25.9	26.8	17.2	20.7	17.5	19.6	12.8	21.1	23.4	32.4	38.1	31.3	28.5	19.1	9.3	6.1	6.4	11.4	16.9	6.1	38.1	19.4	24	
3	14.3	16.0	10.4	7.8	8.7	7.7	P	11.8	17.5	P	25.0	23.4	34.2	34.7	36.3	36.9	32.4	48.8	38.8	33.1	25.7	14.8	16.9	9.0	7.7	48.8	22.9	22	
4	8.2	3.3	4.4	4.2	7.2	11.9	4.6	15.8	21.5	30.9	27.5	24.6	42.5	25.3	22.4	23.1	22.2	22.8	18.9	15.5	14.5	11.6	9.2	7.0	3.3	42.5	16.6	24	
5	6.8	8.5	7.1	6.2	4.4	3.2	8.5	15.2	17.9	17.2	36.2	37.6	35.8	35.0	38.3	38.5	34.4	30.4	31.5	23.3	15.9	6.0	4.1	4.6	3.2	38.5	19.4	24	
6	8.1	5.5	6.9	6.5	7.0	11.4	6.2	9.9	7.7	8.7	16.2	16.9	22.7	25.7	18.5	17.7	15.4	20.7	24.3	17.2	16.2	8.0	15.9	10.4	5.5	25.7	13.5	24	
7	11.4	10.2	11.0	12.9	13.6	11.9	11.3	12.2	12.7	23.5	25.0	23.4	21.3	24.1	29.0	24.3	28.5	21.2	22.8	33.8	25.9	19.7	14.4	17.7	10.2	33.8	19.2	24	
8	25.7	26.1	23.1	24.6	P	31.9	31.0	28.9	34.8	32.9	39.9	45.0	42.2	44.7	35.1	38.9	38.5	33.2	32.7	28.5	24.8	22.0	17.6	14.2	14.2	45.0	31.1	23	
9	21.2	22.1	19.6	18.4	20.2	24.2	28.3	40.8	47.8	38.2	43.0	44.6	44.5	42.8	45.7	43.5	41.0	42.1	44.2	35.3	39.9	30.6	32.5	27.2	18.4	47.8	34.9	24	
10	19.2	13.2	14.2	8.4	6.7	12.7	11.7	12.4	13.1	16.0	20.9	21.5	24.9	25.4	24.1	15.9	8.7	16.4	40.6	35.9	27.8	28.6	27.3	31.0	6.7	40.6	19.9	24	
11	20.7	9.5	12.5	8.6	10.0	5.2	6.2	8.8	7.4	10.6	15.3	14.8	15.6	17.0	22.2	22.8	20.3	22.0	19.7	12.7	8.5	7.5	9.7	9.2	5.2	22.8	13.2	24	
12	17.5	19.2	23.2	28.6	26.2	26.8	20.8	26.3	27.8	34.7	35.7	41.1	39.3	32.9	31.6	32.9	33.1	28.7	26.6	18.4	16.2	9.6	9.4	7.8	7.8	41.1	25.6	24	
13	7.0	12.3	11.1	7.8	8.7	8.5	13.0	13.3	12.7	9.6	12.7	17.6	22.6	22.5	26.2	23.5	21.7	29.5	31.6	24.4	21.1	18.6	15.6	14.8	7.0	31.6	16.9	24	
14	9.4	17.2	14.9	11.6	11.0	12.9	23.2	27.2	29.7	26.0	26.1	29.8	29.6	30.0	32.8	35.7	21.0	13.6	13.3	5.9	13.4	13.9	11.5	17.8	5.9	35.7	19.9	24	
15	14.4	12.0	8.4	4.3	3.8	4.7	5.2	10.8	12.9	12.6	12.7	11.3	11.5	16.3	10.8	7.3	10.5	10.9	19.3	12.7	12.2	17.9	26.3	20.8	3.8	26.3	12.1	24	
16	23.7	19.1	19.2	15.1	11.1	17.7	17.1	20.9	22.8	24.9	27.4	29.5	31.4	40.5	43.0	44.2	38.8	44.8	43.2	36.7	28.8	19.5	18.5	19.7	11.1	44.8	27.4	24	
17	6.4	6.1	5.7	2.3	5.8	9.9	13.3	17.2	20.6	20.9	31.2	34.1	42.8	42.1	47.7	41.1	40.9	40.1	32.4	26.4	30.0	16.8	11.5	10.8	2.3	47.7	23.2	24	
18	7.8	11.1	14.3	13.4	12.1	9.8	14.5	24.6	15.0	39.2	27.8	38.1	35.8	40.2	34.0	43.7	33.8	18.7	16.8	20.0	16.9	4.6	3.4	3.8	3.4	43.7	20.8	24	
19	2.8	4.7	5.1	7.3	7.3	7.8	8.5	16.4	18.0	17.5	21.9	26.0	25.1	24.2	24.6	19.3	19.5	13.9	29.1	21.0	5.4	7.3	7.7	10.8	2.8	29.1	14.6	24	
20	9.1	8.1	11.3	11.0	8.3	12.9	14.7	13.8	17.4	22.4	24.9	25.1	31.0	32.4	34.8	43.8	43.4	37.8	32.7	23.4	29.0	29.9	39.3	35.7	8.1	43.8	24.7	24	
21	46.0	30.7	29.5	21.0	15.6	19.2	20.0	35.8	36.3	30.7	35.3	38.7	42.7	45.2	41.4	39.9	36.1	30.0	27.5	19.1	13.9	12.2	14.9	16.7	12.2	46.0	29.1	24	
22	14.1	16.9	8.9	7.9	5.9	8.0	18.4	19.2	23.6	28.3	26.5	26.4	21.1	27.7	37.5	33.1	24.1	23.4	22.7	10.1	2.7	7.6	6.6	5.1	2.7	37.5	17.7	24	
23	4.5	6.0	6.7	5.1	5.0	7.0	4.8	8.5	13.2	19.2	19.9	24.3	21.3	24.8	27.9	21.6	22.6	31.1	28.4	19.4	7.8	8.9	7.3	3.4	3.4	31.1	14.5	24	
24	7.0	4.5	8.3	5.5	3.3	3.6	7.5	15.3	15.3	16.7	22.3	20.2	24.1	24.4	25.8	24.6	25.8	17.8	10.2	10.1	9.0	5.3	6.3	7.7	3.3	25.8	13.4	24	
25	8.4	12.1	12.5	12.0	12.9	14.6	16.9	21.1	24.3	29.4	31.3	31.3	30.8	31.8	35.4	33.7	33.6	39.0	33.2	40.1	33.4	29.7	26.7	29.9	8.4	40.1	26.0	24	
26	25.8	25.0	41.3	38.0	20.2	13.0	23.9	21.9	20.1	18.3	21.1	15.5	15.6	21.3	27.9	P	12.0	40.9	42.1	19.0	19.0	29.6	20.8	16.6	12.0	42.1	23.9	23	
27	15.4	13.7	10.3	9.3	19.5	16.8	15.2	19.1	19.0	24.8	24.7	23.5	34.8	47.0	36.0	29.6	30.3	28.6	23.8	30.0	27.3	X	X	X	9.3	47.0	23.7	21	
28	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	0
29	X	X	X	X	X	X	X	X	C	C	22.2	25.0	25.0	30.8	25.8	27.9	28.1	32.3	44.0	31.2	11.3	11.3	25.9	8.9	8.9	44.0	25.0	16	
30	6.3	8.2	8.4	10.4	8.0	9.0	8.1	12.0	15.1	15.2	23.7	28.4	25.5	26.1	23.5	19.3	13.4	14.9	8.2	5.6	7.8	9.1	14.4	P	5.6	28.4	13.9	23	
HOURLY MAX	46.0	30.7	41.3	38.0	26.2	31.9	31.0	40.8	47.8	39.2	43.0	45.0	44.5	47.0	47.7	44.2	43.4	48.8	44.2	40.1	39.9	30.6	39.3	35.7					
HOURLY AVG	13.6	12.8	13.2	12.1	10.9	12.7	14.5	18.2	20.0	22.5	25.7	27.0	29.0	30.6	30.9	30.3	27.3	28.1	27.7	22.1	18.4	15.0	15.4	14.4					


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

MONTHLY SUMMARY

MAXIMUM INSTANTANEOUS VALUE:	48.8	kph	@ HOUR	17	ON DAY	3	
OPERATIONAL TIME:						680	hrs

WIND SPEED Instantaneous Maximum (WS kph)




Wind: PRAMP_842
 Monitor: WSP [kph]
 Monthly: 17/06
 Type: WindRose
 Direction: Blowing From (Wind Frequency)
 Based On 1 Hr.

Calm: 8.05%

Direction	1.8-6.0	6.0-12.0	12.0-20.0	20.0-29.0	29.0-39.0	>39.0	Total
N	3.1	2.5	0.3	0.0	0.0	0.0	5.9
NE	1.3	1.9	2.1	0.0	0.0	0.0	5.3
E	5.6	6.3	1.3	0.0	0.0	0.0	13.2
SE	7.9	2.9	1.3	0.0	0.0	0.0	12.2
S	2.8	4.4	1.5	0.0	0.0	0.0	8.6
SW	4.5	7.5	5.1	0.9	0.0	0.0	18.0
W	2.1	7.6	8.6	1.0	0.0	0.0	19.3
NW	2.6	5.7	1.0	0.2	0.0	0.0	9.5
Summary	29.9	38.8	21.2	2.1	0.0	0.0	91.9

% Icon Classes (kph) 30 1.8-6.0 39 6.0-12.0 21 12.0-20.0 2 20.0-29.0 0 29.0-39.0 0 >39.0

PRAMP_842 2017/06/01 00:00 - 2017/06/30 23:00 Calm: 8.05% Calm Wind Avg Speed: 1.23(kph)



WIND DIRECTION



PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
Three Creeks 842b Station - June 2017

WIND DIRECTION Hourly Averages (WD)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24-HOUR AVG	24-HR		
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	QUADRANT	RDGS.		
DAY																												
1	SE	SE	SSE	SSE	SSE	SSE	S	SSW	SW	SW	WSW	WSW	WSW	WSW	W	W	W	WSW	WSW	WSW	WSW	SW	SW	WSW	WSW	WSW	24	
2	SW	SW	SSW	SW	SW	WSW	WSW	WSW	SW	SSW	S	S	SW	WSW	W	W	WNW	WNW	NW	N	SSE	S	SW	WSW	WSW	WSW	24	
3	WSW	SSW	SSW	SSE	S	SSE	SSW	SW	SSW	SW	SSW	S	S	SSE	S	SSW	SW	WSW	W	WSW	SW	S	S	WSW	SSW	SSW	24	
4	SW	S	ESE	ESE	ESE	SE	SE	WSW	WSW	WSW	WSW	WSW	W	SW	WSW	WSW	W	WSW	WSW	SSW	SSW	S	SSE	SSE	SW	SW	24	
5	SE	SE	SSE	S	SSW	SE	SW	WSW	W	W	WSW	W	WSW	WSW	W	WSW	WSW	W	WSW	W	WSW	SSW	ESE	ESE	WSW	WSW	24	
6	ESE	ESE	ESE	ESE	SE	SE	SE	S	SSW	SW	NNW	W	S	SSE	SSE	NE	SW	SE	ENE	ENE	E	ENE	E	E	ESE	ESE	24	
7	ENE	E	ENE	ENE	E	E	E	E	E	ESE	ESE	E	ESE	ESE	E	ESE	ESE	E	E	E	E	E	ENE	ENE	ENE	E	24	
8	E	E	E	E	E	E	E	E	E	ESE	ESE	ESE	ESE	ESE	ESE	ESE	E	E	E	E	E	E	E	ENE	ENE	E	24	
9	ENE	E	E	NE	ENE	ENE	NE	NE	NE	NE	ENE	ENE	ENE	NE	NE	NNE	NE	NE	NNE	NE	NNE	NNE	NNE	NE	NE	NE	24	
10	NNE	N	NNE	N	N	NNW	N	N	NW	WNW	WNW	WNW	NW	WNW	NW	NNW	SE	SE	NNE	N	N	N	N	N	N	NNW	24	
11	NNE	N	NW	NW	NNW	W	SW	WNW	WNW	WSW	SW	WSW	WSW	WSW	W	WSW	WSW	SW	SW	SW	SSW	S	SE	SE	WSW	WSW	24	
12	SSE	SSE	SSE	SSE	SSE	S	SSW	SSW	SW	WSW	WSW	W	WSW	WSW	W	W	W	W	W	WSW	SW	SW	WSW	WSW	SW	SW	24	
13	SW	SW	WSW	SSE	SE	SSE	SW	WSW	W	WSW	NNW	WSW	SW	WSW	WSW	SW	WSW	NNE	NNE	NNE	NNE	NNE	NNE	NE	W	W	24	
14	NNE	N	NE	NE	N	NE	NE	ENE	ENE	ENE	ENE	ENE	NE	ENE	ENE	ENE	E	ESE	E	E	ENE	ENE	E	E	ENE	ENE	24	
15	E	E	ESE	ESE	WSW	E	SSE	WSW	W	WSW	SW	SSW	SE	SSW	ENE	SE	ENE	E	SSE	SE	E	E	ESE	ESE	SE	SE	24	
16	SE	SE	ESE	SE	SE	S	SSW	SW	SW	SW	SW	SW	SW	WSW	WSW	WSW	WSW	W	W	W	W	W	WSW	W	WSW	WSW	24	
17	SW	W	WSW	SSE	WSW	SW	WSW	WSW	WSW	WSW	WSW	SW	WSW	SW	WSW	WSW	SW	WSW	WSW	WSW	WSW	SW	SW	SW	WSW	WSW	24	
18	SSE	SSE	SSE	SSE	SSE	SE	SSW	WSW	SSW	W	SW	WSW	W	WSW	N	NNW	N	NW	NNE	NNW	NNW	NE	SE	ESE	WSW	WSW	24	
19	ESE	ESE	ESE	ESE	SE	SE	S	SSW	SW	SSW	SSW	SSW	S	SSW	SSW	SSW	SSW	S	SSW	SW	NE	E	ESE	SE	S	SSW	24	
20	ESE	ENE	ESE	E	E	S	SSW	SSE	S	SSW	SW	WSW	WSW	WSW	WSW	SSW	SSW	SSW	SSW	SSW	SSW	WSW	WSW	W	W	SW	24	
21	W	W	W	WSW	WSW	SW	SW	WSW	W	W	W	WNW	WNW	WNW	W	W	W	W	WNW	W	W	W	NW	NNW	W	W	24	
22	NNW	NW	WNW	WNW	WNW	W	NW	NW	NNW	NNW	NNW	NNW	NW	NW	WNW	NW	NW	NW	WNW	WNW	SSE	SSE	SW	ESE	NW	NW	24	
23	E	E	ESE	ESE	ESE	ESE	ESE	SW	WSW	SW	SW	WSW	WSW	WNW	W	W	WSW	W	NW	N	NNE	E	SSW	SE	W	W	24	
24	W	SW	SE	SE	E	E	W	N	NNW	NW	NW	NW	NW	NW	NW	NNW	NW	WNW	NNW	NNE	NE	ENE	ENE	E	NNW	NNW	24	
25	ESE	SE	SE	ESE	ESE	ESE	SE	ESE	SE	SE	SSE	SSE	SSE	SSE	SSE	SSE	SSE	SSE	SE	SE	SE	SE	SE	SE	SE	SE	24	
26	SE	SE	SE	SSE	SSE	S	SSE	SSW	SW	SSW	WSW	WSW	SW	WSW	W	S	SSW	WNW	SW	SSW	SSW	WSW	S	SSW	SSW	SSW	24	
27	SSW	SW	WNW	NW	NW	NNW	NNW	NW	WNW	W	NW	WNW	WNW	WNW	WNW	WNW	WNW	WNW	WNW	WNW	WSW	WSW	WNW	X	X	X	WNW	21
28	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	24
29	X	X	X	X	X	X	X	X	C	C	SW	SW	SW	SSW	SW	SW	SW	NW	N	ESE	ESE	SE	W	ESE	SW	SW	16	
30	E	N	ESE	SE	NW	WNW	WNW	W	W	WNW	NW	NW	WNW	NW	NW	NNW	NNW	NW	SE	NNE	ESE	E	E	ESE	NW	SW	24	


STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE

LAST CALIBRATION:	June 29, 2017
DECLINATION :	MAGNETIC DECLINATION 15 DEGREE EAST

MONTHLY CALIBRATION TIME:	2	hrs	OPERATIONAL TIME:	685	hrs
STANDARD DEVIATION:	89		AMD OPERATION UPTIME:	95.1	%
			MONTHLY AVERAGE:	239	(WSW)

WIND DIRECTION Hourly Averages (WD)



RELATIVE HUMIDITY



PEACE RIVER AREA MONITORING PROGRAM COMMITTEE
Three Creeks 842b Station - June 2017


RELATIVE HUMIDITY Hourly Averages (RH %)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.	
DAY 1	75	73	73	82	86	87	79	67	56	45	38	37	36	33	34	34	32	33	34	34	38	47	53	58	32	87	53	24
2	60	68	73	71	70	65	65	76	86	88	89	88	80	68	62	56	53	53	57	58	73	86	68	60	53	89	70	24
3	59	70	75	83	83	82	69	58	52	45	39	33	28	27	30	27	26	30	33	33	44	49	59	72	26	83	50	24
4	75	88	91	91	90	80	69	46	40	33	31	29	26	25	24	26	26	24	25	29	33	40	48	59	24	91	48	24
5	62	63	74	79	83	87	72	56	44	35	29	23	22	22	22	21	20	19	20	23	28	47	68	71	19	87	45	24
6	71	63	70	65	62	58	57	46	34	28	25	23	23	22	23	24	22	22	23	26	29	49	51	50	22	71	40	24
7	60	61	64	68	64	62	55	47	40	32	29	29	28	28	29	27	27	31	29	33	40	48	56	58	27	68	44	24
8	51	52	55	59	59	59	55	50	42	35	30	26	26	26	27	35	40	38	38	36	41	42	47	52	26	59	43	24
9	50	46	46	51	63	61	53	47	45	42	39	38	36	34	35	37	40	38	38	38	39	44	48	52	34	63	44	24
10	59	68	73	79	89	87	67	54	51	49	43	40	32	29	28	29	29	51	57	74	91	93	92	92	28	93	61	24
11	93	94	95	95	96	96	92	85	85	83	77	74	72	64	62	56	57	59	60	62	68	75	78	82	56	96	78	24
12	80	81	82	83	85	85	83	76	70	61	49	46	48	43	44	45	42	41	42	43	47	59	60	66	41	85	61	24
13	66	67	66	73	79	79	66	59	52	44	40	38	36	32	31	30	31	43	45	48	55	69	78	84	30	84	55	24
14	88	93	94	93	95	95	92	85	81	80	76	66	61	63	66	67	70	75	89	93	94	94	94	93	61	95	83	24
15	94	94	95	95	95	95	95	92	84	77	73	71	63	61	55	54	57	48	55	65	65	70	76	48	95	76	24	
16	76	75	79	81	83	84	82	79	69	63	56	53	54	47	41	40	37	35	36	41	37	42	48	51	35	84	58	24
17	65	79	88	90	93	86	75	66	56	46	41	37	30	27	26	22	21	21	22	22	27	38	45	50	21	93	49	24
18	70	60	63	65	75	69	64	60	60	59	47	41	35	32	37	49	61	55	47	47	51	74	89	92	32	92	58	24
19	94	95	95	95	96	94	76	58	53	47	41	37	38	34	34	33	34	37	38	60	75	85	80	66	33	96	62	24
20	67	77	77	74	81	78	83	92	89	81	69	61	53	49	46	53	60	55	60	66	46	43	47	55	43	92	65	24
21	59	64	65	73	82	84	81	67	58	56	53	54	53	53	59	63	69	72	84	90	92	94	95	94	53	95	71	24
22	92	91	92	94	94	94	86	76	69	62	53	46	45	43	38	39	35	33	33	31	54	74	74	87	31	94	64	24
23	90	92	92	94	95	95	82	64	56	51	42	36	37	41	48	55	42	38	42	49	61	74	86	90	36	95	65	24
24	86	85	87	89	93	94	83	61	52	49	46	41	34	30	28	28	27	28	29	31	42	65	74	71	27	94	56	24
25	70	58	60	63	68	68	59	51	43	38	32	29	27	26	25	27	29	29	31	31	34	39	45	51	25	70	43	24
26	56	56	54	54	67	67	64	59	57	55	56	50	43	35	27	22	31	39	50	58	71	71	71	79	22	79	54	24
27	83	84	86	89	84	77	75	72	69	66	60	58	59	68	79	83	89	90	90	92	94	95	95	94	58	95	80	24
28	94	94	94	95	95	95	95	95	P	94	90	87	79	72	68	66	60	77	66	60	67	79	88	87	60	95	82	23
29	87	88	92	95	95	96	92	84	79	71	60	53	50	45	42	46	48	55	84	84	89	89	90	90	42	96	75	24
30	92	94	95	94	94	95	94	90	84	80	74	70	62	57	49	48	45	42	41	38	52	68	70	70	38	95	71	24
HOURLY MAX	94	95	95	95	96	96	95	95	92	94	90	88	80	72	79	83	89	90	90	93	94	95	95	94				
HOURLY AVG	74	76	78	80	83	82	75	67	61	57	51	47	44	41	41	41	42	44	46	50	56	65	69	72				

STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE


24 HR AVERAGES June 2017



MONTHLY SUMMARY

MINIMUM 1-HR AVERAGE:	19	%	@ HOUR	17	ON DAY	5
MAXIMUM 1-HR AVERAGE:	96	%	@ HOUR	4	ON DAY	11
MAXIMUM 24-HR AVERAGE:	83	%			ON DAY	14
OPERATIONAL TIME:						719 hrs
AMSD OPERATION UPTIME:						99.9 %
STANDARD DEVIATION:	22		MONTHLY AVERAGE:			60 %

RELATIVE HUMIDITY Hourly Averages (RH %)



BAROMETRIC PRESSURE




BAROMETRIC PRESSURE Hourly Averages (BP mbar)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MIN.	DAILY MAX.	24-HR AVG.	RDGS.	
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59					
DAY 1	933	933	933	933	933	933	933	933	933	933	933	933	933	932	932	932	932	932	932	932	932	933	933	933	932	933	933	24	
2	933	933	933	934	934	934	934	935	935	935	935	935	935	935	935	936	936	937	937	937	938	938	939	939	933	939	935	24	
3	939	939	939	940	940	940	940	940	940	940	939	939	938	938	938	938	938	938	938	939	940	940	941	941	938	941	939	24	
4	941	942	942	942	942	942	943	943	943	943	943	942	942	942	942	942	941	941	942	942	943	943	943	943	941	943	942	24	
5	943	943	943	944	944	944	945	945	945	945	945	945	945	945	945	945	945	945	946	946	947	947	947	947	943	947	945	24	
6	947	947	948	948	948	949	949	949	948	948	948	947	946	946	945	945	944	944	944	944	944	944	944	944	944	949	946	24	
7	944	945	944	944	945	945	945	945	945	944	944	944	944	943	943	943	943	942	942	942	942	942	942	942	942	945	944	24	
8	941	941	941	941	940	940	939	939	939	938	938	937	936	936	936	935	935	934	934	933	933	933	933	932	932	932	941	937	24
9	932	932	932	932	931	931	930	930	930	930	930	930	929	929	929	929	930	929	930	931	931	932	932	932	929	932	930	24	
10	932	932	932	932	932	932	932	932	932	931	931	930	930	930	929	929	929	929	930	932	933	934	935	935	929	935	931	24	
11	936	936	937	937	937	938	938	938	938	938	938	938	938	938	938	938	938	938	938	938	938	938	937	937	936	938	938	24	
12	936	936	935	934	934	934	934	934	934	934	934	934	934	934	934	934	934	934	934	934	934	935	936	936	934	936	934	24	
13	936	937	937	937	937	938	938	939	939	939	939	939	939	938	938	938	938	938	939	939	939	940	940	940	936	940	938	24	
14	940	940	940	940	941	941	941	941	941	941	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	941	940	24	
15	939	939	939	939	939	939	939	939	939	939	938	938	938	937	937	936	936	935	934	934	934	933	933	933	933	939	937	24	
16	932	932	932	932	932	933	933	933	933	933	933	933	932	932	932	932	933	933	933	933	934	934	935	936	932	936	933	24	
17	936	937	937	938	939	939	940	940	941	940	940	940	940	940	939	939	939	939	939	939	939	939	939	939	936	941	939	24	
18	939	939	939	939	940	940	940	940	941	940	940	940	940	940	941	942	943	944	944	945	945	946	946	939	946	942	24		
19	946	946	947	946	946	947	947	947	946	946	945	945	944	944	943	943	942	942	942	942	941	941	940	940	947	944	24		
20	940	939	939	938	938	938	938	938	937	937	936	936	935	935	935	935	935	935	935	935	935	935	936	935	940	936	24		
21	937	937	937	938	938	937	937	937	937	937	937	937	938	938	939	940	940	941	942	942	943	944	944	937	944	939	24		
22	945	946	947	948	949	949	950	951	951	951	951	951	951	951	951	951	950	950	950	950	950	950	951	945	951	950	24		
23	951	951	951	951	951	952	952	952	952	952	952	952	951	951	951	952	951	951	952	952	952	952	952	952	951	952	952	24	
24	952	953	953	953	953	954	954	954	954	954	954	954	954	954	953	953	953	952	952	952	952	951	951	951	954	953	24		
25	951	951	951	950	950	950	950	949	949	948	948	947	947	946	945	944	943	942	941	941	940	939	939	938	938	951	946	24	
26	937	937	935	934	935	935	935	935	935	935	934	934	934	933	933	933	933	933	934	934	933	933	934	933	933	937	934	24	
27	933	932	932	932	933	933	933	932	932	932	932	931	931	932	932	931	931	931	930	929	928	928	929	930	928	933	931	24	
28	931	932	933	933	934	935	935	936	P	938	939	939	940	940	941	941	941	942	942	943	943	944	944	944	931	944	939	23	
29	944	944	944	944	944	944	944	944	944	944	944	944	944	944	943	943	943	943	943	943	944	944	943	943	943	944	944	24	
30	943	943	943	942	943	943	943	943	943	943	943	943	943	943	943	942	942	942	942	942	941	942	942	942	941	943	943	24	
HOURLY MAX	952	953	953	953	953	954	954	954	954	954	954	954	954	954	953	953	953	952	952	952	952	952	952	952	952	951	952	24	
HOURLY AVG	940	940	940	940	940	940	940	940	941	940	940	940	940	940	939	939	939	939	939	939	940	940	940	940	941	943	943	24	

STATUS FLAG CODES


C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE



MONTHLY SUMMARY

MINIMUM 1-HR AVERAGE:	928	mbar	@ HOUR	20	ON DAY	27
MAXIMUM 1-HR AVERAGE:	954	mbar	@ HOUR	5	ON DAY	24
MAXIMUM 24-HR AVERAGE:	953	mbar			ON DAY	24
OPERATIONAL TIME:						719 hrs
AMD OPERATION UPTIME:						99.9 %
STANDARD DEVIATION:	6				MONTHLY AVERAGE:	940 mbar

BAROMETRIC PRESSURE Hourly Averages (BP mbar)



AMBIENT TEMPERATURE




AMBIENT TEMPERATURE Hourly Averages (AmbTPX °C)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.	
DAY 1	11.2	11.7	11.5	9.5	9.0	9.5	12.7	15.4	18.3	20.7	22.1	22.5	23.3	23.7	24.0	23.8	23.9	23.1	22.9	22.3	20.2	17.0	14.7	14.1	9.0	24.0	17.8	24
2	13.7	12.5	11.7	12.9	13.1	13.6	13.4	12.2	11.4	11.4	11.9	12.6	13.9	16.0	17.0	17.5	17.3	17.4	18.7	15.6	11.9	11.3	11.2	11.2	11.2	18.7	14.0	24
3	10.9	7.9	7.0	5.0	4.7	5.6	10.1	13.0	14.8	16.7	18.7	20.5	21.8	21.8	21.2	21.1	21.1	20.3	19.0	18.0	16.0	14.8	12.2	9.4	4.7	21.8	14.7	24
4	7.7	4.6	3.3	1.9	2.0	3.7	8.1	11.9	13.3	14.9	15.8	17.3	18.6	18.8	19.5	19.3	20.0	20.5	19.8	19.3	18.0	15.4	13.5	11.4	1.9	20.5	13.3	24
5	10.5	9.7	7.5	6.6	5.8	4.9	9.6	12.8	15.2	17.3	18.5	19.3	19.8	20.3	21.1	21.0	21.2	21.2	20.7	20.1	18.5	13.5	8.9	7.4	4.9	21.2	14.6	24
6	6.3	6.7	5.5	6.2	6.7	8.9	11.8	15.6	18.5	21.1	22.8	23.9	24.4	24.6	24.2	25.1	25.6	24.6	25.5	24.2	22.7	17.1	15.6	15.6	5.5	25.6	17.6	24
7	13.1	13.6	12.8	11.8	11.9	12.5	15.3	19.1	22.6	24.7	25.1	25.7	25.4	25.7	26.0	27.1	26.0	24.8	24.8	24.3	22.6	20.3	18.1	17.0	11.8	27.1	20.4	24
8	17.8	17.0	16.2	15.3	15.5	15.9	17.4	19.3	21.6	23.5	25.1	26.2	26.9	26.9	25.7	24.4	23.7	24.5	24.0	23.7	22.6	21.7	20.4	18.7	15.3	26.9	21.4	24
9	18.9	19.5	19.2	18.3	16.1	15.9	18.0	20.2	21.1	22.2	23.0	23.7	24.8	25.2	25.0	23.6	22.9	22.9	21.5	20.3	18.4	15.2	13.0	11.6	11.6	25.2	20.0	24
10	9.5	7.1	6.1	4.4	2.1	3.6	9.4	13.9	15.2	15.7	16.9	17.6	21.0	20.5	21.2	21.2	20.4	17.1	15.7	12.3	9.3	8.6	7.4	5.9	2.1	21.2	12.6	24
11	4.8	3.5	2.6	1.8	2.1	3.1	5.6	7.5	7.7	7.9	9.0	10.0	10.4	11.4	11.8	12.3	12.4	12.1	11.6	11.5	10.8	9.8	8.3	7.8	1.8	12.4	8.2	24
12	8.6	9.2	9.8	10.1	10.0	10.2	11.1	13.1	14.2	15.8	17.5	18.0	18.1	18.8	18.8	18.7	20.3	20.4	19.4	19.2	18.1	14.7	12.8	10.6	8.6	20.4	14.9	24
13	9.9	9.3	9.2	7.2	5.7	6.5	10.3	12.4	14.5	17.3	19.7	19.3	19.9	20.6	21.3	21.6	21.6	20.2	20.8	19.6	17.7	13.6	11.3	9.8	5.7	21.6	15.0	24
14	8.0	6.4	7.2	6.6	6.5	9.2	10.4	11.0	11.7	11.6	11.9	15.2	16.5	15.8	15.0	14.4	14.0	13.4	12.0	11.6	11.5	11.0	10.6	10.2	6.4	16.5	11.3	24
15	9.8	9.6	9.4	9.4	9.5	9.7	10.0	10.3	11.3	12.7	13.5	14.0	14.8	16.6	17.3	18.1	18.7	17.8	18.2	16.6	15.1	14.0	13.4	12.9	9.4	18.7	13.4	24
16	13.4	13.7	13.3	12.8	12.2	12.3	12.7	13.3	14.5	15.7	16.9	17.6	17.4	18.3	19.8	19.7	19.8	19.4	18.8	17.9	16.2	14.8	14.2	13.7	12.2	19.8	15.8	24
17	10.5	7.8	6.0	5.2	5.5	8.2	10.6	12.3	13.8	15.4	16.1	16.5	17.4	17.9	18.4	18.8	18.9	19.0	18.5	18.1	16.9	13.9	11.5	9.9	5.2	19.0	13.6	24
18	6.5	6.9	5.8	5.2	3.4	5.0	7.7	9.0	9.9	10.6	13.0	13.9	15.4	16.7	17.6	14.9	12.6	14.0	15.5	15.5	14.2	9.3	5.3	3.7	3.4	17.6	10.5	24
19	2.6	2.4	2.1	1.4	1.4	3.4	8.8	12.3	13.6	15.1	16.6	18.0	18.5	20.3	20.3	20.2	20.0	19.3	18.3	15.8	14.7	13.0	12.8	13.7	1.4	20.3	12.7	24
20	13.1	11.4	10.5	11.4	10.5	11.9	12.6	12.3	13.4	15.2	17.1	18.3	19.6	19.8	18.8	17.8	16.2	15.9	15.5	14.9	15.0	14.6	13.8	13.2	10.5	19.8	14.7	24
21	12.1	11.0	10.5	9.5	8.4	8.0	7.4	9.0	10.6	11.6	13.1	12.9	13.0	13.1	11.9	11.1	10.3	10.3	9.0	8.4	8.3	8.3	7.9	7.4	13.1	10.2	24	
22	6.0	4.7	4.1	3.1	3.0	3.6	7.3	10.4	12.4	14.0	15.5	17.0	17.2	17.5	18.6	18.7	20.0	20.6	19.6	20.4	16.3	11.2	10.4	7.0	3.0	20.6	12.4	24
23	5.7	5.0	4.2	3.4	2.7	4.2	9.6	14.2	16.3	17.6	19.0	20.0	20.5	18.9	16.9	16.3	19.2	20.6	20.4	18.7	15.4	12.5	9.1	7.8	2.7	20.6	13.3	24
24	9.3	9.9	9.2	7.6	6.3	6.9	11.4	16.7	19.1	20.0	21.3	22.5	23.7	24.2	25.2	25.4	24.8	24.4	24.2	23.9	21.0	14.2	11.1	10.5	6.3	25.4	17.2	24
25	10.4	13.1	12.8	12.4	11.6	11.8	15.3	18.6	21.0	22.5	23.7	24.7	25.4	26.1	26.5	26.7	26.6	26.2	26.1	25.4	24.1	22.1	20.7	19.8	10.4	26.7	20.6	24
26	19.0	18.9	19.3	19.0	15.6	16.4	17.7	19.5	20.8	21.9	22.2	23.2	24.0	25.4	25.5	25.4	23.4	20.7	18.6	16.9	15.2	14.7	14.5	13.8	13.8	25.5	19.7	24
27	12.6	12.2	11.9	11.1	11.4	11.9	12.6	12.9	12.9	13.8	15.8	16.6	16.4	15.4	14.2	13.5	12.9	11.4	11.3	11.1	11.0	11.2	11.1	10.4	10.4	16.6	12.7	24
28	10.3	10.1	9.7	9.6	9.9	10.6	11.3	11.8	P	13.1	14.5	15.9	17.7	19.9	19.8	20.6	21.1	16.6	19.5	20.3	17.7	15.4	14.9	14.5	9.6	21.1	15.0	23
29	13.1	12.8	11.5	10.2	10.1	10.4	13.0	14.9	16.6	18.8	20.9	22.2	22.9	23.6	24.1	23.9	24.1	21.6	15.7	15.6	15.0	14.6	14.2	14.1	10.1	24.1	16.8	24
30	13.9	13.6	13.4	13.3	12.6	13.3	13.9	14.8	16.5	17.2	18.9	20.1	21.5	23.0	24.5	23.5	24.1	25.3	23.1	25.6	22.4	17.6	16.4	16.1	12.6	25.6	18.5	24
HOURLY MAX	19.0	19.5	19.3	19.0	16.1	16.4	18.0	20.2	22.6	24.7	25.1	26.2	26.9	26.9	26.5	27.1	26.6	26.2	26.1	25.6	24.1	22.1	20.7	19.8				
HOURLY AVG	10.6	10.1	9.4	8.7	8.2	9.0	11.5	13.7	15.3	16.5	17.9	18.8	19.7	20.2	20.4	20.2	20.1	19.5	18.9	18.3	16.7	14.2	12.7	11.7				

STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE


24 HR AVERAGES June 2017



MONTHLY SUMMARY

MINIMUM 1-HR AVERAGE:	1.4	°C	@ HOUR	3	ON DAY	19
MAXIMUM 1-HR AVERAGE:	27.1	°C	@ HOUR	15	ON DAY	7
MAXIMUM 24-HR AVERAGE:	21.4	°C			ON DAY	8
OPERATIONAL TIME:						719 hrs
AMD OPERATION UPTIME:						99.9 %
STANDARD DEVIATION:	5.8					MONTHLY AVERAGE: 15.1 °C

AMBIENT TEMPERATURE Hourly Averages (AmbTPX °C)



STATION TEMPERATURE




STATION TEMPERATURE Hourly Averages (StnTPX °C)

HR START (MST)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	24-HR	RDGS.
HR END (MST)	0:59	1:59	2:59	3:59	4:59	5:59	6:59	7:59	8:59	9:59	10:59	11:59	12:59	13:59	14:59	15:59	16:59	17:59	18:59	19:59	20:59	21:59	22:59	23:59	MIN.	MAX.	AVG.	
DAY 1	20.7	20.7	20.7	21.5	20.7	21.5	20.2	20.5	20.6	20.5	20.5	20.5	20.7	20.8	20.6	20.5	20.8	20.8	20.9	20.8	20.4	20.5	20.5	20.8	20.2	21.5	20.7	24
2	20.7	20.9	20.9	20.8	20.5	20.7	20.8	20.8	20.5	20.5	20.8	20.9	21.0	20.8	20.6	20.4	20.6	20.7	20.6	20.5	20.6	20.9	21.0	20.5	20.4	21.0	20.7	24
3	20.7	21.5	22.1	22.1	22.0	21.7	20.7	20.6	20.5	20.3	20.3	20.5	20.6	20.6	20.5	20.4	20.5	20.4	20.5	20.5	20.6	20.8	20.6	20.5	20.3	22.1	20.8	24
4	20.2	21.1	21.2	21.0	20.3	20.9	21.7	20.4	20.2	20.5	20.3	20.6	20.4	20.5	20.4	20.6	20.7	20.7	20.5	20.4	20.7	20.3	20.7	20.1	20.1	21.7	20.6	24
5	20.9	20.1	21.7	21.7	20.8	21.5	21.3	20.7	20.3	20.4	20.4	20.4	20.5	20.4	20.6	20.8	20.8	20.7	20.8	20.9	20.4	20.5	20.2	20.0	20.0	21.7	20.7	24
6	20.7	21.6	21.8	21.9	22.0	20.8	20.2	20.5	20.5	20.3	20.7	20.7	21.1	20.8	20.8	21.1	20.7	20.6	20.6	20.5	20.5	20.3	20.1	20.3	20.1	22.0	20.8	24
7	20.5	20.5	20.3	20.1	20.5	20.4	20.3	20.2	20.2	20.2	20.4	20.2	20.6	20.5	20.6	20.7	20.5	20.8	20.6	20.7	20.6	20.5	20.4	20.6	20.1	20.8	20.5	24
8	20.3	20.5	20.6	20.4	20.8	20.2	20.6	20.3	20.3	20.7	20.2	20.7	20.6	20.5	20.7	20.6	20.5	20.7	20.8	20.5	20.6	20.6	20.6	20.6	20.2	20.8	20.5	24
9	20.5	20.6	20.4	20.5	20.4	20.4	20.4	20.4	20.3	20.5	20.5	20.5	20.7	20.5	20.9	20.5	20.6	20.7	20.6	20.5	20.3	20.4	20.3	20.6	20.3	20.9	20.5	24
10	19.9	19.9	21.4	19.8	21.6	21.9	20.9	20.3	20.3	20.4	20.5	20.3	20.5	20.6	20.4	20.6	20.7	20.4	20.2	20.4	20.6	20.9	20.7	21.2	19.8	21.9	20.6	24
11	21.2	19.8	19.5	19.7	19.6	19.5	20.2	20.8	20.2	21.0	20.6	20.5	20.3	20.6	20.3	20.6	20.2	20.2	20.6	20.4	20.3	20.2	21.0	19.7	19.5	21.2	20.3	24
12	20.8	19.9	20.6	20.6	20.4	20.4	20.5	20.6	20.4	20.6	20.3	20.4	20.4	20.4	20.6	20.5	20.6	20.7	20.4	20.5	20.4	20.2	20.6	20.3	19.9	20.8	20.5	24
13	19.9	19.7	21.3	19.8	20.9	21.4	19.9	20.2	20.5	20.3	20.4	20.3	20.4	20.7	20.8	20.6	20.6	20.6	20.4	20.5	20.4	20.4	20.4	20.5	19.7	21.4	20.5	24
14	20.6	21.0	21.0	21.1	20.9	20.3	20.8	20.8	20.3	20.6	20.7	21.3	21.7	20.7	20.4	20.1	20.8	20.3	20.1	20.1	19.5	19.2	18.8	18.8	18.8	21.7	20.4	24
15	18.8	18.9	18.8	18.9	18.9	18.8	18.8	19.3	19.2	19.2	19.8	20.3	20.8	20.8	20.8	20.9	21.5	21.4	21.3	21.0	20.5	20.2	19.9	18.8	21.5	20.0	24	
16	19.8	19.8	19.7	19.5	19.2	19.0	19.1	19.2	19.7	20.2	21.0	21.3	21.3	21.2	21.5	21.5	21.5	21.7	21.7	21.3	21.3	20.8	20.3	19.9	19.0	21.7	20.5	24
17	19.3	19.4	19.6	19.7	19.6	19.6	19.1	19.1	19.6	20.3	20.4	21.0	21.2	21.5	21.3	21.7	21.5	21.8	21.9	21.8	21.7	21.2	20.0	19.2	19.1	21.9	20.5	24
18	19.7	19.8	19.8	19.8	20.0	19.9	19.7	19.6	19.4	19.1	19.6	19.5	19.8	20.5	20.9	20.9	20.6	20.3	20.7	21.1	21.2	20.3	19.6	19.9	19.1	21.2	20.1	24
19	20.0	20.0	20.1	20.1	20.1	19.9	19.6	19.3	19.3	19.9	20.7	21.3	21.4	21.4	21.6	21.9	21.9	21.7	21.7	21.2	21.0	20.8	20.4	20.1	19.3	21.9	20.6	24
20	19.8	19.4	18.8	19.1	19.0	18.9	19.1	19.0	19.4	20.1	20.7	21.4	21.5	21.6	21.5	21.2	21.2	21.1	20.9	21.1	20.6	20.2	19.7	19.3	18.8	21.6	20.2	24
21	19.1	19.0	19.2	19.3	19.2	19.3	19.3	19.4	19.4	19.1	19.0	19.0	19.0	19.0	19.1	19.3	19.3	19.2	19.3	19.1	19.2	19.3	19.1	19.2	19.0	19.4	19.2	24
22	19.3	19.5	19.8	19.9	20.1	20.0	19.7	19.5	19.2	19.1	19.3	19.8	20.3	20.3	21.1	21.6	21.8	21.7	21.8	21.9	21.8	21.0	20.1	19.2	19.1	21.9	20.3	24
23	19.4	19.6	19.7	19.9	20.0	19.9	19.3	19.3	20.2	20.7	21.3	21.1	21.3	21.6	21.5	21.2	21.5	21.8	21.7	21.7	22.0	21.2	19.9	19.1	19.1	22.0	20.6	24
24	18.9	19.0	19.1	19.1	19.3	19.4	19.1	19.6	20.4	20.7	21.1	21.4	21.4	21.5	21.6	22.1	21.8	21.8	21.9	21.8	21.9	21.4	20.8	20.1	18.9	22.1	20.6	24
25	19.3	19.0	18.8	18.9	18.9	19.0	19.3	20.5	21.2	21.3	21.6	21.9	21.7	21.8	22.1	21.7	21.9	21.9	21.9	21.9	21.9	21.7	21.5	21.7	18.8	22.1	20.9	24
26	21.1	21.6	21.5	21.3	20.8	20.9	21.3	21.4	21.4	21.6	21.6	21.6	21.8	21.9	21.8	21.8	21.8	21.7	21.3	21.4	20.9	20.6	20.7	20.7	20.6	21.9	21.4	24
27	20.3	19.9	19.5	19.2	18.9	18.8	19.0	19.0	19.1	19.5	20.3	21.0	21.2	20.9	20.9	20.7	20.8	20.3	19.9	19.6	19.3	19.1	19.4	19.3	18.8	21.2	19.8	24
28	19.2	19.1	19.1	19.0	19.0	19.1	18.9	20.8	P	22.5	22.3	22.0	21.8	21.7	20.7	21.0	21.5	21.6	21.7	20.9	21.3	21.6	21.9	22.1	18.9	22.5	20.8	23
29	22.0	22.2	22.4	22.5	22.5	22.5	22.1	21.7	20.9	22.1	21.8	21.9	21.6	21.5	21.6	21.8	21.6	22.1	22.6	22.6	22.9	22.9	23.0	23.1	20.9	23.1	22.2	24
30	23.1	23.1	23.1	23.0	23.1	23.2	23.1	23.1	22.7	22.5	22.3	22.4	22.3	22.1	22.1	22.1	21.9	22.1	22.6	22.6	22.9	22.9	23.0	23.1	21.5	23.2	22.5	24
HOURLY MAX	23.1	23.1	23.1	23.0	23.1	23.2	23.1	23.1	22.7	22.5	22.3	22.4	22.3	22.1	22.1	22.1	21.9	22.1	22.6	22.6	22.9	22.9	23.0	23.1				
HOURLY AVG	20.2	20.2	20.4	20.3	20.3	20.3	20.2	20.2	20.2	20.5	20.6	20.8	20.9	20.9	20.9	21.0	21.0	21.0	21.0	20.9	20.9	20.7	20.5	20.3				

STATUS FLAG CODES

C	- MONTHLY CALIBRATION	Q	- QUALITY ASSURANCE
C1	- REPEAT CALIBRATION	R	- RECOVERY
Y	- MAINTENANCE	X	- MACHINE MALFUNCTION
S	- DAILY ZERO/SPAN CHECK	G	- OUT FOR REPAIR
S1	- REPEAT ZERO/SPAN CHECK	P	- POWER FAILURE


24 HR AVERAGES June 2017



MONTHLY SUMMARY

MINIMUM 1-HR AVERAGE:	18.8	°C	@ HOUR	22	ON DAY	14
MAXIMUM 1-HR AVERAGE:	23.2	°C	@ HOUR	5	ON DAY	30
MAXIMUM 24-HR AVERAGE:	22.5	°C			ON DAY	30
OPERATIONAL TIME:						719 hrs
AMD OPERATION UPTIME:						99.9 %
STANDARD DEVIATION:	0.9		MONTHLY AVERAGE:			20.6 °C

STATION TEMPERATURE Hourly Averages (StnTPX °C)



APPENDIX II
EQUIPMENT CALIBRATION RESULTS

SULPHUR DIOXIDE



API 100A Sulphur Dioxide Analyzer Calibration

Date: June 6, 2017	Barometer ID #/Last Cert. Date/B.P.: Brunton 5490, December 4, 2016	27.96 inHg
Company/Airshed: PRAMP	Thermometer ID #/Last Cert. Date/Temp: fisher Scientific 160348895, April 8, 2017	21.4 degrees
Location/Station Name: 842B	Weather Conditions: Mainly sunny	
Parameter: Sulphur Dioxide	Calibration Purpose: routine monthly	
Start Time 24 hr. (mst): 8:30	Performed By/Reviewer: Limin Li	Trina Whitsitt
End Time 24 hr. (mst): 12:10	Cal Gas Expiry Date: December 8, 2019	
Calibration Method: Gas Dilution	Converter Model & s/n (if applicable): n/a	

Analyzer:		
ID# or Serial Number: 838	Range ppb: 500	
Last Calibration Date: May 10, 2017	As Found C.F.: 0.999	
Previous C.F.: 0.998	New C.F.: 0.999	

Calibration Standards:		Standard Calibration Points for Ranges	
Low Flow Meter ID/Cert. Date: Defender 1 Low ID# 152019 November 21, 2016		Point	ppb
High Flow Meter ID/Cert. Date: Defender 1 High ID# 148944 November 21, 2016		High	380
Calibrator ID/Cert. Date: Sabio 2010 17200415, May 16, 2017		Mid	180
Cal Gas Cylinder I.D. #: EY0000769		Low	90
Cal Gas Conc. (ppm): 50.5			


ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015

Point	Calibrator Flow Rates (cc/min)			Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):
	Diluent	Cal Gas	Total	(ppb)	(ppb)	
as found zero	4952	0.00	4952	0.0	-0.1	n/a
as found high	4914	37.61	4952	383.5	384.0	0.999
adjusted zero	4952	0.00	4952	0.0	0.0	n/a
adjusted high	4914	37.61	4952	383.5	384.0	0.999
mid	4989	17.92	5007	180.7	182.0	0.993
low	5009	9.16	5018	92.2	91.4	1.009
calibrator zero	4952	0.00	4952	0.0	0.2	n/a
Average C.F. =						1.000

Linear Regression/Calibration Results:

Correlation Coefficient =	1.000	LIMITS
Slope =	0.998	> or = 0.995
b (Intercept as % of full scale) =	0.03%	.95-1.05
% change in C.F. from last cal =	-0.06%	± 3% F.S.
		± 10%

API 100A Sulphur Dioxide Analyzer Calibration



<p style="text-align: center;">As found:</p> Slope: 1.049 Offset: 19.3 Hvps: 685 Dcps: 2545 Rcell Temp: 50.8 Box Temp: 29.1 Pmt Temp: 7.3 Izs Temp: 60.1 Converter Temp: 667.2 Pres: 26.7 Samp Fl: 647 Pmt: 55.7 Uv Lamp: 2146 Lamp Ratio: 87 Str Lgt: 10.1 Drk Pmt: 33.2 Drk Lmp: -7.1 Expected Value: 238.9	<p style="text-align: center;">As left:</p> Slope: 1.049 Offset: 19.3 Hvps: 685 Dcps: 2545 Rcell Temp: 50.8 Box Temp: 29.1 Pmt Temp: 7.3 Izs Temp: 60.1 Converter Temp: 667.2 Pres: 26.7 Samp Fl: 647 Pmt: 55.7 Uv Lamp: 2146 Lamp Ratio: 87 Str Lgt: 10.1 Drk Pmt: 33.2 Drk Lmp: -7.1 Expected Value: 238.9
---	--


Comments:

The analyzer sample inlet filter was changed.

No high point adjustment was required/made. The "as found" high value was copied to the "adjusted zero" value field for linearity calculation purposes.

Flow measurements performed after mid-point.

SO2[ppb] Station: PRAMP_842 Daily: 17.06.06 Type: AVG 1 Min. [1 Min.]



— SO2[ppb]

TOTAL REDUCED SULPHUR



Thermo 43i Total Reduced Sulphur Analyzer Calibration

<input checked="" type="checkbox"/> remove	
Date: June 6, 2017 Company/Airshed: PRAMP Location/Station Name: 842B Parameter: Total Reduced Sulphur Start Time 24 hr. (mst): 8:30 End Time 24 hr. (mst): 13:00 Calibration Method: Gas Dilution	Barometer ID #/Last Cert. Date/B.P.: Brunton 5490, December 4, 2016 27.96 inHg Thermometer ID #/Last Cert. Date/Temp: fisher Scientific 160348895, April 8, 2017 21.4 degrees Weather Conditions: Mainly sunny Calibration Purpose: routine monthly Performed By/Reviewer: Limin Li Trina Whitsitt <input checked="" type="checkbox"/> skip Cal Gas Expiry Date: January 6, 2018 Converter Model & s/n (if applicable): CDNOVA CDN-101 & s/n:553

Analyzer:	
ID# or Serial Number: 1162460023 Last Calibration Date: May 10, 2017 Previous C.F.: 1.000	Range ppb: 100 As Found C.F.: 1.030 New C.F.: 1.000

Calibration Standards:		Standard Calibration Points for Ranges	
Low Flow Meter ID/Cert. Date: Defender 1 Low ID# 152019 November 21, 2016		Point	ppb
High Flow Meter ID/Cert. Date: Defender 1 High ID# 148944 November 21, 2016		High	78
Calibrator ID/Cert. Date: Environics 2000 1991, March 16, 2017		Mid	38
Cal Gas Cylinder I.D. # : BLM002508		Low	19
Cal Gas Conc. (ppm): 10.2			


ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015

Point	Calibrator Flow Rates (cc/min)			Calculated Concentration:	Indicated Concentration:	Correction Factors (C.F.):
	Diluent	Cal Gas	Total	(ppb)	(ppb)	
as found zero	7486	0.00	7486	0.0	-0.1	n/a
as found high	7414	57.90	7472	79.0	76.6	1.030
adjusted zero	7486	0.00	7486	0.0	0.0	n/a
adjusted high	7414	57.90	7472	79.0	79.0	1.000
mid	7468	28.17	7496	38.3	37.8	1.014
low	7490	14.07	7504	19.1	18.5	1.034
calibrator zero	7486	0.00	7486	0.0	0.0	n/a
Average C.F.=						1.016

Linear Regression/Calibration Results:

Correlation Coefficient = 1.000 Slope = 0.998 b (Intercept as % of full scale)= 0.36% % change in C.F. from last cal= -3.05%	LIMITS > or = 0.995 .95-1.05 ± 3% F.S. ± 10%
---	--

Thermo 43i Total Reduced Sulphur Analyzer Calibration




As found: Bkg: 2.54 Coef: 0.825 Pmt: -725.6 Flash: 983 Internal: 29.1 Chamber: 45.1 Perm Oven Gas: 45.00 Perm Oven Heater: 44.11 Pressure: 667.2 Sample Flow: 0.410 Lamp Intensity: 90 Converter: 850 Converter Set: 850 Averaging Time: 120 Expected Value: 56.5	As left: Bkg: 2.52 Coef: 0.850 Pmt: -725.6 Flash: 988 Internal: 29.3 Chamber: 45.1 Perm Oven Gas: 45.00 Perm Oven Heater: 44.11 Pressure: 665.4 Sample Flow: 0.408 Lamp Intensity: 90 Converter: 850 Converter Set: 850 Averaging Time: 120 Expected Value: 57.6
---	--

Comments:

The analyzer sample inlet filter was changed.

The analyzer cooling fan filter(s) were cleaned.

Flow measurements performed after mid-point



— TRS[ppb]

TOTAL HYDROCARBON



Thermo 55i Methane/Non-Methane Analyzer Calibration

Date: June 6, 2017	Barometer ID #/Last Cert. Date/B.P.: fisher Scientific 05544, December 5, 2016	27.96 inHg
Company/Airshed: PRAMP	Thermometer ID #/Last Cert. Date/Temp: fisher Scientific 160348895, April 8, 2017	21 degrees
Location/Station Name: 842B	Weather Conditions: Mainly sunny	
Parameter: CH ₄ / NMHC / THC	Calibration Purpose: routine monthly	
Start/End Time 24 hr. (mst): 11:30/15:55	Performed By/Reviewer: Limin Li	Trina Whitsitt
Calibration Method: Gas Dilution	Cal Gas Expiry Date: November 24, 2022	

Analyzer:			Correction Factors:		
ID# or Serial Number: 1433563261	Previous C.F.:	As Found C.F.:	New C.F.:		
Measured Flow: 1.130 lpm	CH ₄ = 0.997	0.964	1.002		
Last Calibration Date: May 10, 2017	NMHC = 0.999	1.004	1.001		
Range ppm: 20 CH ₄ /20 NMHC/40 THC	THC = 0.998	0.983	1.002		

Calibration Standards:				
Low Flow Meter ID/Cert. Date: Defender 1 Low ID# 152019 November 21, 2016	Standard Calibration Points for Analyzer Range of 20/20/40 ppm			
High Flow Meter ID/Cert. Date: Defender 1 High ID# 148944 November 21, 2016	Point	CH ₄	NMHC	THC
Calibrator ID/Cert. Date: Sabio 2010 17200415, May 16, 2017	High	13.00	13.00	26.00
Cal Gas Cylinder I.D. #: LL165367	Mid	7.00	7.00	14.00
CH ₄ Cylinder Conc.: 590.0 207.0 =C ₁ H ₄ Cylinder Conc.	Low	3.00	3.00	6.00
CH ₄ as C ₂ H ₆ : 569.3 1159.3 =total CH ₄ equivalent				

ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015										Correction Factors:		
Calibrator Flow Rates (cc/min)				Calculated CH ₄ (ppm)	Calculated NMHC (ppm)	Calculated THC (ppm)	Indicated CH ₄ (ppm)	Indicated NMHC (ppm)	Indicated THC (ppm)	CH ₄	NMHC	THC
Point	Diluent	Cal Gas	Total Flow									
as found zero	2503	0.00	2503	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a
as found high	2513	62.25	2575	14.26	13.76	28.02	14.80	13.70	28.50	0.964	1.004	0.983
adjusted zero	2503	0.00	2503	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a
adjusted high	2513	62.25	2575	14.26	13.76	28.02	14.23	13.75	27.98	1.002	1.001	1.002
mid	2505	31.45	2536	7.32	7.06	14.38	7.33	7.04	14.37	0.998	1.003	1.000
low	2507	14.23	2521	3.33	3.21	6.54	3.34	3.28	6.62	0.997	0.980	0.988
calibrator zero	2503	0.00	2503	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a
										Average C.F.=		
										0.999 0.994 0.997		




Linear Regression/Calibration Results:				
	CH ₄	NMHC	THC	LIMITS
Correlation Coefficient =	1.000	1.000	1.000	> or = 0.995
Slope =	0.998	0.997	0.997	.95-1.05
b (Intercept as % of full scale) =	0.06%	0.13%	0.10%	± 3% F.S.
% change in C.F. from last cal =	3.34%	-0.55%	1.47%	± 10%

<p>Interface Board Voltages: Bias Supply: -300.9</p> <p>Temperatures: Detector Oven: 175.1 Filter: 175.1 Column Oven: 75.1 Internal: 29.4</p> <p>Cylinder Pressures/reg.: Carrier: 1000 50 Fuel: 2100 50 Span Gas: 1600 16 Zero Air Generator: 45</p> <p>Internal Pressures: Carrier: 28.6 Fuel: 37.6 Air: 34.3</p> <p>FID Status: Status: LIT Counts: 25474 Flame: 350.1 Det Base: 175.1</p> <p>Flame and Power Stats: Last Power On: 07Apr2017 07:56:39 Flameouts: 1 Det Oven at Start: 160.5 Col Oven at Start: 72.5</p> <p>Calibration History: Time: 10MAY17 12:51 Type: SPAN Status: GOOD Check/Adjust: ADJUST CH₄ Span Conc: 13.41 CH₄ SP Ratio: 0.000716 CH₄ RT: 12.4 CH₄ PK IDX: 22 CH₄ PK HT: 18738 NM Span Conc: 12.99 NM SP Ratio: 0.000151</p>	<p>Calibration History cnt'd: NM Peak Area: 85969</p> <p>Crucial Settings: Methane Start: 8 Methane End: 16 Backflush: 18 NMHV Start: 26 NMHC End: 56</p> <p>Run History>1: Date: 06JUN2017 Time: 10:29 CH₄ PK HT: 2654 CH₄ RT: 12.4 CH₄ Baseline: 1917 CH₄ LOD: 325 CH₄ SD: 108 CH₄ CONC: 1.90 NM PK HT: 169 NM Peak Area: 32 NM CONC: 0 NM Base Start: 1875 NM Base End: 1909 NM LOD: 18 NM Start IDX: 17 NM End IDX: 46 NM Max Slope: 1.3e+01 NM Min Slope: -1.1e+01 NM PT Count: 0 Expected Values: Previous CH₄: 10.14 Previous NMHC: 10.83 Previous THC: 20.98 New CH₄: 10.14 New NMHC: 10.83 New THC: 20.98</p>	<p>As found:</p> <p>As left:</p>
---	---	----------------------------------


Comments:
 The analyzer sample inlet filter was changed.
 No zero adjustment was required/made. As found zero values were copied to adjusted zero values for linearity calculation purposes.
 The analyzer cooling fan filter(s) were cleaned.

Date: June 6, 2017
Company/Airshed: PRAMP
Location/Station Name: 842B

Start/End Time 24 hr. (mst): 11:30/15:55
Calibration Purpose: routine monthly
Calibration Method: Gas Dilution



Station: PRAMP_842 Daily: 17.06.06 Type: AVG 1 Min. [1 Min.]



— CH4[ppm] — NMHC[ppm]



Thermo 55i Methane/Non-Methane Analyzer Calibration

Date:	June 14, 2017	Barometer ID #/Last Cert. Date/B.P.:	fisher Scientific 05544, December 5, 2016 27.73 inHg
Company/Airshed:	PRAMP	Thermometer ID #/Last Cert. Date/Temp:	fisher Scientific 160348895, April 8, 2017 21 degrees
Location/Station Name:	842B	Weather Conditions:	Mainly cloudy with clear breaks
Parameter:	CH ₄ / NMHC / THC	Calibration Purpose:	shut down
Start/End Time 24 hr. (mst):	09:15/11:15	Performed By/Reviewer:	Limin Li / Trina Whitsitt
Calibration Method:	Gas Dilution	Cal Gas Expiry Date:	November 24, 2022

Analyzer:		Correction Factors:			
ID# or Serial Number:	1433563261	Previous C.F.:	As Found C.F.:	New C.F.:	
Measured Flow:	1.130 lpm	CH ₄ =	1.002	1.028	n/a
Last Calibration Date:	June 6, 2017	NMHC =	1.001	1.011	n/a
Range ppm:	20 CH ₄ /20 NMHC/40 THC	THC =	1.002	1.020	n/a

Calibration Standards:		Standard Calibration Points for Analyzer Range of 20/20/40 ppm			
Low Flow Meter ID/Cert. Date:	Defender 1 Low ID# 152019 November 21, 2016	Point	CH ₄	NMHC	THC
High Flow Meter ID/Cert. Date:	Defender 1 High ID# 148944 November 21, 2016	High	13.00	13.00	26.00
Calibrator ID/Cert. Date:	Sabio 2010 17200415, May 16, 2017	Mid	7.00	7.00	14.00
Cal Gas Cylinder I.D. #:	LL165367	Low	3.00	3.00	6.00
CH ₄ Cylinder Conc. =	590.0 207.0 = C ₂ H ₆ Cylinder Conc.				
CH ₄ as C ₂ H ₆ =	569.3 1159.3 = total CH ₄ equivalent				

ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015

Calibrator Flow Rates (cc/min)				Calculated CH ₄ (ppm)	Calculated NMHC (ppm)	Calculated THC (ppm)	Indicated CH ₄ (ppm)	Indicated NMHC (ppm)	Indicated THC (ppm)	Correction Factors:		
Point	Diluent	Cal Gas	Total Flow							CH ₄	NMHC	THC
as found zero	2459	0.00	2459	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a
as found high	2463	60.00	2523	14.03	13.54	27.57	13.65	13.39	27.04	1.028	1.011	1.020
mid	2458	31.16	2489	7.39	7.13	14.51	7.26	7.10	14.36	1.017	1.004	1.011
low	2459	14.25	2473	3.40	3.28	6.68	3.36	3.32	6.68	1.012	0.988	1.000
Average C.F. =										1.019	1.001	1.010




Linear Regression/Calibration Results:				
	CH ₄	NMHC	THC	LIMITS
Correlation Coefficient =	1.000	1.000	1.000	> or = 0.995
Slope =	0.972	0.988	0.980	0.90-1.10
b (Intercept as % of full scale) =	0.18%	0.20%	0.19%	± 3% F.S.
% change in C.F. from last cal =	-2.59%	-1.00%	-1.75%	± 10%

<p>Interface Board Voltages: Bias Supply: -299.9</p> <p>Temperatures: Detector Oven: 175 Filter: 175 Column Oven: 75 Internal: 26.6</p> <p>Cylinder Pressures/reg.: Carrier: 800 50 Fuel: 1800 50 Span Gas: 1450 16 Zero Air Generator: 45</p> <p>Internal Pressures: Carrier: 28.6 Fuel: 37.6 Air: 34.3</p> <p>FID Status: Status: LIT Counts: 22559 Flame: 348.2 Det Base: 175</p> <p>Flame and Power Stats: Last Power On: 07Apr2017 07:56:39 Flameouts: 1 Det Oven at Start: 160.5 Col Oven at Start: 72.5</p> <p>Calibration History: Time: 06June17 13:03 Type: SPAN Status: GOOD Check/Adjust: ADJUST CH₄ Span Conc: 14.26 CH₄ SP Ratio: 0.000691 CH₄ RT: 12.4 CH₄ PK IDX: 22 CH₄ PK HT: 20626 NM Span Conc: 13.76 NM SP Ratio: 0.000152</p>	<p>Calibration History cnt'd: NM Peak Area: 90586</p> <p>Crucial Settings: Methane Start: 8 Methane End: 16 Backflush: 18 NMHV Start: 26 NMHC End: 56</p> <p>Run History>1: Date: 17JUN2017 Time: 09:22 CH₄ PK HT: 0 CH₄ RT: 13.2 CH₄ Baseline: 1811 CH₄ LOD: 43 CH₄ SD: 14 CH₄ CONC: 0.00 NM PK HT: 0 NM Peak Area: 0 NM CONC: 0.00 NM Base Start: 1827 NM Base End: 1859 NM LOD: 25 NM Start IDX: 22 NM End IDX: 93 NM Max Slope: 1.2e+00 NM Min Slope: -6.8e-01 NM PT Count: 0 Previous CH₄: 9.76 Previous NMHC: 10.98 Previous THC: 20.77 New CH₄: 9.76 New NMHC: 10.98 New THC: 20.77</p>	<p>As found:</p> <p>Bias Supply: -299.9</p> <p>Detector Oven: 175</p> <p>Filter: 175</p> <p>Column Oven: 75</p> <p>Internal: 26.6</p> <p>Carrier: 800 50</p> <p>Fuel: 1800 50</p> <p>Span Gas: 1450 16</p> <p>Zero Air Generator: 45</p> <p>Carrier: 28.6</p> <p>Fuel: 37.6</p> <p>Air: 34.3</p> <p>Status: LIT</p> <p>Counts: 22559</p> <p>Flame: 348.2</p> <p>Det Base: 175</p> <p>Last Power On: 07Apr2017 07:56:39</p> <p>Flameouts: 1</p> <p>Det Oven at Start: 160.5</p> <p>Col Oven at Start: 72.5</p> <p>Time: 06June17 13:03</p> <p>Type: SPAN</p> <p>Status: GOOD</p> <p>Check/Adjust: ADJUST</p> <p>CH₄ Span Conc: 14.26</p> <p>CH₄ SP Ratio: 0.000691</p> <p>CH₄ RT: 12.4</p> <p>CH₄ PK IDX: 22</p> <p>CH₄ PK HT: 20626</p> <p>NM Span Conc: 13.76</p> <p>NM SP Ratio: 0.000152</p>
--	---	---

Comments:
Flow measurements performed after mid-point

Date: June 14, 2017
Company/Airshed: PRAMP
Location/Station Name: 842B

Start/End Time 24 hr. (mst): 09:15/11:15
Calibration Purpose: shut down
Calibration Method: Gas Dilution





Thermo 55i Methane/Non-Methane Analyzer Calibration

Date:	June 14, 2017	Barometer ID #/Last Cert. Date/B.P.:	fisher Scientific 05544, December 5, 2016	27.70 inHg
Company/Airshed:	PRAMP	Thermometer ID #/Last Cert. Date/Temp:	fisher Scientific 160348895, April 8, 2017	21 degrees
Location/Station Name:	842B	Weather Conditions:	Mix of sun and clouds	
Parameter:	CH ₄ / NMHC / THC	Calibration Purpose:	as found	
Start/End Time 24 hr. (mst):	14:50/17:50	Performed By/Reviewer:	Limin Li	not yet reviewed
Calibration Method:	Gas Dilution	Cal Gas Expiry Date:	November 24, 2022	

Analyzer:		Correction Factors:			
ID# or Serial Number:	1236656188	Previous C.F.:	As Found C.F.:	New C.F.:	
Measured Flow:	1.212 lpm	CH ₄ =	n/a	1.000	n/a
Last Calibration Date:	n/a	NMHC =	n/a	1.000	n/a
Range ppm:	20 CH ₄ /20 NMHC/40 THC	THC =	n/a	1.000	n/a

Calibration Standards:		Standard Calibration Points for Analyzer Range of 20/20/40 ppm			
Low Flow Meter ID/Cert. Date:	Defender 1 Low ID# 152019 November 21, 2016	Point	CH ₄	NMHC	THC
High Flow Meter ID/Cert. Date:	Defender 1 High ID# 148944 November 21, 2016	High	13.00	13.00	26.00
Calibrator ID/Cert. Date:	Sabio 2010 17200415, May 16, 2017	Mid	7.00	7.00	14.00
Cal Gas Cylinder I.D. #:	LL165367	Low	3.00	3.00	6.00
CH ₄ Cylinder Conc. =	590.0	207.0	=C ₃ H ₈ Cylinder Conc.		
CH ₄ as C ₃ H ₈ =	569.3	1159.3	=total CH ₄ equivalent		

ALL POINTS ARE 15 MINUTES OF STABILITY AS OF SEPTEMBER 23, 2015

Calibrator Flow Rates (cc/min)				Calculated CH ₄ (ppm)	Calculated NMHC (ppm)	Calculated THC (ppm)	Indicated CH ₄ (ppm)	Indicated NMHC (ppm)	Indicated THC (ppm)	Correction Factors:		
Point	Diluent	Cal Gas	Total Flow							CH ₄	NMHC	THC
as found zero	2472	0.00	2472	0.00	0.00	0.00	0.00	0.00	0.00	n/a	n/a	n/a
as found high	2473	60.16	2533	14.01	13.52	27.53	14.01	0.00	27.53	1.000	1.000	1.000
Average C.F. =										n/a	n/a	n/a

Linear Regression/Calibration Results:

Correlation Coefficient =	CH ₄	NMHC	THC	LIMITS
Slope =	n/a	n/a	n/a	> or = 0.995
b (Intercept as % of full scale) =	n/a	n/a	n/a	.95-1.05
% change in C.F. from last cal =	n/a	n/a	n/a	± 3% F.S.
				± 10%




Interface Board Voltages:	Bias Supply:	-287.8	Calibration History cnt'd:	NM Peak Area:	84568	
Temperatures:	Detector Oven:	175	Crucial Settings:	Methane Start:	8	
	Filter:	175		Methane End:	16	
	Column Oven:	75		Backflush:	18	
Cylinder Pressures/reg.:	Internal:	29.8	Run History-1:	NMHV Start:	24	
	Carrier:	800		50	NMHC End:	56
	Fuel:	1800		50	Date:	17JUN2017
	Span Gas:	1450		16	Time:	16:24
Internal Pressures:	Zero Air Generator:	48	CH ₄ PK HT:	0		
	Carrier:	30.5	CH ₄ RT:	12.0		
	Fuel:	40.0	CH ₄ Baseline:	1449		
FID Status:	Air:	24.8	CH ₄ LOD:	25		
	Status:	LIT	CH ₄ SD:	8		
	Counts:	32906	CH ₄ CONC:	0.00		
	Flame:	335.7	NM PK HT:	0		
Flame and Power Stats:	Det Base:	175	NM Peak Area:	0		
	Last Power On:	14JUN2017 11:10:35	NM CONC:	0.00		
	Flameouts:	1	NM Base Start:	1438		
	Det Oven at Start:	152.0	NM Base End:	1442		
	Col Oven at Start:	113.2	NM LOD:	13		
Calibration History:	Time:	14JUN17 15:01	NM Start IDX:	37		
	Type:	SPAN	NM End IDX:	76		
	Status:	GOOD	NM Max Slope:	3.7e-01		
	Check/Adjust:	ADJUST	NM Min Slope:	-2.0e-01		
	CH ₄ Span Conc:	14.01	NM PT Count:	0		
	CH ₄ SP Ratio:	0.000732	Expected Values:	Previous CH ₄ :	9.76	
	CH ₄ RT:	12.4	Previous NMHC:	10.98		
	CH ₄ PK IDX:	22	Previous THC:	20.77		
	CH ₄ PK HT:	19128	New CH ₄ :	9.76		
	NM Span Conc:	13.52	New NMHC:	10.98		
NM SP Ratio:	0.00016	New THC:	20.77			


Comments:
A column conditioning was performed.
Flow measurements performed after mid-point

Around 3 hours column conditioning was performed before the installation calibration.

Date: June 14, 2017
Company/Airshed: PRAMP
Location/Station Name: 842B

Start/End Time 24 hr. (mst): 14:50/17:50
Calibration Purpose: as found
Calibration Method: Gas Dilution





— CH4[ppm] — NMHC[ppm]

WIND SYSTEM



Meteorological Sensor Audit/Calibration

Location Information

Company:	PRAMP	Performed By:	Limin Li
Audit Location:	842b	Reviewed By:	Trina Whitsitt
Audit Date:	April 5, 2017	Start /EndTime (mst):	16:35 / 18:10

Wind Sensor Information

Sensor ID Data:		Sensor Outputs:	
Sensor Make:	RM Young	Velocity Voltage Output Range:	0-1 V
Sensor Model:	05305VK	Velocity Unit Output Range:	0-200 km/h
Serial #:	92411	Direction Voltage Output Range:	0-1 V
Previous Cal/Audit Date:	February 14, 2017	Direction Unit Output Range:	0-360 degrees

Wind Calibrator Information

Calibrator Make/ Model:	RM Young 18802	Serial #:	CA 0309
Maxxam Unit ID #:	13-3357	Certification Date:	October 6, 2016

Wind Speed Audit Data ****+/- 2% of the average correction factor is the limit****

RPM	Wind Speed Generated kph	Clockwise Wind Speed kph	Counter Clockwise Wind Speed kph	Correction Factor
0	0	0.0	0.0	-
1000	18.4	18.5	18.5	0.995
2000	36.9	36.9	36.9	1.000
3000	55.3	55.4	55.4	0.999
4000	73.7	73.8	73.8	0.999
5000	92.2	92.2	92.2	1.000
6000	110.6	110.7	110.7	0.999
7000	129.0	129.1	129.1	0.999
8000	147.4	147.5	147.5	0.999
9000	165.9	165.9	165.9	1.000
10000	184.3	184.3	184.3	1.000
The audit meets AMD requirements.			Average Correction Factor=	0.999

Wind Direction Audit Data ****+/- 5° of the absolute average degrees difference for all points is the limit****

Generated Wind Direction 0-360 (Up)	Generated Wind Direction 360-0 (Down)	Indicated Wind Direction 0-360 (Up)	Indicated Wind Direction 360-0 (Down)	Degrees Difference 0-360 (Up)	Degrees Difference 360-0 (Down)	Average Absolute Degrees Difference
0	355	1	351	0.8	3.6	2.2
30	330	31	327	-1.3	2.9	2.1
60	300	62	297	-1.7	3.0	2.3
90	270	91	268	-1.1	1.9	1.5
120	240	121	239	-0.7	1.5	1.1
150	210	150	209	-0.2	0.7	0.4
180	180	181	180	-0.6	-0.2	0.4
210	150	210	150	0.1	0.3	0.2
240	120	239	120	0.9	-0.3	0.6
270	90	268	91	1.6	-0.7	1.2
300	60	297	61	3.1	-1.3	2.2
330	30	327	31	3.0	-1.1	2.1
355	0	351	1	3.6	0.6	2.1
The audit meets AMD requirements.				Average Absolute Degrees Difference=		1.4

Comments: Adjust wind speed gain before calibration.

Meteorological Sensor Audit/Calibration

Location Information

Company: PRAMP	Performed By: Chris Wesson
Audit Location: 842b	Reviewed By: Trina Whitsitt
Audit Date: June 29, 2017	Start /EndTime (mst): 8:20 / 08:34
Calibration Purpose: installation	Weather Conditions: A few clouds

Wind Sensor Information

Sensor ID Data:	Sensor Outputs:
Sensor Make: RM Young	Velocity Voltage Output Range: 0-1V
Sensor Model: 05305VK	Velocity Unit Output Range: 0-200 km/h
Serial #: 110980	Direction Voltage Output Range: 0-1V
Previous Cal/Audit Date: n/a or unknown	Direction Unit Output Range: 0-360°

Wind Calibrator Information

Calibrator Make/ Model: RM Young	Serial #: CA 4039
Maxxam Unit ID #: n/a	Certification Date: February 24, 2017

Wind Speed Audit Data ****+/- 2% of the average correction factor is the limit****

RPM	Wind Speed Generated kph	Clockwise Wind Speed kph	Counter Clockwise Wind Speed kph	Correction Factor
0	0	0.0	0.1	-
1000	18.4	18.4	18.5	1.000
2000	36.9	36.8	36.8	1.002
3000	55.3	55.2	55.2	1.001
4000	73.7	73.6	73.6	1.002
5000	92.2	92.0	92.0	1.002
6000	110.6	110.4	110.4	1.002
7000	129.0	128.7	128.7	1.002
8000	147.4	147.2	147.2	1.002
9000	165.9	165.5	165.5	1.002
10000	184.3	184.3	183.9	1.001
The audit meets AMD requirements.			Average Correction Factor=	1.002

Wind Direction Audit Data ****+/- 5° of the absolute average degrees difference for all points is the limit****

Generated Wind Direction 0-360 (Up)	Generated Wind Direction 360-0 (Down)	Indicated Wind Direction 0-360 (Up)	Indicated Wind Direction 360-0 (Down)	Degrees Difference 0-360 (Up)	Degrees Difference 360-0 (Down)	Average Absolute Degrees Difference
0	355	1	355	0.8	-0.1	0.5
30	330	30	330	0.3	0.1	0.2
60	300	60	300	-0.1	-0.2	0.1
90	270	90	270	0.1	-0.2	0.1
120	240	121	240	-0.7	-0.3	0.5
150	210	150	210	0.5	0.0	0.3
180	180	180	180	0.4	-0.3	0.4
210	150	210	150	-0.4	0.1	0.3
240	120	240	120	-0.1	0.4	0.3
270	90	270	91	-0.2	-0.9	0.5
300	60	300	60	-0.3	-0.1	0.2
330	30	331	30	-0.5	-0.2	0.4
355	0	354	0	0.6	0.2	0.4
The audit meets AMD requirements.				Average Absolute Degrees Difference=		0.3

Comments:

CALIBRATORS

Company <u>Maxxam</u>		Operator: <u>Micheal Espiritu</u>	
Calibrator:		Flow Measurement Device:	
Make/Model	<u>Sabio 2010</u>	Make/Model	<u>Mesa Defender 530</u>
Serial Number	<u>17200415</u>	Serial Number	<u>L-152019 H-148944</u>
Last Verification Date	<u>May 2016</u>	Temperature (°C)	<u>25.0 C</u>
NO Cylinder S/N	<u>EY0000597</u>	Barometric Pressure	<u>697 mmhg</u>
NO [PPM]	<u>49.0</u>	NOx [PPM]	<u>49.0</u>
Expiry Date	<u>December 2019</u>		

Dilution Flow (sccm)		
Pt. #1 <u>5000</u>	Pt. #2 <u>5000</u>	Pt. #3 <u>5000</u>
Gas Flow (sccm)		
Pt. #1 <u>80</u>	Pt. #2 <u>40</u>	Pt. #3 <u>20</u>

Calibrator Flow (sccm)		Calculated Conc.(ppm)		Indicated Conc.(ppm)			% Difference vs Audit Gas	
Dilution	Gas	NO	NOx	NO	NO ₂	NOx	NO	NOx
5028	0.0	0.000	0.000	0.000	0.000	0.000	Limit ± 10%	
4930	78.7	0.783	0.783	0.809	-0.012	0.797	3%	2%
4936	38.6	0.383	0.383	0.396	-0.006	0.390	3%	2%
4935	19.4	0.193	0.193	0.199	-0.003	0.196	3%	2%
Absolute Average Percent Difference							3%	2%

LINEAR REGRESSION ANALYSIS *y=mx+b (where x=calculated concentration, y=indicated concentration)*

NO	LIMITS	NOx
Correlation= 1.0000	≥ 0.990	Correlation= 1.0000
m (Slope)= 1.0334	0.90-1.10	m (Slope)= 1.0181
b (Intercept % of FS)= -0.0105	± 3% F.S.	b (Intercept % of FS)= -0.0148

Flow	O ₂ Conc (LC)	NO Decrease	NO	NO ₂	NOX	% Diff. Vs Audit gas	
4930	0.000	0.000	0.806	-0.013	0.795	NO ₂	% Diff. Limit
4930	1.425	0.523	0.283	0.511	0.794	0%	± 10%
4930	0.825	0.278	0.528	0.266	0.795	0%	± 10%
4930	0.386	0.095	0.711	0.085	0.796	3%	± 10%
Absolute Average Percent Difference						1%	± 10%

LINEAR REGRESSION ANALYSIS *y=mx+b (where x=calculated concentration, y=indicated concentration)*

NO₂	LIMITS	
Correlation= 1.0000	≥ 0.995	
m (Slope)= 0.9998	0.90-1.10	
b (Intercept % of FS)= -1.1702	± 3% F.S.	

AENV Standards Audit Calibrator	NO_x Analyzer
Make/Model <u>Teco 146i</u>	Make/Model <u>Teco 42i</u>
Serial/AMU Number <u>AMU 1809</u>	Serial/AMU Number <u>AMU 1868</u>
SRM Gas Cylinder No. <u>CAL018101</u>	Last Calibration Date <u>May 16, 2017</u>
Cylinder Conc. (ppm) <u>48.79</u>	Full Scale (ppm) <u>1.0</u>
	Cylinder Gas Expiry Date <u>March 2019</u>

COMMENTS: Contains 50.4 ppm SO₂.

Auditor: Al Clark
Operator Signature:

Date: May 16, 2017
Location: McIntyre Center Edmonton

Company Maxxam **Operator:** Mike

Calibrator:		Flow Measurement Device:	
Make/Model	<u>Enviroics 2000</u>	Make/Model	<u>Bios Defender 530</u>
Serial Number	<u>1991</u>	Serial Number	<u>HI148944 Lo 152019</u>
Last Verification Date	<u>March 31, 2016</u>	Temperature (°C)	<u>24.5</u>
NO Cylinder S/N	<u>EY0000597</u>	Barometric Pressure	<u>699</u>
NO [PPM]	<u>49.0</u>	NOx [PPM]	<u>49.0</u>
Expiry Date	<u>December 8, 2019</u>		

Dilution Flow (sccm)		
Pt. #1	<u>4902</u>	Pt. #3 <u>4957</u>
Pt. #2	<u>4935</u>	
Gas Flow (sccm)		
Pt. #1	<u>79.3</u>	Pt. #3 <u>19.4</u>
Pt. #2	<u>38.7</u>	

Calibrator Flow (sccm)		Calculated Conc.(ppm)		Indicated Conc.(ppm)			% Difference vs Audit Gas	
Dilution	Gas	NO	NOx	NO	NO ₂	NOx	NO	NOx
4976	0.0	0.0000	0.0000	0.0001	0.0000	0.0001	Limit ± 10%	
4981	79.3	0.7801	0.7801	0.7898	0.0000	0.7898	1%	1%
4972	38.7	0.3814	0.3814	0.3841	0.0002	0.3843	1%	1%
4976	19.4	0.1910	0.1910	0.1913	0.0003	0.1916	0%	0%
Absolute Average Percent Difference							1%	1%

LINEAR REGRESSION ANALYSIS *y=mx+b (where x=calculated concentration, y=indicated concentration)*

NO	LIMITS	NOx
Correlation= 1.0000	≥ 0.990	Correlation= 1.0000
m (Slope)= 1.0130	0.90-1.10	m (Slope)= 1.0129
b (Intercept % of FS)= -0.1190	± 3% F.S.	b (Intercept % of FS)= -0.1029

Flow	O ₃ Conc	NO Decrease	NO	NO ₂	NOX	% Diff. Vs Audit gas	
4981	0.000	0.0000	0.7925	-0.0001	0.7924	NO ₂	% Diff. Limit
4981	0.400	0.5347	0.2578	0.5279	0.7857	-1%	± 10%
4981	0.200	0.2490	0.5435	0.2478	0.7913	0%	± 10%
4981	0.090	0.1090	0.6835	0.1095	0.7927	1%	± 10%
Absolute Average Percent Difference						0%	± 10%

LINEAR REGRESSION ANALYSIS *y=mx+b (where x=calculated concentration, y=indicated concentration)*

NO₂	LIMITS
Correlation= 1.0000	≥ 0.995
m (Slope)= 0.9864	0.90-1.10
b (Intercept % of FS)= 0.1136	± 3% F.S.

AENV Standards	NO_x Analyzer
Audit Calibrator	Make/Model <u>Thermo 42i</u>
Make/Model <u>Thermo 146i</u>	Serial/AMU Number <u>1868</u>
Serial/AMU Number <u>1809</u>	Last Calibration Date <u>March 15, 2017</u>
SRM Gas Cylinder No. <u>CAL018140</u>	Full Scale (ppm) <u>1.0</u>
Cylinder Conc. (ppm) <u>48.79</u>	Cylinder Gas Expiry Date <u>March 28, 2019</u>

COMMENTS: Gas has ~50ppm SO2

Auditor: Shea Beaton Date: March 16, 2017

Operator Signature: [Signature] Location: McIntyre Center Edmonton

CALIBRATION GASES



Calibration Gas Audit

Single Component Cylinder Gas

File No. 2016-436CGA

Company: Maxxam **Operator's Name:** Chris

Cylinder #: EY0000769 Concentration PPM: 50.5 Tolerance(%) 1.6 Certified By: Praxair

Expiry Date: December 8, 2019

Reference Calibrator and Gas:

Make/Model: Thermo 146i

Serial Number: AMU 1809

Last Verification Date: January 26, 2017

Gas Type: SO2 Conc. 98.07

Cylinder Number: CAL016625

Expiry Date: January 5, 2019

Flow Measurement Device:

Make/Model: Bios Befiner 220

Serial Number: AMU1941

Temp. °C: 24.4

B.P. 704.7

Reference Analyzer:

Make/Model: Themro 43C Serial/AMU Number: AMU 1623

Instrument Settings: Zero: 9.5 Span: 1.023 Range: 1.0

Last Calibration: Date: 25-Jan-17 C.F. 1.000 Done By: SB

Calibrator Flows (sccm)		Indicated Concentration (PPM)	Gas Flow/ Dilution Flow	Concentration Factor	Cylinder Concentration
Dilution	Gas				
4911	0.0	0.000	0.01574	63.540	50.9
4918	77.4	0.801	0.01574	63.540	50.9
4918	38.5	0.398	0.00783	127.740	50.9
4915	19.2	0.196	0.00391	255.990	50.0
Average Cylinder Concentration:					50.6

Previous Stated Concentration PPM: 50.5

Percent variance from Stated: 0.2

Meets Manufacturer Tolerance. Use manufacturers stated concentration **COMMENTS:** _____

< =5% Outside Manufacturer Tolerance. Use manufacturers concentration _____

> 5% Outside Manufacturer Tolerance. **DO NOT USE** this cylinder _____

Auditor: Shea Beaton

Operator Signature: _____

Date: January 26, 2017

Location: McIntyre Center Edmonton



Calibration Gas Audit

CH₄ / C₃H₈ Cylinder Gas

File No. 2015-029CGA

Company: Maxxam **Operators name:** Limin Li
Cylinder #: LL165367 **Conc CH₄ (PPM)** 590/207 **Tolerance (%)** 2 **Certified By:** Praxair

Reference Calibrator and Gas:				Flow Measurement Device:	
Make/Model	<u>R&R MFC 201</u>			Make/Model	<u>Bios DC2</u>
Serial Number	<u>AMU 1691</u>			Serial Number	<u>AMU 1650</u>
Last Verification Date	<u>May 21, 2015</u>			Temp. °C	<u>24.0 C</u>
Gas Type	<u>CH₄</u>	Conc.	<u>999.2</u>	B.P.	<u>703 mmhg</u>
Cylinder Number	<u>D751932</u>				
Gas Type	<u>C₃H₈</u>	Conc.	<u>246.5</u>		
Cylinder Number	<u>XF0037998</u>				

Reference Analyzer:

Make/Model Teco 55C Serial/AMU Number: 1643
Instrument Settings Zero: N/A Span: N/A Range: 20
Last Calibration: Date: May 21/15 C.F. 1.000 Done By: Al Clark

Calibrator Flows (sccm)		Indicated Conc. (ppm)		Gas Flow/ Dilution Flow	Concentration Factor	Cylinder Concentration	
		CH ₄	C ₃ H ₈			CH ₄	C ₃ H ₈
Dilution	Gas						
2600	0.0	0.00	0.00	0.02005	49.883	602	206
2569	51.5	12.06	11.37	0.02005	49.883	602	206
3549	22.3	3.77	3.57	0.00628	159.148	600	207
3523	10.4	1.77	1.70	0.00295	338.750	600	209
Average Cylinder Concentration:						600	207

<u>CH₄</u>	<u>C₃H₈</u>
Previous Stated Concentration PPM: <u>590</u>	<u>207</u>
Percent variance from Stated: <u>1.8</u>	<u>0.2</u>

Cylinder gas tolerances based on CH₄ only

Meets Manufacturer Tolerance. Use manufacturers stated concentration **COMMENTS:** _____
< =5% Outside Manufacturer Tolerance. Use manufacturers concentration _____
> 5% Outside Manufacturer Tolerance. **DO NOT USE** this cylinder _____

Auditor: Al Clark Date: May 21, 2015
Operator Signature: _____ Location: McIntyre Center Edmonton

APPENDIX IV
REPORT CERTIFICATION FORM

Report Certification Form

Alberta Airshed (if applicable)	EPA Approval or Code of Practice Registration # (if applicable)
YES	NA
Company Name (if applicable)	Industrial Operation Name (if applicable)
Peace River Area Monitoring Program Committee	Three Creeks 842b Station
Name of the Representative of the Person Responsible (Last, First, Middle)	Position / Title of the Representative of the Person Responsible
Maram Ghaleb	Project Manager, Customer Service, Air Services
Is an External Party Certifying the Report? (If 'Yes', fill in the fields below for the external person.)	
<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Name of External Person Certifying the Report (Last, First, Middle)	Position / Title of External Person Certifying the Report
NA	NA
Company Name for the External Person Certifying the Report	Identification of Qualifications / Professional Designations of the External Person Certifying the Report
NA	NA

I certify that I have reviewed and verified the submitted report. I also certify that the report presented with this certification form is complete, accurate and representative of the monitoring results and timeframe.

Maram Ghaleb

Signature of the Representative of the Person Responsible / External Person Certifying the Report

July 26, 2017

Report Issued Date (dd-mm-yyyy)

APPENDIX V
DATA VALIDATION CERTIFICATION FORM



Validation Certificate Form

Client: <u>Peace River Area Monitoring Program Committee</u>	Project #: <u>8449-2017-06-80-C</u>
Site: <u>Three Creeks 842b Station</u>	Contact: <u>Karla Reesor</u>

Level 0 Preliminary Verification	<u>Maram Ghaleb</u>	Date <u>June 30, 2017</u>
Level 1 Primary Validation	<u>Maram Ghaleb</u>	Date <u>June 30, 2017</u>
Level 2 Final Validation	<u>Maram Ghaleb</u>	Date <u>July 18, 2017</u>
Level 3 Independent Data Review	<u>Carla Reesor</u>	Date <u>July 20, 2017</u>
Post-Final Validation	<u>NA</u>	Date <u>NA</u>

Notes
The Post-Final Validation step serves to re-evaluate the data that errors or omissions are discovered and/or suspected after the initial submittal of data. This validation is performed on an annual basis.